

104 FERC ¶ 61,103

UNITED STATES OF AMERICA
FEDERAL ENERGY REGULATORY COMMISSION

18 CFR Part 35

[Docket No. RM02-1-000; Order No. 2003]

Standardization of Generator Interconnection Agreements and Procedures

(Issued July 24, 2003)

AGENCY: Federal Energy Regulatory Commission

ACTION: Final Rule

SUMMARY: The Federal Energy Regulatory Commission (Commission) is amending its regulations under the Federal Power Act to require public utilities that own, control, or operate facilities for transmitting electric energy in interstate commerce to file revised open access transmission tariffs containing standard generator interconnection procedures and a standard agreement that the Commission is adopting in this order and to provide interconnection service to devices used for the production of electricity having a capacity of more than 20 megawatts, under them. Any non-public utility that seeks voluntary compliance with the reciprocity condition of an open access transmission tariff may satisfy this condition by adopting these procedures and this agreement.

EFFECTIVE DATE: This Final Rule will become effective [insert date that is 60 days after publication in the FEDERAL REGISTER.]

FOR FURTHER INFORMATION CONTACT:

Patrick Rooney (Technical Information)
Office of Market, Tariffs and Rates
Federal Energy Regulatory Commission
888 First Street, N.E.
Washington, D.C. 20426
(202) 502-6205

Roland Wentworth (Technical Information)
Office of Market, Tariffs and Rates
Federal Energy Regulatory Commission
888 First Street, N.E.
Washington, D.C. 20426
(202) 502-8262

Bruce Poole (Technical Information)
Office of Market, Tariffs and Rates
Federal Energy Regulatory Commission
888 First Street, N.E.
Washington, D.C. 20426
(202) 502-8468

Michael G. Henry (Legal Information)
Office of the General Counsel
Federal Energy Regulatory Commission
888 First Street, N.E.
Washington, D.C. 20426
(202) 502-8532

SUPPLEMENTARY INFORMATION:

TABLE OF CONTENTS

	Page No.
I. INTRODUCTION	<u>1</u>
A. Background	<u>2</u>
1. Need for Standard Generator Interconnection Procedures and Agreement	<u>3</u>
2. Interconnection ANOPR	<u>5</u>
3. Interconnection NOPR	<u>5</u>
a. Overview of the NOPR	<u>5</u>
b. Severing of Small Generator Issues from the NOPR	<u>6</u>
B. Legal Authority	<u>6</u>
1. The Federal Power Act and Order No. 888	<u>6</u>
2. Commission Interconnection Case Law	<u>7</u>
C. Differences Between the Proposed and Final Rules	<u>9</u>
II. DISCUSSION	<u>9</u>
A. Issues Related to the Standard Large Generator Interconnection Procedures (LGIP)	<u>10</u>
1. Overview	<u>10</u>
2. Section-by-Section Discussion of the Proposed LGIP	<u>14</u>
Section 1 – Definitions	<u>15</u>
Section 2 – Scope and Application	<u>20</u>
Section 3 – Interconnection Request	<u>22</u>
Section 4 – Queue Position	<u>32</u>
Section 5 – Procedures for Interconnection Requests Submitted Prior to Effective Date of Interconnection Procedures	<u>41</u>
Section 6 – Interconnection Feasibility Study	
Section 7 – Interconnection System Impact Study	
Section 8 – Interconnection Facilities Study	
Section 10 – Optional Interconnection Study	<u>44</u>
Section 9 – Engineering & Procurement ("E&P") Agreement ...	<u>50</u>
Section 11 – Standard Large Generator Interconnection Agreement	<u>51</u>
Section 12 – Construction of Transmission Provider's Interconnection Facilities and Network Upgrades	<u>54</u>

Section 13 – Miscellaneous	<u>56</u>
Appendices	<u>63</u>
B. Issues Related to the Standard Large Generator Interconnection Agreement (LGIA)	<u>63</u>
1. Overview	<u>63</u>
2. Article-by-Article Discussion of the Proposed LGIA	<u>64</u>
Article 1 – Definitions	<u>64</u>
Article 2 – Effective Date, Term and Termination	<u>64</u>
Article 3 – Regulatory Filings	<u>69</u>
Article 4 – Scope of Service	<u>70</u>
Article 5 – Interconnection Facilities Engineering, Procurement, and Construction	<u>71</u>
Article 6 – Testing and Inspection	<u>98</u>
Article 7 – Metering	<u>98</u>
Article 8 – Communication	<u>100</u>
Article 9 – Operations	<u>101</u>
Article 10 – Maintenance	<u>112</u>
Article 11 – Performance Obligation	<u>112</u>
Article 12 – Invoice	<u>116</u>
Article 13 – Emergencies	<u>116</u>
Article 14 – Regulatory Requirements and Governing Law	<u>118</u>
Article 15 – Notices	<u>119</u>
Article 16 – Force Majeure	<u>120</u>
Article 17 – Default	<u>121</u>
Article 18 – Indemnity	<u>122</u>
Article 19 – Assignment	<u>124</u>
Article 20 – Severability	<u>125</u>
Article 21 – Comparability	<u>125</u>
Article 22 – Confidentiality	<u>125</u>
Article 23 – Environmental Releases	<u>127</u>
Article 24 – Information Requirements	<u>127</u>
Article 25 – Information Access and Audit Rights	<u>128</u>
Article 26 – Subcontractors	<u>128</u>
Article 27 – Disputes	<u>128</u>
Article 28 – Representations, Warranties and Covenants	<u>128</u>
Article 29 – Joint Operating Committee	<u>128</u>
Article 30 – Miscellaneous	<u>129</u>
Appendices	<u>130</u>
C. Other Significant Policy Issues	<u>130</u>
1. Interconnection Pricing Policy	<u>130</u>
Concerns about the Fairness and Efficiency of the Commission's Crediting Policy	<u>133</u>

	Interconnection Pricing and the Transition to Standard Market Design	<u>139</u>
	The Inability of a Transmission Owner to Recover the Costs of Network Upgrades	<u>140</u>
	Responsibility for Line Outage Costs Resulting from Interconnection	<u>141</u>
	Issues Concerning the Five Year Refund Period and the Payment of Interest	<u>143</u>
	Rules Governing the Payment of Credits	<u>145</u>
	Responsibility for the Costs Incurred by Affected Systems	<u>148</u>
	Policies Regarding Previously Approved Cost Allocations and Pricing Arrangements	<u>149</u>
	Miscellaneous Pricing Issues	<u>151</u>
2.	Interconnection Products and Scope of Service	<u>152</u>
	Definition of Interconnection Products	<u>152</u>
	Pricing of Network Resource Interconnection Service	<u>157</u>
	Study Requirements for Network Resource Interconnection Service	<u>159</u>
	Identification of Types of Interconnection Services to be Studied	<u>160</u>
	Revisions to the Final Rule LGIP and Final Rule LGIA	<u>163</u>
3.	"Distribution" Interconnections	<u>163</u>
4.	Issues Relating to Qualifying Facilities	<u>167</u>
5.	Variations from the Final Rule	<u>170</u>
6.	Waiver Availability for Small Entities	<u>172</u>
7.	OATT Reciprocity Requirements Applied to the Final Rule LGIP and Final Rule LGIA	<u>173</u>
8.	General Comments/Clarifications	<u>176</u>
	a. Insurance	<u>176</u>
	b. Liquidated Damages	<u>177</u>
	c. Consequential Damages	<u>187</u>
	d. Two vs. Three Party Agreements	<u>188</u>
D.	Compliance Issues	<u>189</u>
	1. Amendments to Transmission Providers' OATTs	<u>189</u>

2.	Grandfathering of Existing Interconnection Agreements (ISOs and non-ISOs)	<u>190</u>
3.	Order No. 2001 and the Filing of Interconnection Agreements .	<u>190</u>
III.	INFORMATION COLLECTION STATEMENT	<u>191</u>
IV.	ENVIRONMENTAL IMPACT STATEMENT	<u>193</u>
V.	REGULATORY FLEXIBILITY ACT	<u>194</u>
VI.	DOCUMENT AVAILABILITY	<u>196</u>
VII.	EFFECTIVE DATE AND CONGRESSIONAL NOTIFICATION	<u>196</u>

REGULATORY TEXT

APPENDIX A – Flow Chart of the Large Generating Facility Interconnection Process

APPENDIX B – Commenter Acronyms

APPENDIX C – Standard Large Generator Interconnection Procedures (LGIP),
including Standard Large Generator Interconnection Agreement (LGIA)

104 FERC ¶ 61,103
UNITED STATES OF AMERICA
FEDERAL ENERGY REGULATORY COMMISSION

Before Commissioners: Pat Wood, III, Chairman;
William L. Massey, and Nora Mead Brownell.

Standardization of Generator Interconnection
Agreements and Procedures

Docket No. RM02-1-000

ORDER NO. 2003

FINAL RULE

(Issued July 24, 2003)

I. INTRODUCTION

1. This Final Rule requires all public utilities that own, control or operate facilities used for transmitting electric energy in interstate commerce to have on file standard procedures and a standard agreement for interconnecting generators larger than 20 MW. The Commission expects that this Final Rule will prevent undue discrimination, preserve reliability, increase energy supply, and lower wholesale prices for customers by increasing the number and variety of new generation that will compete in the wholesale electricity market.

2. This Final Rule requires public utilities that own, control, or operate facilities for transmitting electric energy in interstate commerce to file revised open access transmission tariffs (OATTs) to add Standard Large Generator Interconnection Procedures (Final Rule LGIP)¹ and a Standard Large Generator Interconnection Agreement (Final Rule LGIA).² Any non-public utility that seeks voluntary compliance with the reciprocity condition of an open access transmission tariff may satisfy this condition by adopting this Agreement and these procedures.

3. The Final Rule LGIP sets forth the procedures that Interconnection Customers and Transmission Providers are required to follow during the interconnection process.³ The

¹Readers may note that provisions of the Final Rule LGIP are referred to as "Sections" whereas provisions of the Final Rule LGIA are referred to as "Articles."

²Such filings must be made within 60 days of publication of this Final Rule in the Federal Register.

³Unless otherwise defined in this Preamble, capitalized terms used in this Final Rule have the meanings specified in Section 1 of the Final Rule LGIP and Article 1 of the Final Rule LGIA. The term Generating Facility means the specific device for which the Interconnection Customer has requested interconnection. The owner of the

(continued...)

Final Rule LGIA sets forth the legal rights and obligations of each Party, addresses cost responsibility issues, and establishes a process for resolving disputes.

4. The Federal Energy Regulatory Commission's (Commission's) authority to require the addition of the Final Rule LGIA and Final Rule LGIP to the OATT derives from its findings of undue discrimination in the interstate electric transmission market that formed the basis for Order No. 888.⁴ The Commission here adopts standard procedures and a standard agreement to be used by Transmission Providers with Interconnection Customers proposing to interconnect a generator of more than 20 MW to sell energy at wholesale in interstate commerce. The Final Rule LGIP and Final Rule LGIA apply to any new Interconnection Request to a Transmission Provider's Transmission System.⁵ The Commission is not requiring any retroactive changes to individual (versus generic) interconnection agreements filed with the Commission prior to the effective date of this Final Rule.

A. Background

5. The electric power industry continues to be in transition. Where the industry once comprised mainly large, vertically integrated utilities providing bundled power at cost-based rates, companies selling unbundled wholesale power at rates set by competitive markets have now become common. Balanced market rules and sufficient infrastructure are essential for achieving power markets that will provide customers with reasonably priced and reliable service.

6. The Commission continues to work to encourage fully competitive bulk power markets. The effort took its first major step with Order No. 888, which required public

³(...continued)

Generating Facility is referred to as the Interconnection Customer. The entity (or entities) with which the Generating Facility is interconnecting is referred to as the Transmission Provider. The term Large Generator is intended to refer to any energy resource having a capacity of more than 20 megawatts, or the owner of such a resource.

⁴Promoting Wholesale Competition Through Open Access Non-Discriminatory Transmission Services by Public Utilities; Recovery of Stranded Costs by Public Utilities and Transmitting Utilities, Order No. 888, 61 FR 21540 (May 10, 1996), FERC Stats. & Regs. ¶ 31,036 (1996), order on reh'g, Order No. 888-A, 62 FR 12274 (Mar. 14, 1997), FERC Stats. & Regs. ¶ 31,048 (1997), order on reh'g, Order No. 888-B, 81 FERC ¶ 61,248 (1997), order on reh'g, Order No. 888-C, 82 FERC ¶ 61,046 (1998), aff'd in relevant part sub nom. Transmission Access Policy Study Group v. FERC, 225 F.3d 667 (D.C. Cir. 2000), aff'd sub nom. New York v. FERC, 535 U.S. 1 (2002).

⁵New Interconnection Requests include those submitted after the effective date of this Final Rule and include requests to increase the capacity of, or modify the operating characteristics of, an existing Generating Facility that is interconnected with the Transmission Provider's Transmission System.

utilities to provide other entities comparable access to their facilities for transmitting electricity in interstate commerce, and continued with Order No. 2000,⁶ which encouraged the development of Regional Transmission Organizations (RTOs).

7. In this proceeding the Commission, pursuant to its responsibility under Sections 205 and 206 of the Federal Power Act (FPA) to remedy undue discrimination, requires all public utilities that own, control, or operate facilities for transmitting electric energy in interstate commerce to append to their OATTs a Final Rule LGIP and Final Rule LGIA. The Commission believes that these documents will provide just and reasonable terms and conditions of transmission service while ensuring that reliability is protected and that they will provide a reasonable balance between the competing goals of uniformity and flexibility.

1. Need for Standard Generator Interconnection Procedures and Agreement

8. In April 1996, in Order No. 888, the Commission established the foundation necessary to develop competitive bulk power markets in the United States: non-discriminatory open access transmission services by public utilities and stranded cost recovery rules to provide a fair transition to competitive markets. Order No. 888 did not directly address generator interconnection issues.

9. In Tennessee Power Company⁷ (Tennessee) the Commission clarified that interconnection is a critical component of open access transmission service and thus is subject to the requirement that utilities offer comparable service under the OATT. In Tennessee the Commission encouraged, but did not require, each Transmission Provider to revise its OATT to include interconnection procedures, including a standard interconnection agreement and specific criteria, procedures, milestones, and time lines for evaluating Interconnection Requests.⁸

10. The Commission to date has addressed interconnection issues on a case-by-case basis. Although a number of Transmission Providers have filed interconnection procedures as part of their OATTs,⁹ many industry participants remain dissatisfied with

⁶Regional Transmission Organizations, Order No. 2000, 65 FR 810 (Jan. 6, 2000), FERC Stats. & Regs. ¶ 31,089 (1999), order on reh'g, Order No. 2000-A, 65 FR 12,088 (Mar. 8, 2000), FERC Stats. & Regs. ¶ 31,092 (2000), aff'd sub nom. Public Util. Dist. No. 1 v. FERC, 272 F.3d 607 (D.C. Cir. 2001).

⁷Tennessee Power Company, 90 FERC ¶ 61,238 (2002).

⁸See, e.g., Commonwealth Edison Co., 91 FERC ¶ 61,083 (2000).

⁹See, e.g., American Electric Power Service Corp., 91 FERC ¶ 61,308 (2000), order denying reh'g and granting clarification, 94 FERC ¶ 61,166, order dismissing request for clarification, 95 FERC ¶ 61,130 (2001), appeal docketed sub nom. Tenaska,

existing interconnection policy and procedures. With the increasing number of interconnection-related disputes, it has become apparent that the case-by-case approach is an inadequate and inefficient means to address interconnection issues.

11. Interconnection plays a crucial role in bringing much-needed generation into the market to meet the growing needs of electricity customers. Further, relatively unencumbered entry into the market is necessary for competitive markets. However, requests for interconnection frequently result in complex, time consuming technical disputes about interconnection feasibility, cost, and cost responsibility. This delay undermines the ability of generators to compete in the market and provides an unfair advantage to utilities that own both transmission and generation facilities. The Commission concludes that there is a pressing need for a single set of procedures for jurisdictional Transmission Providers and a single, uniformly applicable interconnection agreement for Large Generators.¹⁰ A standard set of procedures as part of the OATT for all jurisdictional transmission facilities will minimize opportunities for undue discrimination and expedite the development of new generation, while protecting reliability and ensuring that rates are just and reasonable.

12. Interconnection is a critical component of open access transmission service, and standard interconnection procedures and a standard agreement applicable to Large Generators will serve several important functions: they will (1) limit opportunities for Transmission Providers to favor their own generation, (2) facilitate market entry for generation competitors by reducing interconnection costs and time, and (3) encourage needed investment in generator and transmission infrastructure. The Commission expects that the Final Rule LGIP and Final Rule LGIA (as well as the documents that will be developed in the Small Generator Interconnection proceeding B see footnote 10, supra) will resolve most disputes, minimize opportunities for undue discrimination, foster increased development of economic generation, and protect system reliability. Therefore, the Commission adopts the Final Rule LGIP and Final Rule LGIA, which will be required

⁹(...continued)

Inc. v. FERC, No. 01-1194 (D.C. Cir. Apr. 23, 2001); Southwest Power Pool, Inc., 92 FERC ¶ 61,109 (2000); Carolina Power & Light Co., 93 FERC ¶ 61,032 (2000), reh'g denied, 94 FERC ¶ 61,165 (2001), appeal docketed sub nom. Tenaska, Inc. v. FERC, No. 01-1195 (D.C. Cir. Apr. 23, 2001); Virginia Electric & Power Co., 93 FERC ¶ 61,307 (2000), order on clarification, 94 FERC ¶ 61,045, reh'g denied, 94 FERC ¶ 61,164 (2001), appeal docketed sub nom. Tenaska, Inc. v. FERC, No. 01-1196 (D.C. Cir. Apr. 23, 2001); Consumers Energy Co., 93 FERC ¶ 61,339 (2000), order on reh'g and clarification, 94 FERC ¶ 61,230, order on clarification and denying reh'g, 95 FERC ¶ 61,131 (2001).

¹⁰In another rulemaking, the Commission proposes a separate set of procedures and an agreement applicable to Small Generators (any energy resource having a capacity of no larger than 20 MW, or the owner of such a resource) that seek to interconnect to jurisdictional Transmission Providers. See Standardization of Small Generator Interconnection Agreements and Procedures, Notice of Proposed Rulemaking, Docket No. RM02-12-000(issued concurrently with this Final Rule) 104 FERC ¶ 61,104.

as an amendment to the OATT of each public utility that owns, controls, or operates facilities for transmitting electric energy in interstate commerce. As discussed below, more flexibility is available to independent transmission entities in the procedures and agreement they must adopt as compared with the standard provisions adopted herein.

2. Interconnection ANOPR

13. The Commission issued an Advance Notice of Proposed Rulemaking (ANOPR) regarding generator interconnection on October 25, 2001.¹¹ As a point of departure, the ANOPR presented the Standard Generator Interconnection Procedures and Standard Generation Interconnection Agreement of the Electric Reliability Council of Texas (ERCOT).¹² The Commission supplemented and modified the ERCOT documents with various "best practices" that were identified in Attachment A to the ANOPR. These "best practices" were based, in part, on generator interconnection procedures and agreements that had been approved by the Commission in past cases. The ANOPR instructed the commenters and parties to assume that the Commission's current pricing policy, as described in ANOPR Attachment B, would remain in effect.

14. The ANOPR initiated a consensus-making process in which members of various segments of the electric power industry, government, and the public had an opportunity to provide input. This effort resulted in two documents that largely shaped the Notice of Proposed Rulemaking (Large Generator Interconnection NOPR) that followed.¹³ These two documents are referred to as the Consensus LGIP and Consensus LGIA (although a consensus was not reached on all issues). The Commission received numerous comments, primarily from Transmission Providers, Transmission Owners, generators (herein called Interconnection Customers), and state regulators, on the ANOPR and the Consensus LGIP and Consensus LGIA.

3. Interconnection NOPR

a. Overview of the NOPR

15. Although the negotiators did not reach consensus on every issue, the Consensus LGIP and LGIA reflect substantial agreement among diverse interests. The Commission used these documents and the comments on them to create the proposed standard LGIP and LGIA documents (NOPR LGIP and NOPR LGIA). Generally, the NOPR used the

¹¹Standardizing Generator Interconnection Agreements and Procedures, Advance Notice of Proposed Rulemaking, 66 FR 55140 (Nov. 1, 2001), FERC Stats. & Regs. ¶ 35,540 (2001).

¹²The ERCOT agreement and procedure were appended to the ANOPR as Appendix A.

¹³Standardization of Generator Interconnection Agreements and Procedures, Notice of Proposed Rulemaking, 67 FR 22250 (May 2, 2002), FERC Stats. & Regs. ¶ 32,560 (2002).

Consensus LGIP and LGIA provisions where there was agreement. Where the participants could not reach consensus on a particular issue and options were presented in the Consensus LGIP and LGIA, the Commission chose between those options guided by the principle of minimizing barriers to entry of new generation without increasing the risk of reliability problems. Where an issue remained unresolved and no option was presented, the Commission generally proposed the ERCOT provision.

b. Severing of Small Generator Issues from the NOPR

16. In their comments on the interconnection NOPR, supporters of Small Generators (which are defined herein as devices for the production of electricity having a capacity no more than 20 MW) requested that the Commission adopt separate rules and procedures for interconnecting Small Generators. They argued that use of a Final Rule LGIP and Final Rule LGIA designed for Large Generators would unduly hinder the development of Small Generators. They sought streamlined procedures and requirements that would allow an Interconnection Customer with a Small Generator to avoid delays caused by studying sequentially the effects of interconnecting its generator with the Transmission Provider's electric system.

17. Persuaded by this request, the Commission decided to propose separate Small Generator interconnection procedures and an agreement (SGIP and SGIA) to provide the right incentives for both Transmission Providers and Interconnection Customers with Small Generators.¹⁴ To that end, the Commission severed the issues related to interconnecting generators no larger than 20 MW from this proceeding and initiated another rulemaking docket, RM02-12-000, for the former.¹⁵

B. Legal Authority

1. The Federal Power Act and Order No. 888

18. In fulfilling its responsibilities under Sections 205 and 206 of the Federal Power Act,¹⁶ the Commission is required to address, and has the authority to remedy, undue discrimination. The Commission must ensure that the rates, contracts, and practices affecting jurisdictional transmission do not reflect an undue preference or advantage for non-independent Transmission Providers and are just and reasonable. Additionally, as discussed in Order No. 888, the Commission's regulatory authority under the Federal

¹⁴The Small Generator Interconnection ANOPR proposed adopting two Small Generator Interconnection Procedures documents and two Small Generator Interconnection Agreements, with the distinction between the two sets of documents being the size of the Small Generator.

¹⁵See Standardization of Small Generator Interconnection Agreements and Procedures, Advance Notice of Proposed Rulemaking, 67 FR 54749 (Aug. 26, 2002), FERC Stats. & Regs. ¶ 35,544 (2002).

¹⁶16 U.S.C. 824d, 824e (2000).

Power Act "clearly carries with it the responsibility to consider, in appropriate circumstances, the anticompetitive effects of regulated aspects of interstate utility operations pursuant to [FPA] §§ 202 and 203, and under like directives contained in Sections 205, 206, and 207."¹⁷

19. The record underlying Order No. 888 showed that public utilities owning or controlling jurisdictional transmission facilities had the incentive to engage in, and had engaged in, unduly discriminatory transmission practices.¹⁸ The Commission in Order No. 888 also thoroughly discussed the legislative history and case law involving Sections 205 and 206, concluded that it had the authority and responsibility to remedy the undue discrimination it had found by requiring open access, and decided to do so through a rulemaking on a generic, industrywide basis.¹⁹ The Supreme Court affirmed the Commission's decision to exercise this authority by requiring non-discriminatory (comparable) open access as a remedy for undue discrimination.²⁰

20. The Commission has identified interconnection as an element of transmission service that is required to be provided under the OATT.²¹ Thus, the Commission may order generic interconnection terms and procedures pursuant to its authority to remedy undue discrimination and preferences under Sections 205 and 206 of the Federal Power Act.

2. Commission Interconnection Case Law

21. Unless expressly changed in this Final Rule, the holdings in the Commission's existing interconnection precedents will remain a useful guide during the implementation of this Final Rule. The Commission's interconnection cases have drawn the distinction between Interconnection Facilities and Network Upgrades. Interconnection Facilities are found between the Interconnection Customer's Generating Facility and the Transmission Provider's Transmission System. The Commission has developed a simple test for distinguishing Interconnection Facilities from Network Upgrades: Network Upgrades

¹⁷Gulf States Utils. Co. v. FPC, 411 U.S. 747, 758-59 (1973); see City of Huntingburg v. FPC, 498 F.2d 778, 783-84 (D.C. Cir. 1974) (noting the Commission's duty to consider the potential anticompetitive effects of a proposed interconnection agreement).

¹⁸Order No. 888, FERC Stats. & Regs ¶ 31,036 at 31,679-84; Order No. 888-A, FERC Stats. & Regs ¶ 31,048 at 30,209-10.

¹⁹Order No. 888, FERC Stats. & Regs ¶ 31,036 at 31,668-73, 31,676-79; Order No. 888-A, FERC Stats. & Regs ¶ 31,048 at 30,201-12; TAPS v. FERC, 225 F.3d 667, 687-88 (D.C. Cir. 2000).

²⁰New York v. FERC, 535 U.S. 1 (2002) .

²¹See Tennessee Power Co., 90 FERC ¶ 61,238 at 61,761, reh'g dismissed, 91 FERC ¶ 61,271 (2000).

include only facilities at or beyond the point where the Interconnection Customer's Generating Facility interconnects to the Transmission Provider's Transmission System.²² The Commission has made clear that Interconnection Agreements are evaluated by the Commission according to the just and reasonable standard.²³ Most improvements to the Transmission System, including Network Upgrades, benefit all transmission customers, but the determination of who benefits from such Network Upgrades is often made by a non-independent transmission provider, who is an interested party. In such cases, the Commission has found that it is just and reasonable for the Interconnection Customer to pay for Interconnection Facilities but not for Network Upgrades. Agreements between the Parties to classify Interconnection Facilities as Network Upgrades, or to otherwise directly assign the costs of Network Upgrades to the Interconnection Customer, have not been found to be just and reasonable and have been rejected by the Commission.²⁴

22. Regarding pricing for a non-independent Transmission Provider, the distinction between Interconnection Facilities and Network Upgrades is important because Interconnection Facilities will be paid for solely by the Interconnection Customer, and while Network Upgrades will be funded initially by the Interconnection Customer (unless the Transmission Provider elects to fund them), the Interconnection Customer would then be entitled to a cash equivalent refund (*i.e.*, credit) equal to the total amount paid for the Network Upgrades, including any tax gross-up or other tax-related payments. The refund would be paid to the Interconnection Customer on a dollar-for-dollar basis, as credits against the Interconnection Customer's payments for transmission services, with the full amount to be refunded, with interest within five years of the Commercial Operation Date. The Commission has clarified that transmission credits may be used whether or not a Generating Facility is being dispatched and that credits must be accepted for all network transmissions by the Interconnection Customer, regardless of whether the plant from which the credits originated is dispatched.²⁵ Credits are not tied to any particular Generating Facility.²⁶ The Commission has stated that peaking facilities, for instance, must be allowed to use credits even when the Generating Facility is not dispatched.²⁷ The Commission has also allowed Transmission Providers to require

²²Entergy Gulf States, Inc., 98 FERC ¶ 61,014 at 61,023, reh'g denied, 99 FERC ¶ 61,095 (2002); see Public Service Co. of Colorado, 59 FERC ¶ 61,311 (1992), reh'g denied, 62 FERC ¶ 61,013 at 61,061 (1993).

²³Pacific Gas & Electric Company, et al., 102 FERC ¶ 61,070 (2003).

²⁴See, e.g. Illinois Power Co., 103 FERC ¶ 61,032 (2003); American Electric Power Service Corp., 101 FERC ¶ 61,194 (2002).

²⁵Entergy Services, Inc., 101 FERC ¶ 61,289 (2002).

²⁶Id.

²⁷Colton Power, LP, 101 FERC ¶ 61,150 (2002).

several Interconnection Customers to share the costs of Network Upgrades, under certain circumstances.²⁸

23. The Commission has also clarified that an Interconnection Customer need not enter into an agreement for the delivery component of transmission service to interconnect with a Transmission Providers' Transmission System.²⁹ At the same time, Interconnection Service or an interconnection by itself does not confer any delivery rights from the Generating facility to any points of delivery.³⁰

24. The Commission has clarified that ownership of the Interconnection Facilities does not have a direct effect on reliability of the system. Therefore, as long as the Transmission Provider operates the Interconnection Facilities, the Commission will allow an Interconnection Customer to own part, or all, of those facilities.³¹

C. Differences Between the Proposed and Final Rules

25. The Final Rule LGIP and Final Rule LGIA largely track the proposed documents. Changes made in the Final Rule tend to be specific to an individual LGIP section or LGIA article, and do not require fundamental changes to the documents. That being said, there are a few significant issues, some substantive and others organizational, that the Commission summarizes here.

26. Most importantly, we note that the Final Rule applies to independent and non-independent Transmission Providers alike, but non-independent Transmission Providers are required to adopt the Final Rule LGIP and Final Rule LGIA into their OATTs, with deviations from the Final Rule justified using either the "regional differences" or "consistent with or superior to" standard. We also allow Regional Transmission Organizations (RTOs) and ISOs more flexibility to customize an LGIP and LGIA to meet their regional needs. This applies to terms and conditions as well as pricing. While RTOs and ISOs are required to submit compliance filings, they may submit LGIP and LGIA terms and conditions that meet an "independent entity variation" standard that is more flexible than the "consistent with or superior to" standard and the regional differences standard.

27. We are also including in the Final Rule LGIA an article addressing insurance requirements and limiting liability for consequential damages, both of which were absent

²⁸Id.

²⁹Entergy Services, Inc., 101 FERC ¶ 61,016 (2002); Southern Company Services, Inc., 95 FERC ¶ 61,307 at 62,049, order dismissing reh'g, 96 FERC ¶ 61,168 (2001); Tennessee Power Co., 90 FERC ¶ 61,238 at 61,761 (2000).

³⁰See Arizona Public Service Co., 94 FERC ¶ 61,027 at 61,076, order on reh'g, 94 FERC ¶ 61,267 (2001).

³¹Arizona Public Service Company, 102 FERC ¶ 61,303 (2003).

from the NOPR. Provision for liquidated damages had been removed from the Final Rule LGIP but remains an option in the Final Rule LGIA. Also, in the Final Rule LGIP, when a Transmission Provider elects to study Interconnection Requests in Clusters, it would simultaneously study all Interconnections Requests received within a 180 day window, rather than a 90 day window as proposed.

28. On pricing, we clarify the approach set forth in the NOPR. We continue our current policy of requiring a Transmission Provider that is not an independent entity to provide transmission credits for the cost of Network Upgrades needed for a Generating Facility interconnection. For a Transmission Provider that is an independent entity, such as an RTO or ISO, we allow flexibility as to the specifics of the interconnection pricing policy. Also, an RTO or ISO may propose participant funding for Network Upgrades for a generator interconnection, and, for a transitional period not to exceed a year, a region may use participant funding as soon as an independent administrator has been approved by the Commission and the affected states.

29. Where the policy of transmission credits for upgrades required as a result of the interconnection applies, the Commission provides several clarifications in this Final Rule. For example, the Interconnection Customer should receive transmission credits only if its Generating Facility has achieved commercial operation. Transmission credits are to be paid to the Interconnection Customer when upgrades to an Affected System³² are constructed and the Interconnection Customer has paid for them. Finally, the Transmission Provider may decline to award credits for only those transmission charges that are designed to recover out-of-pocket costs, such as the cost of line losses, associated with the delivery of the output of the Generating Facility.

II. DISCUSSION

30. In Part A of this discussion we address the Standard Large Generator Interconnection Procedures (Final Rule LGIP) that specify the details of the uniform process a prospective Interconnection Customer and its Transmission Provider shall use to initiate, evaluate, and implement an Interconnection Request pursuant to the Final Rule.

31. In Part B we discuss the details of the Standard Large Generator Interconnection Agreement (Final Rule LGIA) to be executed by the prospective Interconnection Customer, the Transmission Provider and, where appropriate, the Transmission Owner. This document is incorporated as Appendix 6 to the Standard Large Generator Interconnection Procedures and covers the related rights and obligations of the Parties.³³

³²An Affected System is an electric system other than the Transmission Provider's Transmission System that may be affected by the proposed interconnection.

³³The Final Rule LGIP and Final Rule LGIA define Party or Parties as "Transmission Provider, Transmission Owner, Interconnection Customer, or any combination of the above."

32. In Part C, we discuss a number of other significant policy issues in connection with this rulemaking, including pricing policies; the required Interconnection Services; the treatment of "Distribution" level interconnections; Qualifying Facility matters; variations from the Final Rule and accommodation of regional differences; the availability of waivers for small entities; OATT reciprocity implications for interconnection requests; assorted clarifications to the NOPR's proposals; insurance and liquidated damages matters; two- versus three party interconnection agreements; and consequential damage issues.

33. In Part D, we address Compliance Issues pertaining to the requirement for a Transmission Provider to file conforming amendments to its existing OATT; the treatment to be accorded existing interconnection agreements (grandfathering); and the method a Transmission Provider is to use to file executed and unexecuted interconnection agreements in accord with this Final Rule.

A. Issues Related to the Standard Large Generator Interconnection Procedures (LGIP)

1. Overview³⁴

34. The Final Rule Standard Large Generator Interconnection Procedures (LGIP) document specifies the steps that must be followed and deadlines that must be met when an Interconnection Customer requests interconnection of either a new Generating Facility or the expansion of an existing Generating Facility with the Transmission Provider's Transmission System.³⁵ The Commission directs each public utility to amend its OATT with a single compliance filing to incorporate the Final Rule LGIP and the Standard Large Generator Interconnection Agreement (LGIA) documents. RTOs and ISOs must also make compliance filings, but as discussed above, will have more flexibility to propose different procedures and a different agreement.

35. The Final Rule LGIP sets forth the following steps to secure an interconnection. First, the prospective Interconnection Customer will submit an Interconnection Request to the Transmission Provider along with a \$10,000 deposit, preliminary site documentation, and the expected In-Service Date.³⁶ The Transmission Provider will acknowledge receipt of the request and promptly notify the Interconnection Customer if its request is deficient. When the Interconnection Request is complete, the Transmission

³⁴For the convenience of the reader, a flow chart depicting the interconnection process is appended to this preamble as Appendix A.

³⁵Any Transmission Provider with an Interconnection Request outstanding at the time this Final Rule becomes effective shall transition to the Final Rule LGIP within a reasonable period of time. This is further described in Final Rule LGIP Section 5.1.

³⁶The standard form of Interconnection Request is Appendix 1 of the LGIP document.

Provider will place it in its interconnection queue with other pending requests. The Transmission Provider will assign a Queue Position to each completed Interconnection Request based on the date and time of its receipt.³⁷ Queue Position is used to determine the order of performing the various Interconnection Studies and the assignment of cost responsibility for the construction of facilities necessary to accommodate the Interconnection Request.³⁸ The Transmission Provider will also maintain a list of all Interconnection Requests³⁹ on its OASIS.⁴⁰

36. The Parties will then schedule a Scoping Meeting to discuss possible Points of Interconnection and exchange technical information, including data that would reasonably be expected to affect such interconnection options.⁴¹ The Scoping Meeting is followed by a series of Interconnection Studies to be performed by, or at the direction of, the Transmission Provider to evaluate the proposed interconnection in detail, identify any Adverse System Impacts on the Transmission Provider's Transmission System or Affected Systems, and specify the facility modifications that are needed to safely and reliably complete the interconnection.⁴² These studies include:

³⁷For example, the first complete Interconnection Request, assigned an earlier Queue Position, is "higher-queued" relative to the second complete Interconnection Request that is assigned a later Queue Position and is "lower queued." The withdrawal of a complete Interconnection Request causes it to lose its Queue Position and all succeeding complete Interconnection Requests to advance, accordingly.

³⁸Any Interconnection Customer assigned a Queue Position before the effective date of this Final Rule would retain that Queue Position.

³⁹We emphasize that the Final Rule LGIP requires the Transmission Provider, the Transmission Owner, and such entities' officers, employees, and contractors to maintain proper procedures for Confidential Information provided by an Interconnection Customer related to the Interconnection Request, the disclosure of which could harm or prejudice the Interconnection Customer or its business.

⁴⁰Open Access Same-Time Information System and Standards of Conduct, Order No. 889, 61 FR 21737 (May 10, 1996), FERC Stats. & Regs. ¶ 31,035 at 31,590 (1996), order on reh'g, Order No. 889-A, 62 FR 12484 (Mar. 14, 1997), FERC Stats. & Regs. ¶ 31,049 (1997), reh'g denied, Order No. 889-B, 81 FERC ¶ 61,253 (1997), aff'd in relevant part sub nom. Transmission Access Policy Study Group v. FERC, 225 F.3d 667 (D.C. Cir. 2000), aff'd sub nom. New York v. FERC, 535 U.S. 1 (2002).

⁴¹The Scoping Meeting will address technical matters such as facility loadings, general instability issues, general short-circuit issues, general voltage issues, and general reliability issues that would affect the Interconnection Customer's designation of its Point of Interconnection.

⁴²The standard forms of agreement for the Interconnection Feasibility Study, the Interconnection System Impact Study, the Interconnection Facilities Study, and the

(continued...)

- (1) Interconnection Feasibility Study to evaluate on a preliminary basis the feasibility of the proposed interconnection, using power flow and short-circuit analyses (to be completed within 45 Calendar Days from the date of signing of an Interconnection Feasibility Study Agreement) (study requires a \$10,000 deposit);
- (2) Interconnection System Impact Study to evaluate on a comprehensive basis the impact of the proposed interconnection on the reliability of Transmission Provider's Transmission System and Affected Systems, using a stability analysis, power flow, and short-circuit analyses (to be completed within 60 Calendar Days from the date of signing of an Interconnection System Impact Study Agreement) (study requires a \$50,000 deposit);⁴³
- (3) Interconnection Facilities Study to determine a list of facilities (including Transmission Provider's Interconnection Facilities and Network Upgrades as identified in the Interconnection System Impact Study), the cost of those facilities, and the time required to interconnect the Generating Facility with the Transmission Provider's Transmission System (to be completed within 90-180 Calendar Days from the date of signing of an Interconnection Facilities Study Agreement) (study requires a \$100,000 deposit or an estimated monthly cost developed by the Transmission Provider for conducting the Interconnection Facilities Study); and
- (4) Optional Interconnection Study or sensitivity analysis of various assumptions specified by the Interconnection Customer to identify any Network Upgrades that may be required to provide transmission delivery service over alternative transmission paths for the electricity produced by the Generating Facility and (study requires a \$10,000 deposit).

37. The Interconnection Feasibility Study, the Interconnection System Impact Study, and the Interconnection Facilities Study must be performed in the above order, with completion of each study before the next begins.⁴⁴ An Interconnection Customer may

⁴²(...continued)

Optional Interconnection Study, are included at Appendices 2-4 to the Final Rule LGIP, respectively.

⁴³At the Transmission Provider's option, Interconnection System Impact Studies for multiple Generating Facilities may be conducted serially or in clusters.

⁴⁴These Interconnection Studies are typical of the kinds of studies undertaken by Transmission Providers to evaluate Interconnection Requests. The Interconnection Facilities Studies and Interconnection System Impact Studies also correspond to transmission service studies described in the pro forma open access tariff. See Order No. 888-A (Tariff Part II, 19 Additional Study Procedures For Firm Point-To-Point

(continued...)

also request a restudy of any of the above if a higher-queued project either drops out of the queue, is subjected to Material Modifications, or changes its Point of Interconnection.⁴⁵ The Interconnection Customer will pay the actual costs for performing each of the Interconnection Studies and restudies.

38. The Transmission Provider's Interconnection Facilities Study report⁴⁶ will include a best estimate of the costs to effect the requested interconnection which are to be funded up-front by the Interconnection Customer. At the same time as the report is issued, the Transmission Provider shall also give the Interconnection Customer a draft interconnection agreement completed to the extent practicable.⁴⁷ The Transmission Provider and the Interconnection Customer will then negotiate the schedule for constructing and completing any necessary Transmission Provider Interconnection Facilities and Network Upgrades, and incorporate this schedule into the interconnection agreement that is signed by the Parties.⁴⁸

2. Section-by-Section Discussion of the Proposed LGIP

⁴⁴(...continued)

Transmission Service Requests; and Tariff Part III, 32 Additional Study Procedures For Network Integration Transmission Service Requests), FERC Stats. & Regs., Regulations Preambles (July 1996-December 2000), ¶ 31,048 at 30,524-26 and 30,535-36.

⁴⁵An Interconnection Feasibility Restudy must be completed within 45 Calendar Days of such request. Similarly, the Transmission Provider has 60 Calendar Days to complete either an Interconnection System Impact Restudy or an Interconnection Facilities Restudy.

⁴⁶Upon the completion of each of the Interconnection Studies, a report is prepared which presents the results of the analyses.

⁴⁷The draft interconnection agreement shall include: Appendix A, Interconnection Facilities, Network Upgrades and Distribution Upgrades; Appendix B, Milestones; Appendix C, Interconnection Details; Appendix D, Security Arrangements Details; Appendix E, Commercial Operation Date; and Appendix F, Addresses for Delivery of Notices and Billings.

⁴⁸In general, the In-Service Date of an Interconnection Customer's Generating Facility or Generating Facility expansion will determine the sequence of construction of Network Upgrades. An Interconnection Customer, in order to achieve its expected In-Service Date, may request that the Transmission Provider advance the completion of Network Upgrades necessary to support such In-Service Date that would otherwise not be completed pursuant to a contractual obligation of an entity other than the Interconnection Customer. The Transmission Provider will use Reasonable Efforts to advance the construction if the Interconnection Customer reimburses it for any associated expediting costs and the cost of such Network Upgrades. The Interconnection Customer is entitled to transmission credits for the expediting costs that it pays.

39. What follows is a discussion of the standard interconnection procedures the Commission proposed, the comments received, and the Commission's conclusion. The order of discussion follows the organization of the proposed LGIP, covering Sections 1-13. Only subsections for which issues are raised are presented. For example, we discuss Section 2.3, but not Sections 2.1 or 2.2 because no significant issues were raised regarding Sections 2.1 or 2.2. Readers should note that section numbers referred to in the following discussion are the numbers contained in the proposed LGIP. Some proposed sections are renumbered in the Final Rule; mention of that fact will be made in the Commission Conclusions discussion, where appropriate. Also, note that Proposed LGIP Section 14 is eliminated from the Final Rule in its entirety because provisions for interconnection procedures and an interconnection agreement for Small Generators have been severed from this proceeding, as discussed, supra.

40. **Section 1 – Definitions** – Section 1 of the NOPR LGIP and Article 1 of the NOPR LGIA contained defined terms that appeared in the respective documents. For the sake of consistency, the Final Rule LGIP and Final Rule LGIA contain one common set of terms. Included in the list of defined terms are a number of new terms which were not included in the NOPR LGIP and NOPR LGIA. Comments relating to the definition of terms in both documents are discussed below.

41. **Ancillary Services** (In the NOPR: Ancillary and Other Services) – The NOPR proposed that Ancillary and Other Services would have the same meaning as defined in the Transmission Provider's OATT and include some other services such as generator balancing, black start, and automatic generation control.

Comments

42. Cinergy and Entergy claim that this term is not used in the LGIA and that its definition should be deleted.

Commission Conclusion

43. The Commission disagrees that the definition should be deleted. The term is used in Article 9 of the NOPR LGIA and elsewhere. However, to be consistent with the OATT, the Commission here adopts the definition of Ancillary Services in Order No. 888: "Those services that are necessary to support the transmission of capacity and energy from resources to loads while maintaining reliable operation of the Transmission Provider's Transmission System in accordance with Good Utility Practice."

44. **Commercial Operation Date** – The NOPR proposed to define Commercial Operation Date as the date on which the Generating Facility commences commercial operation of a unit at the Generating Facility after Trial Operation of the unit is completed, as confirmed in writing, in accordance with proposed Appendix F to the NOPR LGIA.

Comments

45. Central Maine points out that when a Generating Facility consists of more than one generating unit, under the NOPR, the Commercial Operation Date depends on the operability of a generating unit after its testing. Central Maine requests that the Commission define the term Commercial Operation Date as the date on which the Generating Facility as a whole commences commercial operation, not the individual generating units.

Commission Conclusion

46. The Commission is not adopting Central Maine's proposal. The Generating Facility (referred to as the Facility in the NOPR LGIP and NOPR LGIA) could consist of multiple generating units with substantially different Commercial Operation Dates. Under Central Maine's proposal, all of the Generating Facilities at the complex would be required to undergo a pre-commercial Trial Operation each time a new generating unit at the Generating Facility is ready to commence commercial operation. Central Maine gives no reason why this should be required. Furthermore, revising the NOPR LGIP is unnecessary because Article 6.1 of the NOPR LGIA (Pre-Commercial Operation Date, Testing and Modifications) addresses testing of the Generating Facility and the Interconnection Customer's Interconnection Facilities to ensure their safe and reliable operation.

47. **Generating Facility** (In the NOPR: Facility) – The NOPR proposed to define the term Facility as the Interconnection Customer's generator, as identified in the Interconnection Request, but excluding the Interconnection Customer's Interconnection Facilities. In this Final Rule, the Commission has renamed Facility to Generating Facility to avoid confusion between other facilities and equipment.

Comments

48. Central Maine states that a full description of the Generating Facility should be attached to the interconnection agreement as an appendix.

Commission Conclusion

49. The Commission concludes that it unnecessary to append a description of the Generating Facility to the interconnection agreement because Appendix 1 of the Final Rule LGIP (Interconnection Request) already provides detailed information about the Generating Facility. Accordingly, the Commission adopts the proposed definition but changes the defined term from Facility to Generating Facility.

50. **Generator** – In the NOPR, the Commission proposed to define the term Generator to mean any Generating Facility, regardless of ownership.

Comments

51. Dairyland Power points out that the term Generator is used in the NOPR LGIP to refer to the entity that owns the Generating Facility, as well as the facility itself. It asks for clarification.

Commission Conclusion

52. To clarify, we use the term Interconnection Customer in this preamble and the Final Rule to refer to the owner of the Generating Facility. The terms Small Generator and Large Generator refer to the class of energy producing devices no larger than 20 MW and larger than 20 MW, respectively.

53. **Good Utility Practice** – In the NOPR, the Commission defined Good Utility Practice to mean any of the practices, methods and acts generally accepted in the region, including Applicable Reliability Standards and the National Electrical Code.

Comments

54. NERC states that although the terms Good Utility Practice and Applicable Reliability Standards have separate definitions, they have often been used interchangeably. It notes that the Commission has defined Applicable Reliability Standards to include NERC and regional reliability council requirements while Good Utility Practice is a broader term that includes Applicable Reliability Standards. NERC comments that it is important that these terms be used consistently.

55. Cinergy notes that Good Utility Practice is defined to include compliance with the National Electrical Code. It states that because it is not subject to the National Electrical Code, it would be improper to attempt to bind it to such compliance.

Commission Conclusion

56. The Commission agrees with NERC that there is some overlap in the proposed definitions of Good Utility Practice and Applicable Reliability Standards. To remove any misunderstanding in the definition of Good Utility Practice, the Commission is adopting in the Final Rule the Order No. 888 definition, which contains no references to Applicable Reliability Standards and National Electrical Code. This also addresses Cinergy's concern.

57. **Interconnection Guidelines** – The NOPR stated that the technical requirements to be followed by the Parties are set forth in the proposed Appendix G (Interconnection Guidelines).

Comments

58. Southern observes that proposed Appendix G is blank, inferring that the Interconnection Customer and Transmission Provider negotiate the technical and operational requirements. Southern believes that this is inappropriate because interconnection guidelines should be established by the Transmission Provider, not by negotiation. Southern contends that requiring a Transmission Provider to negotiate the

technical and operational requirements with each Interconnection Customer is inconsistent with the goal of uniform interconnection procedures.

Commission Conclusion

59. Proposed Appendix G was intended to set forth uniform technical and operational requirements applicable to all Interconnection Customers established by the Transmission Provider, not to be a vehicle for the Parties to negotiate technical and operational requirements on a case-by-case basis. The Commission concludes, however, that most, if not all, of the generic technical and operational requirements are already set forth in the Final Rule LGIA. We are therefore not defining the term Interconnection Guidelines as well as not including proposed Appendix G in the Final Rule LGIA.⁴⁹

60. **Joint Operating Committee** – The NOPR proposed to define Joint Operating Committee to mean a committee comprised of members of individual operating committees that addresses issues arising out of the duties, roles, and responsibilities of individual operating committees described in Article 29 of the NOPR LGIA.

Comments

61. FirstEnergy and PSNM state that the Joint Operating Committee would impose additional administrative costs on the Transmission Provider and is also unnecessary.

Commission Conclusion

62. The Commission is not deleting the term. As discussed later, the Final Rule does not require the Parties to form individual operating committees. Instead, the Final Rule requires a Joint Operating Committee comprising the Transmission Provider and all of its Interconnection Customers. Among other things, the committee will address issues arising out of the duties, roles, and responsibilities of the Parties under their interconnection agreements.

63. **Network Upgrades** – In the NOPR, Network Upgrades were defined as additions, modifications, and upgrades to the Transmission System required beyond the Point of Interconnection in order to accommodate the interconnection of the Generating Facility. Network Upgrades are identified by the Parties in Appendix A to the interconnection agreement (including any modifications, additions or upgrades made to such facilities). The NOPR also stated that Network Upgrades benefit all users of the Transmission System, without distinction or regard as to the purpose of the upgrade.

Comments

⁴⁹See, e.g., Article 7 (Metering), Article 8 (Communications) and Article 9 (Operations).

64. Several commenters, including Calpine and SoCal Water District, request that the definition of Network Upgrades be clarified and made as specific as possible. Calpine and Nevada Power propose that Network Upgrades should include only facilities shown to be "integrated" to the Transmission System, that is, likely to be used by entities other than the Interconnection Customer. Some commenters⁵⁰ contend that circuit breakers are not Network Upgrades, since they benefit only the new Interconnection Customer.

Commission Conclusion

65. The Final Rule revises the definition of Network Upgrade to include the phrase "at or beyond the Point of Interconnection," instead of "beyond the Point of Interconnection," to make it consistent with established Commission precedent. The network begins at the point where the Interconnection Customer connects to the Transmission System, not somewhere beyond that point.⁵¹ Facilities beyond the Point of Interconnection are part of the Transmission Provider's Transmission System and benefit all users. We are also removing the concept of beneficiary from the definition so as to avoid implying a pricing policy in the definition.

66. We disagree with the comments stating that the term is not well defined. The Commission has defined Network Upgrades as those facilities "at or beyond the Point of Interconnection" partially in order to clarify to all entities exactly what is a Network Upgrade. We are removing references to beneficiaries from the definition, because our well-established precedent regarding what constitutes Network Upgrades does not require a case-specific determination that all users benefit from Network Upgrade; instead we look only as whether the upgrade is at or beyond the Point of Interconnection.⁵²

67. **Reasonable Efforts** – The NOPR proposed to define Reasonable Efforts as actions that are timely and consistent with Good Utility Practice and are substantially equivalent to those a Party would use to protect its own interests.

Comments

68. Some commenters including Central Maine found this definition to be vague. They also contend that only Good Utility Practice should be required.

⁵⁰E.g., Edison Mission, Georgia Transmission, MidAmerican, and SoCal Water District.

⁵¹See Entergy Gulf States, Inc., 99 FERC ¶ 61,095 (2002).

⁵²E.g., Entergy Services, Inc. v. FERC, 319 F.3d 536 (D.C. Cir. 2003); Southern Company Services, Inc., 101 FERC ¶ 61,309 (2002); American Electric Power Service Corp., 101 FERC ¶ 61,194 (2002); Tampa Electric Company, 99 FERC ¶ 61,192 (2002).

Commission Conclusion

69. The Commission adopts the proposed definition. The standard in the NOPR is necessary to ensure comparable treatment. If a Party normally exceeds Good Utility Practice when it protects its own interests, it must do so for others as well.

70. **System Protection Facilities** – The NOPR proposed to define System Protection Facilities as the equipment required to protect the Transmission System from faults and other electrical disturbances occurring at the Interconnection Customer's Generating Facility, and vice versa.

Comments

71. NERC proposes that the definition of System Protection Facilities should include "necessary protection signal communications equipment" in addition to the other equipment mentioned in the definition. It argues that such communications equipment is needed to coordinate and monitor the operation of protective devices.

Commission Conclusion

72. The Commission agrees with NERC and adopts the recommended language.

73. **Transmission Owner and Transmission Provider** – In the NOPR, the Commission proposed to define Transmission Owner to mean any entity that owns, leases or otherwise possesses an interest in the Transmission System at the Point of Interconnection. It proposed to define Transmission Provider to mean the entity that provides transmission service under its OATT.

Comments

74. EEI proposes that the definition of Transmission Provider be revised to include Transmission Owner. National Grid states that the proposed LGIA should clearly delineate the rights and responsibilities of Transmission Owners that are not Transmission Providers.

Commission Conclusion

75. We agree with EEI. Accordingly, the definition of Transmission Provider in the Final Rule includes the Transmission Owner as well. While we recognize that the Transmission Provider and the Transmission Owner may be distinct entities in some cases, throughout the Final Rule we will refer to both the Transmission Provider and the Transmission Owner generically as the Transmission Provider. There are a few instances in which the distinction between Transmission Owner and Transmission Provider becomes relevant and there we use the appropriate terms.

76. **Section 2 – Scope and Application** – Section 2 of the NOPR LGIP provided that the Transmission Provider receive, process, and analyze all Interconnection Requests in the same manner as it does for itself, its subsidiaries or Affiliates.

77. **Section 2.3 – Base Case Data** – Section 2.3 of the NOPR LGIP required the Transmission Provider to provide base case power flow, short-circuit and stability databases to the Interconnection Customer upon request so that the Interconnection Customer may independently study its Interconnection Request.

Comments

78. Mirant notes that certain of the language from the Consensus LGIP Section 2.3 concerning confidentiality provisions and the makeup of the Base Case data appears to have been unintentionally left out of the NOPR LGIP Section 2.3.⁵³

79. Dominion Resources asks that the Commission revise LGIP Section 2.3 to state that Base Case data is subject to a confidentiality provision between the Parties. Sempra comments that the Transmission Provider should protect the confidentiality of other Interconnection Customers' information that is part of those databases. Entergy states that this Section should apply only to information that is not commercially sensitive, so as to avoid providing a competitive advantage to other Interconnection Customers.

80. Calpine argues that the Transmission Provider should provide, in addition to the stated databases, all underlying assumptions, data files and documents used to create the Base Case, because otherwise the provision could be interpreted as a narrow set of data files that are meaningless.

81. The Ohio PUC contends that the Commission should ensure that rules for handling critical energy infrastructure information (CEII) are not abused by utilities that seek to withhold from public disclosure commercial information that is not really CEII and that has historically been central to public regulatory proceedings. It believes that there must be procedures to ensure protection of critical public interests. The Ohio PUC recommends that the procedures be carried out by an entity, such as the newly formed

⁵³Mirant states that the following language was left out of Section 2.3 of the NOPR LGIP: "and contingency lists upon request subject to confidentiality provisions. Such databases and lists, herein referred to as Base Cases, shall include all (I) generation projects and (ii) transmission projects, including merchant transmission projects that are proposed for a Transmission System for which a transmission expansion plan has been submitted and approved by the applicable authority."

Department of Homeland Security, that has specific experience in CEII and is qualified to review the Commission's CEII decisions.

Commission Conclusion

82. As Mirant correctly notes, segments of the Consensus LGIP Section 2.3 relating to confidentiality and the makeup of the Base Case data were inadvertently omitted from the NOPR; this text is included in the Final Rule. Both confidentiality and the Base Case data format were significant topics in the Commission Staff Queuing Technical Conference held on January 21, 2003. Most conference participants agreed that providing this Base Case data was reasonable in that it would help the Interconnection Customer and its subcontractor conduct Interconnection Studies independently, expedite the evaluation process, and free up the Transmission Provider's resources, and reduce the time that would otherwise be devoted to performing Interconnection Studies or acting as the Interconnection Customer's consultant. The Commission believes that adding the missing text addresses other commenters' concerns regarding the need for confidential treatment of the Base Case data and other commercially sensitive information that may be provided to the Interconnection Customer.

83. In response to Calpine, we clarify that Transmission Providers must provide all underlying assumptions and data files so that the Interconnection Customer or its subcontractor can independently conduct Interconnection Studies.

84. As to the concerns of the Ohio PUC and others regarding the security of critical energy infrastructure information, the security of the energy infrastructure is essential. The Commission expects that all Transmission Providers, market participants, and Interconnection Customers will comply with the recommendations of the President's Critical Infrastructure Protection Board, as well as any best practice recommendations or requirements that may be issued by NERC or any other electric reliability authorities. In particular, all public utilities are expected to meet basic standards for system infrastructure and operational security, including physical, operational, and cyber-security practices. However, they are not to abuse security requirements in an effort to withhold from public disclosure commercial information that lacks legitimate CEII status.

85. **Section 3 – Interconnection Request** – In NOPR LGIP Section 3, the Commission proposed that each Interconnection Request include, among other things, a refundable deposit of \$10,000 that would be applied toward the cost of the Interconnection Feasibility Study.

86. **Section 3.1 – General** – NOPR LGIP Section 3.1 would have required that the Interconnection Customer submit to the Transmission Provider an Interconnection Request and a refundable deposit of \$10,000 to be applied toward the cost of an Interconnection Feasibility Study. The Interconnection Customer would submit a separate Interconnection Request for each site to be studied and may submit multiple Interconnection Requests for a single site. At the Interconnection Customer's option, the Parties could identify alternative Points of Interconnection and configurations at the

Scoping Meeting and attempt to eliminate alternatives from further consideration. The Interconnection Customer would be required to select the Point of Interconnection no later than the execution of the Interconnection Feasibility Study Agreement.

Comments

87. Some commenters, including Entergy and PJM, state that an initial evaluation of several alternative interconnection sites is inconsistent with regional planning and can be accomplished only at the expense of Transmission Providers and lower queued Interconnection Customers seeking swift interconnection.

88. Cal ISO raises several questions related to the possibility of multiple Interconnection Requests for a single site: (1) Do multiple Interconnection Requests refer only to routing and interconnection arrangements? (2) If so, how many alternatives are acceptable under one submittal? (3) Is an Interconnection Request for one site that is to be evaluated at two different voltage levels, one or two Interconnection Requests? and (4) Is the \$10,000 deposit required for each Interconnection Request, resulting in multiple deposits for multiple requests at a single site?

89. ISO New England recommends revising this section to give an RTO or ISO authority to set reasonable interconnection deposit amounts, taking into account the requested study's complexity. It also states that concerns about discriminatory treatment of Interconnection Customers should be alleviated because the RTO or ISO is independent.

Commission Conclusion

90. Except as noted below, we are adopting Section 3.1 in the Final Rule as proposed. Allowing the Interconnection Customer the option to have the Parties evaluate alternative interconnection sites and configurations at the Scoping Meeting will greatly reduce the need to conduct detailed analyses of interconnection options that are found to have little merit. Providing the Interconnection Customer with more information prior to authorizing an Interconnection Feasibility Study should lead to more efficient use of the Transmission Provider's planning resources and higher quality Interconnection Studies.

91. With regard to Cal ISO's first question, multiple Interconnection Requests at a single site could involve more than just alternative routing and interconnection arrangements. For example, they could also involve substantially different Generating Facility designs. Regarding Cal ISO's second question, we do not set a generic limit on the number of Interconnection Requests that may be included in a single submittal, but leave it to the Parties to reach agreement at the Scoping Meeting, or, if they fail to agree, pursue dispute resolution. As to the third question, a request to evaluate one site at two different voltage levels would be two Interconnection Requests. With respect to Cal ISO's fourth question, the Interconnection Customer must submit a deposit with each Interconnection Request when more than one request is submitted for a single site. However, if an Interconnection Request is withdrawn before the execution of an Interconnection Feasibility Study Agreement, perhaps as a result of discussions at the Scoping Meeting, the Transmission Provider must promptly return the deposit to the

Interconnection Customer. Finally, the Commission is clarifying Section 3.1 to eliminate the uncertainty underlying Cal ISO's questions 3 and 4.

92. The Commission is not revising proposed LGIP Section 3.1 to provide the flexibility that the New England ISO seeks. The proposed study deposit requirements appropriately balance the interests of the Transmission Provider and the Interconnection Customer. However, as explained elsewhere in this preamble, we will entertain proposals by an RTO or ISO to adopt alternative interconnection procedures that reflect regional differences.

93. **Section 3.2 – Identification of Types of Interconnection Services** – Section 3.2 of the NOPR LGIP stated that, when the Interconnection Customer submits its Interconnection Request, it must identify the type of Interconnection Service it desires. The Final Rule provides for two service products: (1) Energy Resource Interconnection Service, which is a basic or minimal interconnection service, and (2) Network Resource Interconnection Service, which is a more flexible and comprehensive service. However, any Interconnection Customer requesting Network Resource Interconnection Service may request that it also be studied for the less comprehensive Energy Resource Interconnection Service up to the point when an Interconnection Facility Study Agreement is executed. Comments and conclusions relating to Section 3.2 of the NOPR LGIP are discussed in Part II.C.2 (Interconnection Products and Scope of Service).

94. **Section 3.3.1 – Initiating an Interconnection Request** – According to NOPR LGIP Section 3.3.1, in order to initiate an Interconnection Request, the Interconnection Customer would be required to submit a \$10,000 deposit, a completed Interconnection Request, and either a demonstration of Site Control (e.g., securing land rights, air permit, etc.) or an additional deposit of \$10,000, with the deposits applied toward any required Interconnection Studies. The latter deposit would be refundable only if the Interconnection Customer demonstrates Site Control within the time period specified in the proposed LGIP Section 3.3.3.

95. Proposed LGIP Section 3.3.1 would allow the expected In-Service Date of the Generating Facility to be no later than the completion date of the relevant region's expansion planning period, not to exceed seven years from the date of the Interconnection Request, unless the Interconnection Customer can demonstrate that engineering, permitting and construction of the Generating Facility will take longer. Under the proposal, the In-Service Date may not exceed ten years from the date the Interconnection Request is received by the Transmission Provider.

Comments

96. Some commenters contend that an Interconnection Customer should be required to demonstrate Site Control when it submits an Interconnection Request.⁵⁴ They disagree

⁵⁴E.g., BPA, Central Maine, Cleco, Edison Mission, Georgia Transmission,
(continued...)

with the proposed LGIP Section 3.3.1 provision that allows for the posting of an additional \$10,000 deposit in lieu of the demonstration of Site Control. For example, PJM states that Site Control is a strong indication of a serious project and is essential for establishing a queue that will consist of projects that are likely to be completed. PJM claims that this is not a burdensome requirement, and that every one of the 285 requests for generator interconnection that it has received since 1999 has included evidence of Site Control at the Interconnection Feasibility Study stage. Edison Mission believes that the Interconnection Customer must have uninterrupted Site Control throughout the interconnection process. It states that a \$10,000 deposit is not sufficient to discourage Interconnection Customers from filing premature Interconnection Requests (in order to secure a favorable Queue Position) and only later find themselves to be unable to secure Site Control. Edison Mission further contends that such a minimal deposit requirement may encourage Interconnection Customers, not acting in good faith, to speculate in interconnection rights by placing deposits for Interconnection Requests at promising locations. It believes that such speculation will frustrate other Interconnection Customers that obtain a site but are locked out of interconnection due to the superior Queue Position of a Party that merely posted a deposit. Edison Mission predicts that this will become an even greater issue as market designs based on locational marginal pricing become the norm.

97. Cleco believes that the only deposit that should be refundable is the \$10,000 deposit paid in lieu of demonstrating Site Control, not the original deposit initiating an Interconnection Request. Moreover, Cleco states that the Commission should make clear that the \$10,000 deposited in lieu of Site Control should be refundable if the Interconnection Customer demonstrates Site Control within the time period specified in Section 3.3.3.

98. Central Maine takes exception to allowing an Interconnection Customer to remain in the queue for a period not to exceed ten years from the date of receipt of the Interconnection Request; it says this period is too long. FirstEnergy recommends replacing "Regional Expansion Planning Period" with "Transmission Provider Expansion Planning Period." Salt River Project seeks clarification as to how to reconcile a situation where the original In-Service Date is ten years out and there is then a three year extension.

99. Some commenters, including American Wind Energy, Edison Mission, NMA, Peabody, and WEPCO, contend that the development time for certain large scale coal, wind power, and other types of projects raise special issues. For example, they want the ten year restriction eliminated because their equipment is not "off-the-shelf," and siting and permitting can exceed ten years. Some commenters also want the Commission to revise Section 3.3.1 to allow them up to nine months after the Interconnection Request is made to submit final design specifications. They contend that because large non-gas-fired generators are unique and not "off-the-shelf," completion of the final design

⁵⁴(...continued)
NYTO, PJM, PJMTO, and Salt River Project.

specifications requires nine or more months after the Interconnection Request is submitted.

Commission Conclusion

100. We retain the proposed text that requires a demonstration of Site Control or a posting of an additional deposit of \$10,000. There may be instances when requiring Site Control could unduly delay the interconnection process.

101. We also share Edison Mission's concern that some participants may attempt to game the system by filing Interconnection Requests at multiple sites knowing that Site Control is unlikely to be obtainable at every site. However, under NOPR LGIP Section 11.3, the Interconnection Customer must provide reasonable evidence of Site Control within 15 Business Days after the receipt of the Final Interconnection Agreement or post additional security of \$250,000, which will be applied toward future construction costs when the demonstration of Site Control is made. This is sufficient incentive for an Interconnection Customer to refrain from engaging in the speculative behavior suggested by Edison Mission.

102. With respect to the ten-year period for allowing an Interconnection Customer to remain in the queue, we believe that ten years should be adequate time to complete the siting, permitting and construction requirements for all plants unless major permitting delays are encountered. Large non-gas-fired projects (e.g., coal or oil projects) generally take eight years or less to complete. Thus, a ten-year period gives large projects at least a two year buffer. Moreover, we note that numerous Interconnection Customers and Transmission Providers negotiated this time limit during the Consensus process. Finally, if an Interconnection Customer believes it needs additional time to complete its project, it should seek the approval of the Transmission Provider to extend the In-Service Date. Accordingly, the Commission clarifies that the term of the Final Rule LGIP Section 3.3.1 is ten years, or longer if the Parties agree, with such agreement not to be unreasonably withheld.

103. Regarding the need for additional time for some Interconnection Customers to complete design specifications, the Commission is not convinced that an exception should be made in the Final Rule LGIP to allow an Interconnection Customer proposing to construct a large non-gas-fired Generating Facility to submit final design specifications nine months after the Interconnection Request is made. The Interconnection Customer should have its design substantially completed prior to submitting its Interconnection Request so that it does not block or disrupt the queuing process. The Transmission Provider is not able to act on an Interconnection Request unless it includes all necessary information, and to give one class of Interconnection Customers extra time to submit design specifications would be unfair to other Interconnection Customers in the queue.

104. As to FirstEnergy's recommendation, the Commission clarifies that, in the absence of a regional expansion planning period, the appropriate expansion planning period would be that of the Transmission Provider.

105. **Section 3.3.4 – Scoping Meeting** (In the NOPR: Initial Scoping Meeting) – Proposed LGIP Section 3.3.4 would have required the Transmission Provider to hold a Scoping Meeting with the Interconnection Customer no later than 30 Calendar Days from receipt of the Interconnection Request. The purpose of the Scoping Meeting would be to discuss alternative interconnection options, including potential feasible Points of Interconnection. The Interconnection Customer would designate its Point of Interconnection and one or more alternative Points of Interconnection on the basis of information gathered at the Scoping Meeting. Section 3.3.4 would also provide that the Interconnection Customer may forgo the Interconnection Feasibility Study and proceed directly to an Interconnection System Impact Study.

Comments

106. Several commenters, including El Paso, Entergy, FirstEnergy, and Georgia Transmission, state that the Parties should be able to agree to schedule a Scoping Meeting outside the 30 day window.

107. El Paso believes that the Interconnection Customer should not make the final decision on designation of the Point of Interconnection; instead, the Transmission Provider should designate the Point of Interconnection with the Interconnection Customer's consent. At a minimum, El Paso recommends that Section 3.3.4 be modified to state that the Transmission Provider must consent to the designation of Point of Interconnection and that such consent will not be unreasonably withheld. El Paso explains this is because the designation of Point of Interconnection has serious cost consequences for the Transmission Provider and its customers.

108. PJM states that the Interconnection Feasibility Study is an important first step in evaluating an Interconnection Request and that about one-third of the Interconnection Requests are withdrawn after the Interconnection Feasibility Study. PJM adds that the Interconnection Customer should not be allowed to skip the Interconnection Feasibility Study and go directly to the Interconnection System Impact Study because this omission would have serious implications for the Clustering of Interconnection of Studies and would create the need for a large number of restudies. PJM proposes that this provision be deleted from the Final Rule LGIP.

Commission Conclusion

109. In the Final Rule LGIP, the Commission is revising Section 3.3.4 to allow the Parties to hold the Scoping Meeting outside the 30 Calendar Day window upon agreement of the Parties, since either Party can object to the postponement. With respect to El Paso's concern regarding the designation of the Point of Interconnection, the purpose of the Scoping Meeting is to discuss alternative interconnection options, including potential Points of Interconnection. The Commission notes that the Transmission Provider will have an opportunity to voice its concerns at the Scoping Meeting and assess the likely cost consequences of interconnecting at various points. It is appropriate that the Interconnection Customer decide its Point of Interconnection based on input from the Transmission Provider because the former must consider its

investment in the Generating Facility and its site selection criteria, as well as its initial funding of Network Upgrades. For these reasons, we adopt Section 3.3.4 as proposed.

110. Regarding PJM's concern about allowing the Interconnection Customer to skip the Interconnection Feasibility Study and proceed directly to the Interconnection System Impact Study, the Commission agrees with PJM that the Interconnection Feasibility Study is an important first step in evaluating an Interconnection Request and should not be skipped. The Commission is therefore deleting this text from the Final Rule LGIP Section 3.3.4.

111. **Section 3.4 – OASIS Posting** – Proposed LGIP Section 3.4 required that the Transmission Provider post on its OASIS a list of all Interconnection Requests. It must post the following information for each Interconnection Request: the location by county and state; the station or transmission line or lines where the interconnection will be made; and the projected In-Service Date. The list will not disclose the identity of the Interconnection Customer until the Interconnection Customer executes an interconnection agreement or requests that the Transmission Provider file an unexecuted Agreement with the Commission. The Transmission Provider also must post deviations from the study time lines set forth in the interconnection procedures. Interconnection Study reports and Optional Interconnection Study reports also must be posted after the Parties meet to discuss the applicable study results.

Comments

112. Avista states that listing the location of a Generating Facility by county and state is not sufficient. The location should be specified in greater detail, because some counties cover hundreds of square miles. Mirant and NYTO state that the identity of the Interconnection Customer should be posted on the OASIS when the Interconnection Request is made because it will help identify Interconnection Customers that are unlikely to see their projects through completion and drop out of the queue. Mirant claims that the identity of the Interconnection Customer is important for conducting meaningful Optional Interconnection Studies.

113. NSTAR seeks clarification about whether entire studies consisting of base case data are to be posted on the OASIS, or just the interpretive analysis contained in the study reports. Salt River Project seeks clarification as to whether the posting of deviations refers to the study time lines in proposed LGIP Section 6.3 (Interconnection Feasibility Study Procedures) or the study time lines that were agreed to by the Parties in advance. MidAmerican recommends that changes in the Generating Facility's In-Service Date should also be posted on the OASIS.

Commission Conclusion

114. The Commission is not requiring that the location of a Generating Facility be specified in any greater detail than proposed because the OASIS posting also includes the substation or transmission line where the interconnection is to be made. We are also not requiring that the identity of the Interconnection Customer be posted when the

Interconnection Request is made because disclosing the identity at that early stage may put the Interconnection Customer at a competitive disadvantage and its project at risk. With regard to Mirant's assertion that the identity of the Interconnection Customer is important in conducting meaningful Optional Interconnection Studies because it helps identify who may drop out of the queue, we note that the Optional Interconnection Studies are to be performed after the Interconnection System Impact Study, at which point only serious projects are likely to remain in the queue.

115. The Commission clarifies that the study reports are to be posted, not the actual studies. Regarding deviations from the study time lines, the Commission clarifies that the Transmission Provider is to post deviations from the study time lines as projected by the Transmission Provider for completing future Interconnection Studies. For example, Section 6.3 (Interconnection Feasibility Study Procedures) calls for the Interconnection Feasibility Study to be completed within 45 Calendar Days after the Transmission Provider receives the fully executed Interconnection Feasibility Study Agreement. If the Transmission Provider anticipates that it will not be able to complete the Interconnection Feasibility Study within 45 Calendar Days, it should post its deviation along with an explanation for the delay (e.g., backlog). Finally, we adopt MidAmerican's recommendation, and Final Rule LGIP Section 3.4 requires the posting of any expected deviation from a Generating Facility's In-Service Date.

116. **Section 3.5 – Coordination with Affected Systems** – Proposed LGIP Section 3.5 dealt with interconnections that may affect a Transmission System other than that of the Transmission Provider. A third party Transmission System was proposed to be defined in the NOPR LGIA as an Affected System. Section 3.5 also proposed obligations and rights of the Affected System, the Transmission Provider, and the Interconnection Customer, including a requirement to coordinate Interconnection Studies.

Comments

117. Interconnection Customers including Duke Energy, Independent Producers, Norton Energy, and Peabody support requiring the Transmission Provider (rather than the Interconnection Customer) to coordinate and perform all necessary Interconnection Studies and Network Upgrades with an Affected System. Duke Energy agrees that the Affected System Operator should be required to cooperate with the Transmission Provider in completing necessary studies. Duke Energy also wants the Affected System Operator to enter into an agreement with the Interconnection Customer. Other commenters, predominately Transmission Providers, oppose placing these responsibilities on the Transmission Provider.⁵⁵ They contend that (1) a contract cannot bind a third party that is not a signatory to it, (2) it is unfair to impose liability for

⁵⁵E.g., AEP, Ameren, BPA, Cal ISO, Central Maine, Central Vermont PSC, Cleco, the Construction Issues Coalition, Dairyland Power, Dominion Resources, Entergy, Georgia Transmission, Imperial Irrigation, ISO New England, MidAmerican, the Midwest ISO, National Grid, Nevada Power, NYTO, PGE, PJM, Salt River Project, SoCal Edison, TANC, and TVA.

liquidated damages for an incomplete study on the Transmission Provider where the Transmission Provider has no control over the Affected System, (3) the Transmission Provider should be required to use only "reasonable efforts" to coordinate with an Affected System, (4) the Interconnection Customer should pay any costs of conducting Interconnection Studies on an Affected System, including all costs of delays caused by the studies, (5) the Interconnection Customer should be required to pay for the necessary upgrades on the Affected System and not be allowed to operate until such upgrades are completed, and (6) the Transmission Provider should not be responsible for actions (or inactions) of third parties either with regard to funding or construction of Network Upgrades.

Commission Conclusion

118. The Commission continues to treat interconnection and delivery as separate aspects of transmission service, and an Interconnection Customer may request Interconnection Service separately from transmission service (delivery of the Generating Facility's power output). In the majority of circumstances, interconnection alone is unlikely to affect the reliability of any neighboring Transmission System. However, in those rare instances in which the interconnection alone may cause a reliability problem on an Affected System, the Commission adopts the approach of Order No. 888 for Network Upgrades required to protect an Affected System from a reliability problem due to delivery service.⁵⁶ Under Order No. 888, the Transmission Provider is required to assist the Transmission Customer in coordinating with the Affected System on any Network Upgrades needed to protect the reliability of that system.⁵⁷ We will also allow the Transmission Provider to coordinate the timing of construction of Network Upgrades to its Transmission System with the construction required on the Affected System.⁵⁸ As provided in the OATT, the Commission's Dispute Resolution Service is available should

⁵⁶See Section 21 of the OATT. See also *Tampa Electric Co.*, 103 FERC ¶ 61,047 (2003), and *Nevada Power*, 97 FERC ¶ 61,227 (2001), reh'g denied, 99 FERC ¶ 61,347 (2002); but see *American Electric Power Service Corporation*, 102 FERC ¶ 61,336 (2003).

⁵⁷Section 21.1 of the OATT states that: "The Transmission Provider will undertake reasonable efforts to assist the Transmission Customer in obtaining such arrangements, including without limitation, provided any information or data required by such other Transmission System pursuant to Good Utility Practice."

⁵⁸Section 21.2 of the OATT states that: "Transmission Provider shall have the right to coordinate construction on its own system with the construction required by others. The Transmission Provider, after consultation with the Transmission Customer and representatives of such other systems, may defer construction of its new transmission facilities, if the new transmission facilities on another system cannot be completed in a timely manner."

the Interconnection Customer wish to challenge the Transmission Provider's decision to delay construction pending completion of the Affected System's upgrades.⁵⁹

119. The Commission reiterates that under Order No. 888, economic losses from having to redispatch generation do not justify delaying the provision of the delivery component of transmission service.⁶⁰ The Commission adopts the same standard here for interconnections.

120. Thus, unless the interconnection alone will endanger the reliability of an Affected System, a Transmission Provider may not require an Interconnection Customer, as a condition of interconnection, to accept responsibility for Network Upgrades on other systems. To hold new Interconnection Customers responsible for upgrades to all interconnected systems, including not only the system to which the Generating Facility interconnects, but other, more distant systems as well would create an unreasonable obstacle to the construction of new generation.⁶¹ We reiterate that requiring a Transmission Provider to coordinate intermediate studies and upgrades with other systems is just and reasonable.

121. Although the owner or operator of an Affected System is not bound by the provisions of the Final Rule LGIP or LGIA, the Transmission Provider must allow any Affected System to participate in the process when conducting the Interconnection Studies, and incorporate the legitimate safety and reliability needs of the Affected System. However, the Affected System is not required to participate in the interconnection of the Generating Facility, as proposed by Duke Energy. If the Affected System declines to work with the Transmission Provider, or fails to provide information in a timely manner, the Transmission Provider may proceed in the interconnection process without taking into account the information that could have been provided by the Affected System. Neither the Final Rule LGIP nor the Final Rule LGIA is intended to expose the Transmission Provider to liability as a result of delays by the Affected System.

122. In addition, we note that NERC Planning Standards require Transmission Providers to work together to minimize effects on each others' systems. When a Transmission Provider adds its own new generation to its system, this may have a reliability effect on other systems, requiring coordination among systems. Such coordination must extend to new generation of any Interconnection Customer because, as stated in this provision, a Transmission Provider must offer all generators service that is comparable to the service that it provides to its own generation or that of its Affiliates.

⁵⁹See Section 21.2 of the OATT.

⁶⁰See Section 13.2 of the OATT.

⁶¹Nevada Power, 97 FERC ¶ 61,227 (2001), reh'g denied, 99 FERC ¶ 61,347 at 62,294 (2002).

123. **Section 3.6 – Withdrawal** – Proposed LGIP Section 3.6 provided that the Interconnection Customer would have the option to withdraw its Interconnection Request at any time with written notice to the Transmission Provider. If the Interconnection Customer fails to adhere to the requirements of the interconnection procedures, its request would be deemed withdrawn and the Transmission Provider would provide written notice of the deemed withdrawal along with a written explanation. In either instance, the Interconnection Customer would lose its Queue Position and pay all of the Transmission Provider's prudently incurred costs up to the withdrawal. The Transmission Provider would be required to update its OASIS queue posting and to refund the Interconnection Customer any portion of the Interconnection Customer's deposits or study costs that exceeds the costs that the Transmission Provider has incurred, including interest. In the event of a withdrawal, the Interconnection Customer would be able to request all information the Transmission Provider developed for any completed Interconnection Studies, up to the date of withdrawal of the Interconnection Request, subject to the confidentiality provisions of Section 13.1.

Comments

124. FirstEnergy and WEPCO assert that an Interconnection Customer should be given a reasonable amount of time to address purported deficiencies before a Transmission Provider deems a request withdrawn because the purported deficiency may not have been adequately communicated to the Interconnection Customer.

125. Cinergy requests that this section be modified to require that a Transmission Provider provide written notice to the Transmission Owner of any Interconnection Customer withdrawal notice it receives or, alternatively, that the Interconnection Customer provide notice to both the Transmission Provider and the Transmission Owner.

126. When an Interconnection Customer withdraws its application, NYTO supports having the Interconnection Customer pay the Transmission Provider all monies due to the Transmission Provider before it is allowed to obtain any Interconnection Study data or results. Duke Energy argues that an Interconnection Customer's responsibility for prudently incurred costs terminates either when the Transmission Provider receives the Interconnection Customer's notice of withdrawal or, in the event the Interconnection Customer is deemed to have withdrawn its application for interconnection, when the Transmission Provider provides notice of withdrawal.

127. PJM believes that the proposed language implies that if an Interconnection Customer disputes its loss of Queue Position, it would remain in the queue pending Dispute Resolution. PJM advocates instead the approach the Commission has accepted in the PJM Tariff, that is, when an Interconnection Customer is disqualified from the queue, it is eliminated from the queue unless and until a Dispute Resolution process restores its position.

Commission Conclusion

128. The Commission agrees with FirstEnergy and WEPCO that Interconnection Customers should be given an opportunity to address any deficiencies before their requests are deemed withdrawn by the Transmission Provider. Proposed LGIP Section 3.6 is revised in the Final Rule LGIP accordingly.

129. The Commission agrees with Duke Energy that an Interconnection Customer's responsibility for a Transmission Provider's prudently incurred cost terminates at the earlier of either when the Transmission Provider receives the Interconnection Customer's notice of withdrawal or when the Transmission Provider provides a notice of withdrawal after deeming an Interconnection Request to be withdrawn. The Commission also agrees with NYTO that when the Interconnection Customer withdraws its application, it must pay all monies due to the Transmission Provider before it is allowed to obtain any Interconnection Study data or results.

130. We agree with PJM that it is unreasonable for an Interconnection Customer to maintain its Queue Position pending Dispute Resolution. In most cases, Dispute Resolution and any related litigation would create delays, and it would be unfair to delay the projects of lower queued Interconnection Customers while a higher-queued Interconnection Customer's Queue Position is in dispute. The Commission clarifies this section in the Final Rule LGIP accordingly.

131. **Section 4 – Queue Position** – Proposed LGIP Section 4 would establish the Interconnection Customer's Queue Position (*i.e.*, the chronological priority assigned to an Interconnection Request), which would be used to determine both the order in which studies are performed and the cost responsibility for the facilities necessary to accommodate the Interconnection Request. At the Transmission Provider's option, Interconnection System Impact Studies would be performed serially as Interconnection Requests are received or in clusters, as discussed below. Proposed LGIP Section 4 also described when a Queue Position can be transferred to another entity, and when an Interconnection Customer could modify its Interconnection Request without losing its Queue Position.

132. **Section 4.1 – General** – Proposed LGIP Section 4.1 required the Transmission Provider to assign a Queue Position to the Generating Facility based on the date and time of receipt of a valid Interconnection Request. However, if the sole reason that an Interconnection Request is deemed invalid is lack of information required in the Interconnection Request, and if the Interconnection Customer provides such information in accordance with Section 3.3.3 of the proposed LGIP, the Transmission Provider would then be required to assign the Interconnection Customer a Queue Position based on the date and time that the Interconnection Request was initially filed. The Queue Position of each Interconnection Request would be used to determine the order of performing the Interconnection Studies, which would determine the cost responsibility for the facilities necessary to accommodate the Interconnection Request. This is because the facilities needed for one Interconnection Customer are affected by the facilities needed for other generators that come before it in the queue.

Comments

133. TVA observes that the level of commitment by Interconnection Customers to complete an interconnection varies. A change in the request of a higher queued Generating Facility will affect lower queued generators because it may require restudies. It states that the "first-come, first-served" method rewards an Interconnection Customer that simply is the first in line, even if it has not done the preparation to make a complete and legitimate Interconnection Request. According to TVA, this is costly and unfair to other Interconnection Customers. It also asserts that if an Interconnection Customer seeks to change its Point of Interconnection, it should be placed in a lower position in the queue. Ameren has similar concerns and states that it has a high withdrawal rate for Interconnection Requests. It claims that fewer restudies would be needed if a Transmission Provider could study only "serious" requests.

134. American Wind Energy believes that projects in the queue when the Final Rule takes effect should receive equal treatment under the new rule. It states that since summer 2000 several developers have accelerated their projects and have executed interconnection agreements. These developers should be able to have their interconnection agreements revised to be consistent with the Final Rule LGIA.

135. PJM believes that the proposed procedures do not help eliminate projects that are not economically feasible. Accordingly, the Interconnection Customer should be required to meet milestones to show significant commitment to a project. The fixed schedule approach (which fixes a time period for completing an Interconnection Study after the receipt of an Interconnection Request) undermines integrated regional planning, since it forces planners to study each Interconnection Request independently of other Interconnection Requests that are located in close electrical proximity. PJM also notes that such projects could have related effects on the Transmission System and overall expansion alternatives.

136. PacifiCorp believes that there will be problems in the queuing and the Interconnection System Impact Study process if an Interconnection Customer is allowed to request an Interconnection Study when it does not expect to begin construction or operations for a long time. According to PacifiCorp, long lead times substantially increase the uncertainty that the project will be completed. An independent Transmission Provider should be given more flexibility in addressing these issues.

137. TECO Energy states that the Interconnection Request must provide a demonstration of Site Control for the Generating Facility at the time of the initial request before it may enter the queue. It states that it is inefficient to commit a Transmission Provider's resources to the study of a request until the project achieves a level of certainty and specificity that justifies the commitment of resources, even though the Interconnection Customer pays for the Interconnection Studies.

138. EEI, PSEG, and SoCal Edison all state that they generally support establishing a single integrated queue per RTO region.

139. EEI states that Interconnection Service and delivery service are separate and that there is no need to combine them. It believes that any combination of the two services

requires a single Interconnection Feasibility Study for several generators, would likely overly complicate the queuing process, and subsequently delay study completions. It contends that the separation of interconnection and delivery services is critical to designing a queue that is appropriate for both non-Standard Market Design and Standard Market Design service.

140. Xcel observes that the "first-come, first-served" queue process does not take into account either the transmission planning requirements of RTOs or state integrated resource planning statutes and rules, which often require the use of a "portfolio approach" whereby state-regulated load-serving entities select between competing generation providers based on the total cost of generation and transmission.

141. Xcel supports a process similar to the periodic "open season" used for gas pipelines, in which the Transmission Provider or RTO would periodically solicit market interest in incremental transmission capacity and then develop a transmission plan that serves the various market needs at the lowest overall cost.

142. TXU wants the Final Rule to allow a Transmission Provider, RTO, or ISO to create queues that are periodically opened and closed, based on a predetermined time period. Proposed projects should be placed into a queue according to the date of the Interconnection Request.

143. American Wind Energy, NYISO, and Tenaska believe that Queue Position should not be used exclusively to determine the cost responsibility for the facilities necessary to accommodate the Interconnection Request. American Wind Energy states that the first wind project in the queue should not be required fund the Network Upgrades for what logically will be a long term large scale build-out of an entire wind resource area. NYISO also contends that the Commission's proposal is not workable in the NYISO system because its interconnection cost allocation rules are not based on Queue Position. Instead, Interconnection Facility costs are determined each year and allocated on the basis of pro-rata electrical impact among the members of a group of projects that have reached a specified point in the New York State project permitting process.

Commission Conclusion

144. The Commission understands Ameren's and PJM's concerns that uncertainty about project withdrawal creates difficulties for a Transmission Provider in planning for necessary Network Upgrades. Having an Interconnection Customer and a Transmission Provider establish agreed upon milestones at the Scoping Meeting should help to ensure that the Transmission Provider's planning process reflects only the interconnection of Generating Facilities that are making satisfactory progress toward completion. Also, a Transmission Provider facing difficulties of this sort may wish to consider conducting Interconnection Studies on a clustered basis (see discussion below). Factors other than Queue Position also must be considered in determining the cost responsibility of an

Interconnection Customer, especially when a Transmission Provider conducts Interconnection Studies on a clustered basis. However, we believe that Queue Position must play a critical role in determining cost responsibility, and expect the Transmission Provider to give appropriate recognition to Queue Position when it develops its cost allocation rules.

145. We agree with TVA's comment that moving the proposed Point of Interconnection should lead to a lower Queue Position if it is a Material Modification under Final Rule LGIP Section 4.4.3. Section 4.1 is revised accordingly in the Final Rule.

146. With respect to TECO Energy's comments on the need to demonstrate Site Control in the initial application, the Commission notes that LGIP Section 3.3.1 and the definition of Site Control in the Final Rule already require early demonstration of Site Control or posting a deposit of \$10,000. Section 7.2 of the Final Rule LGIP requires a demonstration of Site Control prior to executing the Interconnection System Impact Study Agreement. We conclude that these provisions adequately demonstrate Site Control.

147. There must be a single integrated queue per geographic region. We note that it was the method generally agreed upon during the Commission staff's Technical Conference on Queuing. However, we will afford an RTO or ISO the flexibility to propose queues and queuing rules designed to meet its regional needs.

148. Xcel's and TXU's comments are addressed in the Commission Conclusions discussion for Section 4.2 (Clustering), which follows.

149. **Section 4.2 – Clustering** – For the purpose of the Interconnection System Impact Study, Section 4.2 of the NOPR LGIP permitted the Transmission Provider to study Interconnection Requests serially or in clusters. The Transmission Provider would be allowed to simultaneously study all Interconnection Requests received during a period not to exceed 90 Calendar Days ("the queue cluster window") except requests for Energy Resource Interconnection Service, which would be studied serially. The Transmission Provider would be permitted to study an Interconnection Request separately if warranted by Good Utility Practice based upon the electrical remoteness of the proposed Generating Facility.

Comments

150. Various Transmission Providers including BPA, NYTO, and PJM recommend that the queue cluster window be extended from 90 to 180 days so that the study process may be fully integrated into the Transmission Provider's planning process, and to ensure that one set of Interconnection Studies can be completed before the next round begins. PJM states that a 180-day window reasonably balances the competing objectives of completing Interconnection Studies as rapidly as possible and ensuring that the study

process produces meaningful regional expansion plans that induce economically efficient decisions by generation developers. PSEG sees merit in the clustering approach, but states that it should be tied to the planning process and have specified start and end dates. PJM opposes the requirement to study requests for Energy Resource Interconnection Service serially, arguing that most of the tests applied to Energy Resource Interconnection Service and Network Resource Interconnection Service are the same.

151. The Midwest ISO seeks clarification whether a cluster refers to a group of Interconnection Requests that were submitted during a specified time period, such as 90 Calendar Days, or to a group of Generating Facilities that are located in geographic proximity to one other, or both. The Midwest ISO seeks further clarification whether each Interconnection Request is to be studied serially within the cluster in order to determine the cost of Network Upgrades for each, or all of the Interconnection Requests are to be studied simultaneously, which will determine only the total cost of Network Upgrades. It argues that if the latter is the case, the Commission will need to prescribe a way to allocate the total cost of Network Upgrades to each Interconnection Customer within the cluster.

152. American Wind Energy states that clustering is the best method to interconnect both large and small generators in a balanced regional planning process, and also facilitates the coordinated completion of a useful Interconnection System Impact Study.

Commission Conclusion

153. In the Final Rule, we are setting the queue cluster window for conducting Interconnection System Impact Studies at 180 Calendar Days. As the commenters make clear, the principal benefit of studying Interconnection Requests in clusters is that it allows the Transmission Provider to better coordinate Interconnection Requests with its overall transmission planning process, and, as a result, achieve greater efficiency in both the design of needed Network Upgrades and in the use of its planning resources. We are persuaded by the arguments of PJM and others that the proposed 90-day cluster window is too short to achieve this result, and that a 180-day window is more appropriate.

154. We are also persuaded by PJM that if the Transmission Provider elects to study Interconnection Requests in clusters, requests for both Energy Resource Interconnection Service and Network Resource Interconnection Service should be included in the clustered Interconnection Studies. Requiring the Transmission Provider to perform System Impact Studies for Energy Resource Interconnection Service requests on a serial basis would mean that many of the efficiency benefits of clustering would be lost. When a Transmission Provider conducts Interconnection Studies on a clustered basis, the Interconnection Customer may have to wait longer to obtain study results than it would if its request were studied serially. However, some of the information that an Interconnection Customer needs is provided by the Interconnection Feasibility Study, which is conducted serially and early in the study process.

155. Clustering is strongly encouraged in queue management and the Interconnection Study process for all Transmission Providers. We vigorously support the use of queue

windows to manage the Interconnection Study process. In response to the Midwest ISO's comments, Final Rule IP Section 4.2 has been modified to better explain the clustering process. Queue windows with regular, fixed opening and closing dates are essential to an orderly process. Once fixed, any changes to these dates should be announced with a posting on the Transmission Provider's OASIS at least 180 days in advance of the change. Cluster windows enable the Transmission Provider to evaluate all pending Interconnection Requests periodically and systematically in light of the Transmission Systems's capabilities at the time of each clustered Interconnection System Impact Study.

156. Clustering (by queue position and electrical location) ensures that the regional expansion plan considers all uses of the Transmission System and enables expansion of the system to be accomplished in the most efficient manner reasonably achievable. However, projects that are electrically isolated can still be studied independently. Additionally, allocation of cost responsibility for system upgrades and jointly used facilities is more readily managed by studying requests in clusters. Absent the ability to cluster interconnection requests, it is difficult to distinguish the Transmission Provider's cost responsibility for baseline reliability upgrades from the responsibility of Interconnection Customers and other developers for the costs of upgrades required to accommodate their Interconnection Requests since each request would have to be studied serially. Equally important, Interconnection Studies for smaller generators can be more easily expedited. These efficiencies are best obtained using clustered queue windows, not through the sequential processing of Interconnection Requests.

157. **Section 4.3 – Transferability of Queue Position** – The Commission proposed in Section 4.3 of the NOPR LGIP that an Interconnection Customer may transfer its Queue Position to another entity if such entity acquires the Generating Facility identified in the Interconnection Request and the Point of Interconnection does not change.

Comments

158. National Grid states that the Commission should resist requests from those that propose to make Queue Position a tradable commodity to gain flexibility over the timing of their proposed projects. National Grid offers several arguments against allowing this: (1) it would create an unnecessary commodity that would encourage gaming in competitive markets, (2) it would render the interconnection queue process unmanageable because the trading of Queue Positions would make it impossible to build sets of assumptions on which to base studies, (3) it would add another layer of administrative burdens for Transmission Providers; and (4) the disputes over Queue Position that are likely to arise would divert the Transmission Provider's attention away from facilitating reasonably prompt interconnections. Instead, the Commission should adopt a subordinate application process like the one implemented in NEPOOL, which allows a project sponsor to accelerate the construction and operation of its facilities application ahead of other projects in the queue in return for the sponsor's assumption of the risks associated with building the facilities in a sequence different from the study order of the queue.

159. The CPUC believes that changes resulting from an Interconnection Customer selling its Queue Position could harm subsequent Interconnection Customers in the queue, since it could affect the portfolio of technologies in the queue and the diversity of the Transmission System as a whole. According to the CPUC, an Interconnection Customer wishing to sell its position should be required to provide assurances that it will pay not only for any Interconnection Studies needed as a result of the change, but also for the costs to subsequent Interconnection Customers in the queue as a result of the change. The seller of the Queue Position should also be liable for any obligations that the buyer of the position is unable to fulfill in the event of a Default.

Commission Conclusion

160. While the commenters raise legitimate concerns with Queue Position trading in general, we conclude that the restrictions on transferability that are already contained in Section 4.3 address these concerns. Section 4.3 of the Final Rule LGIP permits an Interconnection Customer to transfer its Queue Position to another entity only if such entity acquires the specific Generating Facility identified in the Interconnection Request and the Point of Interconnection does not change. These limitations on transferability greatly reduce the potential impact on lower queued Interconnection Customers. The new Interconnection Customer would also be required to show, under Section 4.4.3 of the Final Rule LGIP, that any proposed change is not a Material Modification.

161. **Section 4.4 – Modifications** – Proposed LGIP Section 4.4 would have required that the Interconnection Customer submit to the Transmission Provider, in writing, modifications to any information provided in the Interconnection Request. Either the Interconnection Customer or the Transmission Provider would be permitted to identify changes to the planned interconnection that may reduce the costs and increase the benefits (including reliability) resulting from the interconnection. If the changes are acceptable to the Transmission Provider and Interconnection Customer (such acceptance not to be unreasonably withheld), the Transmission Provider would make the necessary changes and proceed with interconnection restudies in accordance with Sections 6.4, 7.6 and 8.5 of the LGIP, as applicable. Accordingly, the Generating Facility would retain its Queue Position.

162. **Section 4.4.1** – Proposed LGIP Section 4.4.1 LGIP would allow an Interconnection Customer to make the following modifications to its Interconnection Request, provided that it makes them before returning the executed Interconnection System Impact Study Agreement to the Transmission Provider: (1) a reduction of as much as 60 percent in the megawatt output of the proposed project, (2) modification of the technical parameters associated with the Generating Facility technology or the step-up transformer impedance characteristics, (3) modification of the interconnection configuration, or (4) any other type of change except to the proposed Point of Interconnection. Any increase in the Generating Facility's megawatt output would be placed at the end of the queue.

Comments

163. Dynegy argues that item (4) is confusing, makes the other items in the list redundant, and does not belong in this section. Several commenters, including Duke Energy and WEPCO, advocate allowing an Interconnection Customer to increase the output of its Generating Facility by up to ten percent of the voltage level of the line to which it is interconnecting without affecting its Queue Position.

Commission Conclusion

164. We agree with Dynegy that item (4) does not belong in this section. The item more appropriately belongs in Section 4.4.3. Accordingly, Final Rule LGIP Section 4.4.3 includes the following sentence: "Any change to the Point of Interconnection shall constitute a Material Modification."

165. We reject the other commenters' proposal to allow an Interconnection Customer to increase the output of its Generating Facility by up to ten percent. The percentage by which the capacity of the proposed Generating Facility could be increased without substantially changing the size and configuration of necessary Network Upgrades needed to accommodate the change in output would depend on the size and location of the Generating Facility and the voltage level at the Point of Interconnection, among other things. This could vary significantly from case to case, and may well be less than ten percent.

166. **Section 4.4.3** – Proposed LGIP Section 4.4.3 would have required that, prior to making a modification other than one specifically permitted by Sections 4.4.1, 4.4.2, and 4.4.5, the Interconnection Customer may first ask the Transmission Provider to evaluate whether the modification is actually a Material Modification. A Material Modification would be a modification that has a material effect on the cost or timing of a lower queued Interconnection Customer. The Transmission Provider would be required to evaluate the proposed modification and inform the Interconnection Customer in writing whether the modification would be considered a Material Modification. The Interconnection Customer could then either withdraw the proposed modification or submit a new Interconnection Request for such modification.

Comments

167. SoCal Water District and Dynegy ask the Commission to clarify the definition of Material Modification to avoid disputes between the Parties regarding the Generating Facility's Queue Position. Ameren argues that a modification that is proposed as not being "material" may in fact be a Material Modification. FirstEnergy opposes giving the Transmission Provider the discretion to determine whether a request is a Material Modification. El Paso observes that reading proposed LGIP Sections 4.4.3 and 4.4.5 together implies that the Transmission Provider will be forced to judge whether an extension of three years or more is material and to determine if a cost effect or other project change is material. El Paso supports defining a Material Modification as: (1) a change greater than 12 months in Commercial Operation Date, (2) an increase of greater than \$100,000 or 10 percent in the Transmission Provider's cost that a later queued Interconnection Customer would bear; or (3) a change greater than five miles in the

location of, or any change in the voltage level at, the Point of Interconnection. Edison Mission believes that the Final Rule LGIP should clarify the effect of material improvements and modifications to existing Generating Facilities on the interconnection status and the rights of such Generating Facilities. The Bureau of Reclamation expresses concern that the NOPR does not define how or when an existing Interconnection Customer would be affected by Material Modifications. The Bureau of Reclamation is concerned because design and approval of its generator refurbishment is a federal responsibility and would be subject to the federal appropriation process.

Commission Conclusion

168. It is not necessary to revise proposed LGIP Section 4.4.3 to define precisely what constitutes a Material Modification. The impact of a modification depends in large part on the size, location, type of project and the configuration of the Transmission Provider's Transmission System. The various Interconnection Studies will identify the modification's impact on other Interconnection Customers. This impact determines if the change is indeed a Material Modification. We leave it to the Transmission Provider to make that determination; however, it must do so on a reasonable basis.

169. **Section 4.4.4** – Proposed LGIP Section 4.4.4 in the NOPR LGIP provided that, upon receipt of an Interconnection Customer's request for modification permitted under Section 4.4, the Transmission Provider would perform any necessary additional Interconnection Studies as soon as practicable, but in no event later than 30 Calendar Days after receiving notice of the Interconnection Customer's request. Any additional Interconnection Studies resulting from such modification would be done at the Interconnection Customer's expense.

Comments

170. Exelon asserts that this section is not practical and is punitive to all lower queued Interconnection Customers. It contends that each time a modification is requested, a Transmission Provider or Transmission Owner must begin studying the modification within 30 Days and all work on the Interconnection Studies of all lower queued Interconnection Customers must be halted.

Commission Conclusion

171. We adopt Section 4.4.4 as proposed. While any modification that requires additional study can pose a challenge to the Transmission Provider's schedules and resources, the modifications that are permitted under Section 4.4 occur early enough in the study process that their effect on Interconnection Customers lower in the queue should be limited. Furthermore, since all Interconnection Requests are evaluated in the same restudy, this provision appropriately balances the Interconnection Customer's need for flexibility to change the project with the Transmission Provider's need for certainty in resource costs and schedules.

172. **Section 4.4.5** – Section 4.4.5 of the NOPR LGIP provided that an extension of less than three cumulative years in the Commercial Operation Date of the Generating Facility should not be considered a Material Modification and should be treated in the same manner as in Section 12.3 (Construction Sequencing).

Comments

173. Salt River Project seeks clarification on what to do when the original In-Service Date is at the maximum allowable ten years (under Proposed LGIP Section 3.3.1) and there is a request for a three year extension. Duke Energy supports allowing an Interconnection Customer to request an extension of all dates, including the In-Service Date, for periods of less than three cumulative years. Sempra believes that the Transmission Provider needs greater flexibility to manage and evaluate its Transmission System for delays of more than one year.

174. Westconnect RTO finds that two provisions in this Section contradict Western Electricity Coordinating Council (WECC) procedures. They are allowing the Interconnection Customer to decide to extend its Generating Facility's Commercial Operation Date for up to a total of three cumulative years and providing that such extensions are not material and should be handled through construction sequencing. Westconnect RTO asserts that regional practices concerning transmission planning and reliability should be honored.

175. SoCal PPA and El Paso believe that a three year period is an unreasonably long time to permit suspension of interconnection because it interferes with the Transmission Provider's ability to manage the queue and plan its system.

Commission Conclusion

176. With respect to Salt River Project's request, we clarify that the term contained in Final Rule LGIP Section 3.3.1 is ten years, or longer if the Transmission Provider agrees. Furthermore, such agreement shall not be unreasonably withheld. This clarification also addresses Duke Energy's and Sempra's concerns.

177. With respect to Westconnect RTO's assertion that this section contravenes WECC procedures, as stated above, we would permit modifications to the Final Rule LGIA and Final Rule LGIP where the Transmission Provider shows that there are legitimate regional differences, such as the WECC procedures, that would support such modifications. As to other arguments that three years is an unreasonably long time to permit extensions of the Commercial Operation Date, the Commission recognizes that such flexibility places a burden on the Transmission Provider's expansion planning process, but these extensions in most cases are well within the scope of other unforeseen changes that affect the planning process. The Final Rule therefore adopts Section 4.4.5 as proposed.

178. **Section 5 – Procedures for Interconnection Requests Submitted Prior to Effective Date of Interconnection Procedures** – Section 5 of the proposed LGIP

described the procedures for assigning a Queue Position prior to the effective date of the Final Rule LGIP. It also proposed a transition process for a Transmission Provider with an Interconnection Request that is outstanding when the Final Rule takes effect.

179. **Section 5.1 – Queue Position for Pending Requests** – Proposed LGIP Section 5.1 provided that any Interconnection Customer assigned a Queue Position prior to the effective date of the Final Rule LGIP would retain that Queue Position. Also, if an Interconnection Study Agreement has not been executed as of the Final Rule effective date, then that Interconnection Study and subsequent Interconnection Studies would be processed in accordance with the Final Rule. However, an executed Interconnection Study Agreement would be completed in accordance with the terms in place at the time of execution of that agreement. The proposed section also provided that if an interconnection agreement has been tendered as of the Final Rule effective date, the Transmission Provider and Interconnection Customer would finalize its terms. To the extent necessary, outstanding requests would transition to the Final Rule procedures within a reasonable period of time, not to exceed 60 Calendar Days. Reasonable extensions would be granted.

Comments

180. The Midwest ISO recommends adding a subsection to the LGIP that permits Interconnection Requests in existing queues of non-RTO Transmission Providers to be merged into the queue of the RTO or ISO based on the original request dates at the time the Transmission Provider joins the RTO.

181. Central Maine supports the grandfathering of existing interconnection agreements that are filed with and accepted by the Commission as of the effective date of the Final Rule LGIP and Final Rule LGIA.

182. Sempra argues that it is inappropriate to mandate Parties to agree to an interconnection agreement tendered but not fully negotiated prior to the issuance of the Final Rule because, otherwise, the tendering Party could tender them on the eve of the Final Rule going into effect and the other Party would be compelled to negotiate under the Final Rule's terms and conditions. Therefore, either Party should be permitted to set aside unexecuted but tendered interconnection agreements prior to the effective date of the Final Rule.

183. MidAmerican states that the proposed provision of Section 5.1.2, which established a transition period from the old queue processes to the new Final Rule provisions that should not exceed 60 days, is practical only for projects that are in their early stages. It proposes adding the phrase "provided that any existing interconnection agreement or Interconnection Study Agreement shall remain in full force and effect" for projects that have an executed interconnection agreement. MidAmerican also states that the Commission should clarify that this transition period is only for those outstanding requests for which Interconnection Studies Agreements and interconnection agreements have yet to be executed prior to the Final Rule going into effect. Similarly, Central Maine seeks clarification of the meaning of pending or outstanding requests.

184. BPA states that this provision should be clarified with regard to the circumstances under which an Interconnection Customer with an existing Interconnection Request may request an extension of applicable deadlines.

Commission Conclusion

185. The purpose of Proposed LGIP Section 5.1 was to ensure that a Generating Facility that has an established Queue Position prior to the Final Rule taking effect will continue to hold its position. This is also the case mentioned by the Midwest ISO for merging new members into the RTO's queue when the Transmission Provider joins an RTO. However, on compliance, discretion will be granted to RTOs or ISOs to propose queuing rules customized to their needs, in accordance with the "independent entity standard" (described in Part II.C.5).

186. Under proposed LGIP Section 5.1.1, the Interconnection Studies for which the Parties have an executed Interconnection Study Agreement would be completed under the Interconnection Study Agreement's terms, but any remaining studies would be completed under the Final Rule LGIP study procedures. The Commission concludes that this situation may cause confusion and unnecessary complications in the event that the Transmission Provider's existing study procedures conflict with those in the Final Rule LGIP. To provide further clarification, and to prevent situations in which an Interconnection Customer may be forced to comply with conflicting or redundant study requirements, the Commission modifies this section to give the Interconnection Customer a choice. Under the Final Rule LGIP Section 5.1.1.2, if an Interconnection Customer has signed an Interconnection Study Agreement as of the effective date of the Final Rule, the Interconnection Customer will have the option to either continue with the rest of its Interconnection Studies under the Transmission Provider's existing study process or complete those remaining studies for which it does not have a signed Interconnection Study Agreement under the Final Rule LGIP.

187. In response to Central Maine, we clarify that existing interconnection agreements that are filed with and accepted by the Commission prior to the effective date of this Final Rule will remain in effect. Regarding Sempra's request to allow the Parties to set aside interconnection agreements tendered but not executed before the issuance of the Final Rule, the Commission concludes that this decision is best left to the discretion of the Parties. If the Parties decide to continue their negotiations, they have until the Final Rule's effective date to submit their agreement to the Commission to qualify for grandfathering. Accordingly, Final Rule LGIP Section 5.1.1.3 states that an executed or unexecuted interconnection agreement submitted for approval by the Commission before the effective date of the Final Rule will be grandfathered and will not be rejected simply for failing to conform to the Final Rule LGIA.

188. With respect to Central Maine's and MidAmerican's requests for clarification of the term "outstanding requests" in Section 5.1.2, we clarify that the term refers to any request for interconnection that has been submitted to a Transmission Provider but has not yet been submitted to the Commission for approval prior to the effective date of this Final Rule.

189. There is no need to adopt MidAmerican's proposed language regarding the adequacy of a 60 day transition period in Section 5.1.2 since the Final Rule allows an Interconnection Customer to extend deadlines, and the 60 day period applies only to Interconnection Requests with outstanding studies for which an Interconnection Study Agreement has not been executed. We expect the Parties to work together during the transition period to ensure that no Interconnection Request is unreasonably delayed.

190. Finally, we deny BPA's request to explain the circumstances under which an Interconnection Customer may request an extension because these circumstances are likely to differ in each case. However, we expect that a Transmission Provider will grant an extension if it can be reasonably accommodated in a nondiscriminatory manner in the transition to the Final Rule LGIP.

191. **Section 5.2 – New Transmission Provider** – Proposed LGIP Section 5.2 provided that if the Transmission Provider transfers control of its Transmission System to a successor Transmission Provider while an Interconnection Request is pending, the original Transmission Provider would also transfer to the successor any deposit or payment that exceeds the cost that it has incurred. The original Transmission Provider would be required to coordinate with the successor to complete any appropriate Interconnection Study. If an Interconnection Agreement has not been executed or if an unexecuted Interconnection Agreement has been filed with the Commission, the Interconnection Customer would have the option to complete negotiations with either the initial Transmission Provider or the successor.

Comments

192. Dairyland Power observes that the initial Transmission Provider should provide interest to the successor when the balance of deposits or payments is transferred. Also, if the study costs of the new Transmission Provider exceed the amount of the deposit, it is reasonable that the Interconnection Customer make up the difference.

193. Without explanation, NYTO states that the Interconnection Customer should not have the option of negotiating with a successor Transmission Provider.

Commission Conclusion

194. With respect to Dairyland Power's comment, the Commission clarifies that any additional costs incurred by the successor in excess of the deposit amounts must be treated in accordance with the Final Rule and paid upon completion of the Interconnection Studies. The Commission does not adopt NYTO's position and instead permits the Interconnection Customer to negotiate with the successor Transmission Provider.

195. **Section 6 – Interconnection Feasibility Study**
Section 7 – Interconnection System Impact Study
Section 8 – Interconnection Facilities Study

Section 10 – Optional Interconnection Study – Proposed LGIP Sections 6, 7 and

8 describe (1) the analyses that would be conducted for each of the Feasibility, System Impact, and Facilities Studies, (2) the Interconnection Customer's responsibility regarding the actual cost of each study and of any restudies that may be required; and (3) the right an Interconnection Customer would have to maintain its Queue Position and substitute a Point of Interconnection, identified by either the Transmission Provider or the Interconnection Customer, if any of these Interconnection Studies uncovers a result that the Interconnection Customer and Transmission Provider did not contemplate during the Scoping Meeting. These sections would also allow an Interconnection Customer to direct that one of the alternative Points of Interconnection specified in the related Interconnection Feasibility Study Agreement and Scoping Meeting be used if the Transmission Provider cannot agree on a substitute Point of Interconnection.

196. Section 10 proposed that the Interconnection Customer may ask the Transmission Provider to perform a reasonable number of Optional Interconnection Studies. An Optional Interconnection Study would be a sensitivity analysis based on assumptions provided by the Interconnection Customer. The scope of the Optional Interconnection Study would be to identify the Interconnection Facilities, Network Upgrades and the costs that may be required to provide transmission service or Interconnection Service.

197. The following paragraphs group together discussions of Sections 6, 7, 8, and 10 because of the relationships among the topics and provisions.

General Comments Related to the Feasibility Study, the System Impact Study, the Facilities Study and the Optional Interconnection Study

198. A number of commenters, including El Paso, FirstEnergy, the Midwest ISO, National Grid, and PJM, are concerned that the proposed Interconnection Studies will take longer to complete than the Interconnection Studies that a Transmission Provider typically performs today, and will lead to delays in the development of new generation projects. TVA believes that the study deadlines are unrealistic, particularly for Transmission Providers with medium to large interconnection queues. It opposes having to study the Energy Resource Interconnection Service and Network Resource Interconnection Service during each phase of the Interconnection Study process. Instead, TVA proposes that the Interconnection Customer should be able to designate only one Interconnection Service for study purposes or adjusting the time lines in Sections 6, 7, 8, and 10 to reflect the increased scope of work required by giving the Interconnection Customer such alternatives. Imperial Irrigation opposes the NOPR's proposed Interconnection Studies because it does not have enough resources to conduct them. NYISO urges the Commission to allow for regional differences in the Final Rule.

199. Entergy opposes giving the Interconnection Customer the ability to continually modify its selected Point of Interconnection throughout the study process. TVA opposes an Interconnection Customer maintaining its position in the queue if the Interconnection

Customer changes its Point of Interconnection in any of the Interconnection Studies. PJM believes that to allow the Interconnection Customer to require restudies throughout the Interconnection Study process is inconsistent with a workable regional planning process.

200. Sempra opposes setting a dollar figure for good faith estimates of Interconnection Study costs in the standardized study agreements that are attached as appendices to the Final Rule LGIA. It supports leaving the cost estimates blank in the appendices, with the expectation that the Transmission Provider would provide the timely good faith estimate later. Sempra also supports limiting the Transmission Provider's ability to pass on cost overruns to the Interconnection Customer.

201. Central Maine notes that the proposed Interconnection Study agreements would fix the "good faith estimated cost for performance" of each particular study. It argues that this is inappropriate because Interconnection Study costs vary greatly from one Generating Facility to another. It believes that Transmission Providers should be able to tailor each Interconnection Study agreement to the particular Generating Facility, and to include the good faith Interconnection Study cost estimate in each such agreement. If prepayment of Interconnection Study costs is not required, the deposit should be a percentage of the estimated total Interconnection Study cost, as opposed to a fixed dollar amount.

202. Several commenters seek additional requirements in assigning cost responsibility for Interconnection Studies to the Interconnection Customer. Central Maine notes that there are no proposed payment terms governing restudies, and supports clearly stating that the Interconnection Customer should bear full cost responsibility for a restudy. BPA supports requiring the Interconnection Customer to pay the estimated cost of the Interconnection Feasibility Study in advance under Sections 6.1 and 7.2. National Grid's position is that the Interconnection Customer should prepay the costs of all Interconnection Studies because the Transmission Provider is exposed to the risk of nonpayment. Central Vermont PSC believes that the Interconnection Customer should bear study costs involving an Affected System.

203. Several entities seek clarification on the proper scope of, and standards for, the Interconnection Studies. Cal ISO believes that a study should encompass conditions that include off-peak scenarios and contingency conditions. Entergy and Westconnect RTO argue that the NOPR LGIP does not mention types of Interconnection Studies other than load flow, short circuit, and stability studies. They suggest that the scope of the Interconnection Studies not be limited to these named analyses, but be expanded to include additional Interconnection Studies conducted in accordance with Good Utility Practice. PSNM supports expanding the scope of Interconnection Studies to encompass any analyses dictated by Good Utility Practice and allow for additional time on specialized Interconnection Studies, if needed. PacifiCorp supports permitting the Transmission Provider to require additional Interconnection Studies recommended or required by a regional reliability council, including remedial action margin studies. Georgia Transmission believes that the Transmission Provider's obligation under Sections 6.2 and 6.3 is inconsistent with the limited scope of the Interconnection

Feasibility Study, which is defined to consist only of a power flow study and a short circuit analysis.

204. Southern asks whether, if one Interconnection Request is required to be restudied by a date certain, all other lower queued requests would have to be restudied by that same date. Southern believes that this would be unworkable and unrealistic.

205. NYTO seeks details on specific study procedures for each of the Interconnection Studies.

Comments Related to Interconnection Feasibility Studies

206. SoCal Water District argues that an Interconnection Customer should lose its position in the queue when the Interconnection Feasibility Study uncovers a result that was not contemplated during the Scoping Meeting, instead of being allowed to designate a different site for the Point of Interconnection, as proposed. It says that this will encourage the Interconnection Customer to make the right choice at the beginning. It also comments that the Interconnection Customer should not be assigned a Queue Position until after the completion of the Interconnection Feasibility Study.

207. NSTAR believes that Interconnection Feasibility and Interconnection Facilities Studies should be at the option of the Interconnection Customer.

208. The Midwest ISO points out that it is not always possible to determine accurately when an Interconnection Customer in a high Queue Position will actually come on line and that this could affect the accuracy of the Interconnection Feasibility Study requested by a lower queued Interconnection Customer.

209. Sempra supports allowing a Transmission Provider or Transmission Owner to consider in its Interconnection Studies the In-Service Dates of all proposed generation projects, even those lower in the queue. This is so that the studies produce sound results for reliability purposes and consider all projects that will come on line at approximately the same time.

Comments Related to Interconnection System Impact Studies

210. FirstEnergy opposes as unreasonably short the proposed three day period of time during which a Transmission Provider must give an Interconnection Customer a non-binding good faith estimate of the cost and time frame for completing an Interconnection System Impact Study.

Comments Related to Optional Interconnection Studies

211. Proposed LGIP Section 10.1 would allow the Interconnection Customer to ask the Transmission Provider to perform a reasonable number of Optional Interconnection Studies on or after the date the Interconnection Customer receives the results of the Interconnection System Impact Study associated with its Interconnection Request. A Transmission Provider would have five days from the date it receives a request for an

Optional Interconnection Study to give the Interconnection Customer an Optional Interconnection Study Agreement. Commenters raise concerns with the requirement to perform Optional Interconnection Studies, cost responsibilities for such studies, and the proposed deadlines.

212. Southern opposes allowing an Interconnection Customer to require that a Transmission Provider perform Optional Interconnection Studies. Southern believes that Optional Interconnection Studies will delay the process by tying up Transmission Provider resources that could be dedicated to performing the required studies. BPA contends that allowing the Interconnection Customer to require an unspecified number of Optional Interconnection Studies, while requiring that the standard Interconnection Studies be performed within the standard deadlines, places an unreasonable burden on the Transmission Provider.

213. Nevada Power opposes having to conduct Optional Interconnection Studies on the grounds that allowing changes to the original Interconnection Request violates the queue rights of other Interconnection Customers by giving additional study time and priority to the Optional Interconnection Study request. Dominion Resources makes a similar point.

214. SoCal Edison believes that the Final Rule should provide for Optional Interconnection Studies (1) that are performed outside the NOPR LGIP time line, (2) if it is understood by the Interconnection Customer who elects to implement a study that implements Material Changes, that it could impact the Generating Facility's Queue Position; and (3) may not exceed for each requester a maximum of two Optional Interconnection Studies. NYISO urges the Commission to delete Section 10.1 to reduce the number of studies that the Transmission Provider must perform. The Midwest ISO believes that the Interconnection Feasibility Study may be elected and can serve as the Optional Interconnection Study described in Section 10.

215. On the issue of cost responsibility, Central Vermont PSC supports having the Interconnection Customer compensate the Transmission Provider for the costs of an Optional Interconnection Study, including all charges incurred by an Affected System.

216. With respect to the deadlines associated with Optional Interconnection Studies, FirstEnergy believes that the five day turnaround period for the Transmission Provider to provide an Optional Interconnection Study Agreement, as called for in Section 10.1, is too short and that a ten day period would be better. Cal ISO also supports a ten day turnaround time.

Commission Conclusion – General Comments

217. The proposed time frames for completing Interconnection Studies are reasonable. For each of the studies, the NOPR LGIP allows for the possibility that the Transmission Provider will not be able to complete the study within the allotted time. In these cases, the NOPR LGIP provides that the Interconnection Customer and the Transmission Provider will come to an acceptable accommodation. As to Imperial Irrigation's concern that it lacks sufficient resources to conduct the Interconnection Studies, Section 13.4

gives the Parties the option of using a contractor to complete the required studies at the Interconnection Customer's expense and Section 4.2 allows the Transmission Provider to cluster Interconnection Studies, thereby saving time and money.

218. We believe that the proposed Interconnection Study deposit amounts are high enough to ensure that an Interconnection Customer is serious about its Interconnection Request. In the absence of standardized Interconnection Study cost estimates, a Transmission Provider could set the Interconnection Study costs at such high levels so as to discourage entry by competing generators.

219. Central Maine does not identify the benefits of making Interconnection Study deposits a percentage of the estimated Interconnection Study costs. Because the proposed dollar amounts are reasonable and are the result of the consensus process, the Commission adopts them for the Final Rule LGIP.

220. We find that the proposed provisions regarding the payment of study costs by the Interconnection Customer are adequate. The NOPR LGIP makes clear that the Interconnection Customer is responsible for the actual costs of all Interconnection Studies. We reject the proposal that the Interconnection Customer fully prepay the costs of Interconnection Studies because the advance payment would be based on Transmission Provider estimates rather than actual costs. The Commission recognizes that the costs of performing Interconnection Studies may vary by Interconnection Customer because each interconnection is unique. The unique features of each interconnection should be identified either in the Scoping Meeting or early in the Interconnection Study process so that the Transmission Provider can offer the Interconnection Customer a reasonable estimate of what the actual study costs will be. However, we will require the Transmission Provider to provide a detailed and itemized accounting of the Interconnection Study costs in the relevant invoices. If the Interconnection Customer disputes the study cost, it may pursue dispute resolution procedures as described in Section 13.5 of the Final Rule LGIP.

221. With regard to commenters' various concerns about the proper scope of, and standards for, the Interconnection Studies, the Commission emphasizes that the Final Rule LGIP should not be interpreted as preventing the Transmission Provider from studying Interconnection Requests in accordance with Good Utility Practice and regional reliability requirements. The Transmission Provider may conduct necessary Interconnection Studies using any standards that are generally accepted within the region and consistently applied to all generation projects, including those of the Transmission Provider. If these standards differ from those specified in the LGIP, the Transmission Provider must include them in its compliance filing and may implement them only upon approval of the Commission. For this reason, we decline to specify detailed study procedures for each Interconnection Study beyond what is specified in the Final Rule LGIP.

Commission Conclusion – Interconnection Feasibility Studies

222. With regard to the concern that allowing changes to original Interconnection Requests would be unworkable and would violate the rights of lower queued Interconnection Customers due to the need to conduct numerous restudies, the Final Rule allows the Transmission Provider to take additional time to complete the necessary work. In addition, although lower queued Interconnection Customers may be harmed when their Interconnection Requests must be restudied due to actions of an Interconnection Customer higher in the queue, they also benefit from the flexibility to request that the Transmission Provider study a substitute Point of Interconnection. In this respect, the Commission finds that the NOPR LGIP strikes an appropriate balance and, accordingly, adopts it in the Final Rule.

223. Regarding Sempra's question about which projects within the queue should be considered when performing Interconnection Studies, the Commission requires the Transmission Provider to consider in its Interconnection Studies all generators with both higher and lower queued Interconnection Requests that could affect the Network Upgrades associated with integrating these generators with the Transmission System, as specified in the Final Rule LGIP.

Commission Conclusion – Interconnection System Impact Studies

224. In response to FirstEnergy's comment that there is insufficient time to provide cost and time estimates for completing an Interconnection System Impact Study, we find that three Business Days is reasonable. We note that prior to the Interconnection System Impact Study, the Transmission Provider will have conducted the Interconnection Feasibility Study and the Parties will have met to discuss the study results. Accordingly, through this ongoing process, the Transmission Provider will have had ample time to anticipate and prepare such estimates.

Commission Conclusion – Optional Interconnection Studies

225. The Commission finds that commenters' concerns about allowing an Interconnection Customer to request Optional Interconnection Studies are misplaced. Such studies are for informational purposes only and are to be completed within an agreed upon time period using Reasonable Efforts. If Optional Interconnection Studies place too great a burden on the resources of the Transmission Provider, the Final Rule permits the use of a contractor at the Interconnection Customer's expense. The Commission is neither eliminating these provisions nor, as SoCal Edison proposes, limiting the number of Optional Interconnection Studies an Interconnection Customer may request. These studies may provide information needed by the Interconnection Customer. Since the Interconnection Customer pays for the Optional Interconnection Study and a contractor may be used for this purposes, the impact on a Transmission Provider is minimal.

226. **Section 9 – Engineering & Procurement ("E&P") Agreement** (In the NOPR: Agreements) – Proposed LGIP Section 9 provided a mechanism for the Transmission Provider and the Interconnection Customer to enter into an Engineering & Procurement Agreement prior to executing the LGIA. An Interconnection Customer may ask that the

Transmission Provider begin engineering and procurement of long lead-time items necessary for the establishment of the interconnection. The Transmission Provider is not obligated to offer an agreement if the Interconnection Customer is in Dispute Resolution as a result of an allegation that the Interconnection Customer has failed to meet any milestones or comply with any other sections of the LGIP. This section also specifies the cost and other obligations of the Interconnection Customer.

Comments

227. Calpine and Duke Energy propose that Section 9.1 be expanded to cover situations where the construction of certain Network Upgrades takes place prior to the execution of the LGIA. Duke Energy states that the Transmission Provider should be prohibited from refusing to enter into an interim Engineering & Procurement Agreement unless the Interconnection Customer's failure to meet milestones directly affects the Transmission Provider's ability to meet its obligation under the Engineering & Procurement Agreement. FirstEnergy states that it is inappropriate to enter into an Engineering & Procurement Agreement prior to the execution of an LGIA, or the filing of an unexecuted LGIA with the Commission.

Commission Conclusion

228. We disagree with Calpine and Duke Energy regarding construction. The Final Rule does not require the construction of Network Upgrades prior to the execution of the LGIA; nor do we see why the Transmission Provider should be placed at risk by committing to the construction of such Network Upgrades prior to the execution of an LGIA. Regarding FirstEnergy's comments, we conclude that it is reasonable to allow the Parties to enter into an Engineering & Procurement Agreement for long lead-time items necessary to accommodate the interconnection as long as the Interconnection Customer bears the cost risk. Likewise, in response to Duke Energy and consistent with the language in the NOPR, we conclude that it is reasonable to require a Transmission Provider to offer an Engineering & Procurement Agreement only if the Interconnection Customer has met its obligations under the Final Rule LGIP. Accordingly, we adopt Section 9 in the Final Rule as proposed.

229. **Section 11 – Standard Large Generator Interconnection Agreement** (In the NOPR: Interconnection Agreement) – Proposed LGIP Section 11 includes procedures for tendering, negotiating, executing, and filing an interconnection agreement.

230. **Section 11.1 – Tender** – Proposed LGIP Section 11.1 provided that the Transmission Provider simultaneously submit to the Interconnection Customer the draft Interconnection Facilities Study Report and a draft LGIA, to the extent practicable, in the form of the pro forma LGIA. Within 30 Calendar Days after the issuance of the draft Interconnection Facilities Study report and a draft pro forma LGIA, the Transmission Provider shall submit the completed draft of the LGIA.

Comments

231. Central Maine believes that 30 days is an unreasonable time frame in which to prepare such technically detailed documents as the appendices to the interconnection agreement, and it should therefore be increased to 60 days.

Commission Conclusion

232. Central Maine has not convinced us of the difficulty of preparing the interconnection agreement appendices in 30 Calendar Days or shown a need to extend the time in which to prepare them to 60 Calendar Days. Accordingly, the Commission retains the proposed 30 Calendar Day requirement for the Transmission Provider to tender the completed interconnection agreement.

233. **Section 11.2 – Negotiation** – Proposed LGIP Section 11.2 provided that the Transmission Provider and the Interconnection Customer be required to negotiate the terms contained in the appendices to the interconnection agreement for up to 60 Calendar Days after tender of the final Interconnection Facilities Report. If the Interconnection Customer determines that negotiations are at an impasse, it could either request termination of the negotiations and request submission of the unexecuted interconnection agreement to the Commission, or initiate Dispute Resolution procedures. If the Interconnection Customer requests termination of the negotiations, but within 60 Calendar Days thereafter fails to request either the filing of the unexecuted LGIA or initiate Dispute Resolution, it would be deemed to have withdrawn its Interconnection Request.

Comments

234. FirstEnergy contends that the provisions of this section unduly restrict the ability of the Parties to negotiate a resolution. It argues that proposed LGIP Section 11.2 provides no recourse for the Transmission Provider in circumstances where the negotiations are at an impasse and the Interconnection Customer neither terminates the Interconnection Request nor continues to negotiate in good-faith. FirstEnergy recommends that Section 11.2 of the NOPR IA be revised to include the following language: "Unless otherwise agreed to by the Parties, if the Interconnection Customer has not executed the Interconnection Agreement, requested the filing of an unexecuted [interconnection agreement], or initiated Dispute Resolution procedures within 60 days of the tender of the completed draft of the LGIA Appendices, the Interconnection Customer will have been deemed to have withdrawn its Interconnection Request.

Commission Conclusion

235. The Commission agrees with FirstEnergy that there could be circumstances where the Parties could be unduly restricted in their negotiations and therefore adopts the language proposed by FirstEnergy in the Final Rule LGIP.

236. **Section 11.3 – Execution and Filing** – Proposed LGIP Section 11.3 would have the Interconnection Customer demonstrate Site Control to the Transmission Provider, and provides specific milestones as evidence of Site Control. It would also provide that the Transmission Provider file the LGIA as soon as practicable, but not later than ten Business Days after receiving either the two executed originals of the LGIA, or the request by the Interconnection Customer to file an unexecuted LGIA.

Comments

237. Mirant does not oppose requiring an Interconnection Customer to maintain Site Control and provide reasonable evidence that the Interconnection Customer has met some of the specified milestones. However, it asks the Commission to clarify what constitutes "reasonable evidence" of Site Control. Other commenters, including PJM and PJMTO, assert that the Commission should give the Interconnection Customer more milestones to meet.

238. PJM opposes letting an Interconnection Customer deposit \$250,000 instead of demonstrating meaningful progress and believes that doing so can lead to clogging and gaming of the queue.

239. Central Maine requests that the Commission extend from ten to 30 days the obligation to file, as additional time is needed to prepare the filing. It claims that neither Party would be adversely affected by such an extension.

Commission Conclusion

240. We shall modify Proposed LGIP Section 11.3 to better reflect the Commission's unexecuted agreement procedure in the OATT.⁶² Accordingly, the unexecuted agreement should contain terms and conditions deemed appropriate by the Transmission Provider for the Interconnection Request. But the LGIA approach differs from the OATT approach, since the Parties' obligations may be significantly different in the LGIA context. The OATT unexecuted agreement provision requires the Transmission Provider to commence providing service as long as the Transmission Customer agrees to compensate the Transmission Provider at the rate the Commission ultimately determined to be just and reasonable. Since the LGIA involves obligations different from those in the OATT, including facilities construction that may be undertaken by either Party, it is appropriate to give both Parties more flexibility to determine whether to proceed under the non-disputed terms of their unexecuted agreement. Once the unexecuted agreement is filed, if the Parties agree to proceed with design, procurement, and construction of facilities and upgrades under the agreed upon terms of the unexecuted agreement, they may proceed pending Commission action.

⁶²See Section 15.3 of the OATT.

241. In response to Mirant's request to clarify what constitutes "reasonable evidence" of Site Control, the Commission notes that the Final Rule definition of the term specifically lists the types of documentation that reasonably demonstrates evidence of Site Control.

242. PJM proposes to eliminate the \$250,000 additional deposit if the Interconnection Customer is unable to provide evidence of Site Control. It would also have the Generating Facility lose its place in the queue if the Interconnection Customer misses a milestone. We find that the deposit is a sufficient showing that the Interconnection Customer is serious about the project and will continue to work to meet the requirements of Site Control and other milestones. Finally, this section provides sufficient milestones and penalties to reasonably ensure that the Interconnection Customer is intent on completing the project.

243. Central Maine has not provided any support for its request to extend the time from ten to 30 days to meet the filing obligations. Accordingly, the Final Rule retains the ten Business Days requirement.

244. **Section 12 – Construction of Transmission Provider's Interconnection Facilities and Network Upgrades** – Proposed LGIP Section 12 required the Transmission Provider and the Interconnection Customer to agree to a schedule for the construction of Interconnection Facilities and Network Upgrades that are needed to accommodate the Interconnection Request. It also provided for an Interconnection Customer to request the acceleration of Network Upgrades that are needed for a higher-queued Interconnection Customer that would not have otherwise been completed in time to support the lower queued Interconnection Customer's In-Service Date as long as it commits to pay any costs associated with expediting the project, including the cost of any Network Upgrades assigned to the higher-queued Interconnection Customer.

245. **Section 12.1 – Schedule** – Proposed LGIP Section 12.1 provided that the Transmission Provider and Interconnection Customer negotiate in good faith to develop a schedule for the construction of the Transmission Provider's Interconnection Facilities and Network Upgrades.

Comments

246. Duke Energy and FirstEnergy contend that this section should be deleted, since it is already covered in Article 5 of the NOPR LGIA.

Commission Conclusion

247. The Commission finds no reason to delete Section 12.1. It merely states that the Parties must negotiate a construction schedule in good faith. The fact that the negotiated construction schedule is in Appendix B (Milestones) of the LGIA does not require us to delete Section 12.1 from the Final Rule LGIP.

248. **Section 12.2 – Permits** – Proposed LGIP Section 12.2 provided that the Parties specify in the LGIA each Party's responsibility for obtaining permits, licenses, and

authorizations necessary to construct the Interconnection Facilities and Network Upgrades needed to accommodate the proposed interconnection in conformance with all Applicable Laws and Regulations.

Comments

249. Duke Energy states that the first sentence of Section 12.2 should be stricken because it duplicates NOPR LGIA Article 14.1. FirstEnergy contends that the entire section should be deleted because the topic is more properly addressed in the LGIA. Cinergy asks the Commission to clarify that nothing in the section requires the Transmission Provider to exercise its power of eminent domain. Central Maine argues that the phrase "nothing in this Section 12.2 shall be construed to waive any rights under Applicable Laws and Regulations" should be either deleted or applied to the entire Final Rule LGIP, because its inclusion in just one provision creates confusion.

Commission Conclusion

250. The Commission disagrees with Duke Energy. Proposed LGIP Section 12.2 merely requires the Parties to specify in the LGIA each Party's responsibility for obtaining permits, licenses, and authorizations necessary to construct the Interconnection Facilities and Network Upgrades. Article 14.1 of the NOPR LGIA, on the other hand, states that each Party's obligations under the LGIA are conditioned upon regulatory approval from relevant Governmental Authorities.

251. In response to Cinergy's assertion, while the Commission does not require that the Transmission Provider exercise its right of eminent domain in all instances, we do not prohibit it from doing so. Rather, in the Final Rule, consistent with the Commission's discussion of NOPR LGIA Article 5.11 (now Final Rule LGIA Article 5.13), Lands of Other Property Owners, we require that a Transmission Provider or Transmission Owner use efforts similar to those it typically undertakes on its own behalf (or on behalf of an Affiliate), which may include use of eminent domain rights, to secure permits for the Interconnection Customer, unless restricted from doing so by state law.

252. We agree with Central Maine's arguments and are therefore not incorporating into this section the proposed text dealing with the waiving of rights under Applicable Laws and Regulations.

253. Finally, the Commission agrees with FirstEnergy that the issues contained in this section are more appropriately discussed in the Final Rule LGIA. Accordingly, proposed LGIP Section 12.2 is being deleted from the Final Rule LGIP and is being incorporated into the Final Rule LGIA as Article 5.14.

254. **Section 12.3 – Construction Sequencing** (In the Final Rule LGIP: Section 12.2) – Proposed LGIP Section 12.3 stated that an Interconnection Customer may ask the Transmission Provider to advance construction of Network Upgrades supporting other generators that were assumed to be completed in time to support the Interconnection Customer's Generating Facility's In-Service Date. The Transmission Provider would have to use Reasonable Efforts to advance the construction of such Network Upgrades,

provided that the Interconnection Customer commits to pay the Transmission Provider the cost of the Network Upgrades and any associated expediting costs. The Transmission Provider must refund to the Interconnection Customer the costs of any expedited Network Upgrades after the Transmission Provider receives payment from the entity for which the Network Upgrades were to be originally constructed. Until such costs are refunded, the Transmission Provider must provide the Interconnection Customer with transmission credits for the costs of the expedited Network Upgrades.

Comments

255. Duke Energy seeks clarification that (1) the Interconnection Customer earlier in the queue is obligated to pay the Transmission Provider only the amount not refunded, through credits, to the Interconnection Customer requesting the acceleration (and thus is eligible for transmission credits only for that amount), (2) the Interconnection Customer requesting the accelerated construction is reimbursed for Network Upgrade costs only up to the amount of the transmission credits not received, (3) the Transmission Provider is not required to advance funds for construction or to pay total credits in excess of the cost of the Network Upgrades; and (4) the higher-queued Interconnection Customer must pay for the expedited Network Upgrades on the date that it would have been required to pay were it not for the request for acceleration. Duke Energy also notes that there may be circumstances when acceleration requires greater expenditures than would be required to meet a reasonable construction schedule. It therefore recommends that if a Transmission Provider believes that the Commission would not allow such expenditures to be included in the revenue requirement under traditional ratemaking principles, the Transmission Provider should have the opportunity to challenge the provision of credits for these costs.

Commission Conclusion

256. The Commission affirms that an Interconnection Customer higher in the queue is obligated to pay the Transmission Provider for only that portion of the costs of the expedited Network Upgrades not already paid to the Interconnection Customer that requested expedition through transmission credits. The Transmission Provider can then forward this amount to the expediting Interconnection Customer as a lump sum payment for the balance of costs that the higher-queued Interconnection Customer is owed. At this point, the payment of credits will cease and the payment of credits to the higher-queued Interconnection Customer can begin. The latter credits will continue until the higher-queued Interconnection Customer has been reimbursed for the portion of the Network Upgrade costs that it has paid. The Transmission Provider is also not required to advance funds for construction or to pay total credits in excess of the cost of the Network Upgrades, including any interest that may be due. Finally, the higher-queued Interconnection Customer is responsible for paying the costs of the advanced Network Upgrade on the date that it would have been required to pay had there been no request for accelerated construction.

257. In response to Duke Energy's final concern, the Commission recognizes that there may be circumstances under which the Transmission Provider, in attempting to accommodate the Interconnection Customer's request to accelerate the project, may have

to incur costs that would exceed what would normally be required to meet a reasonable construction schedule. However, we will consider such costs to have been prudently incurred unless it is demonstrated in a rate proceeding that the Transmission Provider could have met the Interconnection Customer's requested In-Service Date at a lower cost through the construction of alternative Network Upgrades, or by other means. Consequently, the Transmission Provider should have no reason to challenge the provision of credits for any costs that it prudently incurs.

258. Consistent with the above discussion, the Final Rule clarifies Section 12.3 and removes certain text that is largely redundant.

259. This section is designated Section 12.2 in the Final Rule LGIP.

260. **Section 13 – Miscellaneous** – Proposed LGIP Section 13 included a variety of provisions, described below.

261. **Section 13.1 – Confidentiality** – Proposed LGIP Section 13.1 would have required that the Transmission Provider afford confidential treatment to all information it receives from the Interconnection Customer to process its request for Interconnection Service except for information that is in the Interconnection Request and information that is or becomes generally available to the public. The Transmission Provider would be permitted to use this information only for the Interconnection Study and to share it only with those who need it for Interconnection Studies and actions to interconnect the Generating Facility. The Transmission Provider would not be permitted to share such information with the merchant generation or marketing functions of the Transmission Provider or its Affiliates' merchant functions or as otherwise prohibited by Order No. 889.

262. The Transmission Provider would be liable to the Interconnection Customer for any Breach of confidentiality caused by its agent or contractor. If requested by the Interconnection Customer, the Transmission Provider would be required to destroy or return to the Interconnection Customer information no longer needed. If the Transmission Provider is required to disclose the information to any regulatory body, it would be obligated to request confidential treatment of the information. The Transmission Provider must provide the Interconnection Customer with prompt written notice if it receives a request for the Confidential Information to allow the Interconnection Customer an opportunity to contest the disclosure. The confidentiality provisions would not require the Transmission Provider or Interconnection Customer to disclose information in violation of any confidentiality obligations to third parties.

Comments

263. Several commenters, including Central Maine and MidAmerican, argue that these confidentiality protections should be extended to the Transmission Provider as well. Central Maine seeks a clear policy about what information may be disclosed, what information must be disclosed, the manner of disclosure, and what information must remain confidential as part of the interconnection process.

264. Lakeland seeks reconciliation of the differences between the confidentiality provisions of the NOPR LGIA and the NOPR LGIP. Specifically, the Final Rule LGIP should accommodate compliance with state Open Records laws, including Florida's, as in the NOPR LGIA.

265. Entergy opposes requiring a Transmission Provider to provide Confidential Information, or disclose anything not public, to an Interconnection Customer. If that disclosure is required by the Final Rule, the confidentiality requirements should be reciprocal and a Party should be required to designate which materials warrant confidential treatment.

266. The Midwest ISO agrees with the proposal that Confidential Information only be shared among employees of the Transmission Provider (including Transmission Owners of Affected Systems) and third parties that need the information to perform or review Interconnection Studies. Moreover, in accordance with Order No. 889, the information should not be shared with individuals responsible for merchant or marketing functions. The Midwest ISO also requests that the Commission clarify what type of planning information should be kept confidential for security reasons and what information should be made available, perhaps under a non-disclosure agreement executed by the Parties. Proposed LGIP Section 13.1 would have required that the Transmission Provider keep confidential all information provided by the Interconnection Customer related to Interconnection Service that is not provided in the Interconnection Request; the Midwest ISO and NERC state that some information in the Interconnection Request may be commercially sensitive, such as unit-specific data, and should be kept confidential.

267. GE Power notes that developers generally prefer to look at alternative project scenarios before going "on the record" with their plans. GE Power requests that the Commission address the balance between commercial confidentiality or security-based secrecy and the need to make the data available so that studies and business forecasting can be completed.

268. NERC comments that the information provided by Interconnection Customers that may be considered confidential under Section 13.1 is needed to protect reliability because it generally is shared not only with directly affected neighboring systems, but also with regional and NERC study groups for modeling inter-regional and interconnection reliability effects. NERC states that this data is generally provided in a manner that masks ownership and other commercial terms and that NERC has standards of conduct for Reliability Coordination and a data confidentiality agreement. It requests that mechanisms remain in place to ensure the availability and confidentiality of such data so that Interconnection Customers will provide data needed for reliability assessment. NERC proposes that an Interconnection Customer identify specific information to be protected as confidential and that the Transmission Provider share this information only with parties to confidentiality agreements.

Commission Conclusion

269. In response to Central Maine's and several others' requests that the confidentiality provision in the NOPR LGIP be made more specific, the Commission is incorporating into Section 13.1 certain aspects of the confidentiality provisions in Article 22 of the LGIA. These include a definition of Confidential Information, procedures for the release of Confidential Information, and guidance regarding how Confidential Information should be treated when it is requested by the Commission as part of an investigation. Both Parties are eligible to use the protection afforded by the revised section as long as the information is identified as Confidential Information in accordance with the section. This revision should satisfy commenters that sought greater specificity regarding procedures for maintaining and disclosing information in the confidentiality provisions in the LGIP. It also eliminates any significant conflicts between the LGIP and LGIA confidentiality provisions. The Final Rule LGIP Section 13.1 differs from Final Rule LGIA Article 22 only with respect to the provisions in Article 22 that address the fact that the confidentiality obligations arise under a signed Interconnection Agreement.

270. This revision eliminates from the Section 13.1 the exception for information that appears in the Interconnection Request. Under the revised provision, it is the Interconnection Customer's responsibility to designate the information submitted in its Interconnection Request that should remain confidential.

271. Lakeland requests that the Commission adopt provisions that accommodate compliance with state open records laws. Public utilities also may be subject to information restrictions arising from national security concerns. As noted above, the Commission expects all public utilities to meet basic standards for system infrastructure and operational security. In addition, if state laws indeed conflict with the confidentiality and information sharing addressed in this provision, the Commission expects that public utilities will make conforming changes to these provisions in their compliance filings and explain the statutory basis for such changes.

272. The Commission agrees with the Midwest ISO and NERC that the Final Rule must allow information to be shared with Transmission Provider representatives of NERC and other regional planning groups, since to deny them this information may undermine Transmission System reliability and modeling efforts. Section 13.1 of the Final Rule allows the Parties to share Confidential Information with an independent transmission administrator or reliability organization as long as the disclosing party agrees to promptly notify the other Party in writing and to seek to protect the Confidential Information from public disclosure by separate confidentiality agreement or other reasonable measures. We do not, as the Midwest ISO requests, specify the planning information that may be made available, as it is likely that the data will vary by region.

273. Finally, GE Power proposes that this rulemaking address what information a Transmission Provider should make available to a would-be Interconnection Customer before the submission of an Interconnection Request. We decline to do so. This Final Rule addresses interconnection, not the general availability of information to all those who have not yet submitted an Interconnection Request.

274. **Section 13.3 – Obligation for Study Costs** – Proposed LGIP Section 13.3 would have required the Interconnection Customer to pay the actual costs of the Interconnection Studies. If any deposit exceeds the actual cost of the study, that amount would be refunded to the Interconnection Customer or offset against the cost of any future Interconnection Studies associated with the Interconnection Request. Proposed LGIP Section 13.3 also stated that the Transmission Provider would not be obligated to perform or continue to perform any Interconnection Studies unless the Interconnection Customer has paid all undisputed amounts under this section.

Comments

275. PJM argues that the absence of significant milestones in Section 13.3 amplifies the opportunities for an Interconnection Customer to dispute its bill and string its project along at little cost. Any refusal to pay an invoiced study cost should be a Default that triggers withdrawal of the Interconnection Request.

276. The Midwest ISO believes that the Transmission Provider should be permitted to collect interest on any unpaid amounts not in dispute, and Duke Energy believes that deposits in excess of the actual study cost should be entitled to earn interest from the day a deposit is credited to an account.

277. Sempra would require the Interconnection Customer to pay for simple and inexpensive Interconnection Studies up front, and to pay for expensive and complicated studies through periodic payments.

Commission Conclusion

278. The Commission declines to adopt any of the proposed changes to Section 13.3 in the Final Rule. While an Interconnection Customer could delay the interconnection process merely by disputing its bill, the Commission is not convinced that a significant number of Interconnection Customers will act in this manner, since most Interconnection Customers presumably will want to have their projects on line as soon as possible. Furthermore, requiring the Interconnection Customer to pay all invoiced amounts, no matter how unreasonable, or lose its Queue Position would invite abuse on the part of the Transmission Provider.

279. In response to the Midwest ISO and Duke Energy, the payment of interest on study deposits and unpaid study costs tend to offset one another over time. Moreover, the Commission is not persuaded that the interest costs would be large enough to warrant the additional administrative expense that the Transmission Provider would incur in tracking the amounts due. Also, the requirement to pay a deposit and then additional amounts as they come due will generally achieve the result that Sempra seeks.

280. Finally, to ensure that the Interconnection Customer is adequately informed regarding the actual costs of Interconnection Studies, we revise Section 13.3 to require the Transmission Provider to provide a detailed and itemized accounting of the Interconnection Study costs in the relevant invoices.

281. **Section 13.4 – Third Parties Conducting Studies** – Proposed LGIP Section 13.4 provided that the Interconnection Customer be able to require the Transmission Provider, within 30 days of its notification, to use a consultant to complete the Interconnection Study at issue if (1) the Parties cannot agree to the timing of the completion of the Interconnection Study, or (2) the Interconnection Customer receives notice from the Transmission Provider that the Transmission Provider will not complete an Interconnection Study within the applicable time frame, or (3) the Interconnection Customer receives from the Transmission Provider neither the Interconnection Study nor a notice about not completing the Interconnection Study. In such situations, the Interconnection Study would be conducted at the Interconnection Customer's expense and in the case of (3), the Interconnection Customer could submit a claim to Dispute Resolution to recover the costs of the third party study. The consultant would be required to follow the LGIP protocols and use the information it receives to do the Interconnection Study for the sole purpose of completing the study. The Transmission Provider would be required to cooperate with the consultant to complete and issue the Interconnection Study in the shortest reasonable time.

Comments

282. Some commenters, including Duke Energy, EPSA, NYISO, and Sunflower Electric, endorse the NOPR proposal to allow an Interconnection Customer to request a consultant to undertake or complete an Interconnection Study, while others advocate the Transmission Provider being allowed to initiate use of a consultant to accelerate completion of Interconnection Studies, as well. Sunflower Electric sees use of a consultant as a short-term means to alleviate a Transmission Provider's backlog. Central Maine seeks clarification of the process for selecting the consultant. It argues that a 30 day deadline for a Transmission Provider to issue an RFP and select a consultant is not realistic.

283. BPA, MidAmerican, and PJM question whether use of a consultant will speed up the study process, whether it will significantly reduce a Transmission Provider's overall study effort, and whether it will help a Transmission Provider to more efficiently study multiple Interconnection Requests. They are concerned that any benefits may be limited to situations in which Interconnection Customers' projects are studied individually, on a non-integrated basis, in isolation from other higher-queued Interconnection Requests and system improvements and expansions. Others recommend allowing a Transmission Provider to complete pending Interconnection Studies for higher-queued Interconnection Requests before turning its databases, workpapers, and study results over to the consultant to help it move forward with its study. In addition, PJM observes that an independent Transmission Provider, such as an RTO or ISO, has no incentive to delay completion of an Interconnection Study. NYISO would have the ISO direct and review any consultant Interconnection Studies.

284. BPA proposes allowing a Transmission Provider to ignore the consultant's study if it is not completed by the deadline. BPA also wants sufficient time for the Transmission Provider, as "the expert" in regard to its system, to review the study to ensure that it is adequate and to make necessary changes to it.

Commission Conclusion

285. Based on the foregoing comments and a balancing of the interests of an Interconnection Customer (to obtain the results of any necessary Interconnection Studies as soon as possible) and the responsibility of Transmission Provider (to efficiently and effectively plan its Transmission System), the Commission will permit use of a consultant upon the request of an Interconnection Customer at any time during the Interconnection Study process. This is subject to the Transmission Provider deciding that such use will (1) help maintain or accelerate the study process for the Interconnection Customer's pending Interconnection Request and (2) not interfere with the Transmission Provider's planning processes or hamper the Transmission Provider's progress on any other Interconnection Studies for pending Interconnection Requests. Moreover, a consultant hired to perform an Interconnection Study must follow the same rules and procedures as does a Transmission Provider that conducts the study in-house.

286. The Commission will not specify in Section 13.4 all the terms, conditions, and selection processes that would be applicable. Instead, the Final Rule leaves it up to the Parties to negotiate the details of the timing and process for selecting the consultant, the deadlines for the consultant's work, the Transmission Provider's direction and review of the consultant's work, the contingency rights and obligations of the Parties if the consultant fails to timely deliver a study of adequate quality, and any other relevant matters. This added flexibility may increase opportunities for the use of a consultant to accelerate the completion of necessary Interconnection Studies when it is feasible to do so.

287. **Section 13.6 – Disputes** – Proposed LGIP Section 13.6 detailed requirements for the Dispute Resolution process. Upon written notice of a dispute arising out of the Interconnection and Operating Agreement or its performance, a senior representative or representatives of each Party would be required to try to resolve the dispute informally. Failing informal resolution within 30 Calendar days, by mutual agreement the dispute would be submitted to arbitration, or each Party would exercise its other legal or equitable rights. Section 13.6.2 specified external arbitration procedures, and Section 13.6.3 stated that unless otherwise agreed, the arbitrator would be required to render a decision within 90 Calendar Days of its appointment that shall be binding upon each Party. Final decision affecting jurisdictional rates, terms, and conditions would be filed with the Commission. Finally, Section 13.6.4 delineated responsibility for costs related to the resolution of disputes.

Comments

288. Central Maine believes that the Parties should be precluded from settling by binding arbitration matters that are under the Commission's jurisdiction.

Commission Conclusion

289. Although Section 13.6 proposed making Dispute Resolution available only for disputes arising under the LGIA, the Final Rule extends the procedures to disputes arising under the LGIP. This section is designated Section 13.5 in the Final Rule LGIP.

290. The Commission has long encouraged the use of alternative dispute resolution to resolve disagreements over Commission-jurisdictional contracts. The Commission's complaint rule, in fact, requires Parties to specify in a formal complaint whether they have attempted an informal resolution of contract-related disputes, and if they have not done so, to explain why not.⁶³ Final Rule LGIP Sections 13.5.1 through 13.5.3 reflect the Commission's policy of encouraging alternative dispute resolution without compromising the Commission's authority. Final Rule LGIP Section 13.5.3 prevents arbitrators from changing the provisions of the interconnection agreement in any manner. Arbitrators may only interpret and apply the provisions. Any such changes to the interconnection agreement could be made only pursuant to Sections 205 and 206 of the Federal Power Act, and would require Commission review. Although the arbitrator's decision is binding in so far as it is enforceable in any court having jurisdiction, an arbitrator's decision must be filed with the Commission if it affects jurisdictional rates, terms and conditions of service, Interconnection Facilities, or Network Upgrades. Thus, the Commission retains the authority to review the arbitrator's decision. Nor do we agree that the provision circumscribes the Parties' right to avail themselves of the Commission's complaint process because under Section 13.5.1, a Party that does not agree to arbitration may exercise its rights, including its right to bring a complaint to the Commission.

291. The Commission also adds language to Section 13.6.1 to emphasize that Parties should consider using informal dispute resolution as well as more formal options. The Commission encourages Parties to settle their disputes through other mechanisms (e.g., mediation, assisted negotiations, settlement judge procedures) prior to commencing arbitration proceedings. Of course, at any point during the process the disputing Parties may have recourse to alternative methods of dispute resolution, provided that both Parties agree.⁶⁴

292. **Appendices** – Proposed Appendix 1 is the application form for making an Interconnection Request. Proposed Appendices 2, 3, 4, and 5 set forth the terms for the Interconnection Feasibility Study Agreement, the Interconnection System Impact Study Agreement, the Interconnection Facilities Study Agreement, and the Optional Interconnection Study Agreement; and require a deposit of \$10,000 for the Interconnection Feasibility Study, \$50,000 for the Interconnection System Impact Study, \$100,000 for the Interconnection Facilities Study, and \$10,000 for the Optional Interconnection Study. The Final Rule LGIP retains these appendices. In addition, the Final Rule LGIP incorporates the Final Rule Standard Large Generator Interconnection Agreement at Appendix 6.

⁶³18 CFR 385.206(b)(9) (2003).

⁶⁴Disputing parties may retain mediators from outside sources, or they may use the Commission's Dispute Resolution Service or the Commission's settlement judge process.

B. Issues Related to the Standard Large Generator Interconnection Agreement (LGIA)

1. Overview

293. The proposed LGIA contained the Parties' contractual Interconnection Service rights and obligations. It addressed matters such as the effective date and termination costs; regulatory filings; scope of service, including interconnection product options; generator provided services; Interconnection Facilities engineering, procurement and construction; testing and inspection, including start-up and synchronization, system protection and controls requirements; emergency, and disconnect obligations; metering and communications; operations and maintenance; Defaults and indemnifications; transmission crediting; audits; and Dispute Resolution.

294. The proposed LGIA also specified the allocation of the responsibilities among the Interconnection Customer, the Transmission Provider and Transmission Owner (where the latter is a Party other than the Transmission Provider that owns the facilities to which the interconnection is being made), in regard to obtaining all permits and authorizations necessary to accomplish the interconnection.

295. Under this Final Rule, if an Interconnection Customer agrees to pay for any modification to the Transmission Provider's facilities necessitated by the requested interconnection, the Transmission Provider is obligated to offer an executable form of LGIA to the Interconnection Customer. The interconnection agreement becomes effective upon execution by the Parties, subject to acceptance by the Commission. If the Interconnection Customer executes the LGIA, the Transmission Provider, the Interconnection Customer, and the Transmission Owner must perform their respective obligations in accordance with the terms of the executed interconnection agreement, subject to modification by the Commission.

296. If the Interconnection Customer determines that negotiations are at an impasse, it may initiate Dispute Resolution procedures and, if not successful, request submission of the unexecuted agreement to the Commission by the Transmission Provider in accordance with Final Rule LGIP Section 11. Pending Commission action, the Parties will comply with the unexecuted agreement to the extent they can proceed under the agreed upon terms.

2. Article-by-Article Discussion of the Proposed LGIA

297. What follows is a discussion of the proposed LGIA, the comments received, and the Commission's conclusion. The order of discussion follows the organization of the proposed LGIA, covering Articles 1 through 30. Similar to the section-by-section discussion of the proposed LGIP, only articles for which issues are raised are presented. Readers should note again that article numbers referred to in the following discussion are the numbers contained in the proposed LGIA. Some proposed articles are renumbered in

the Final Rule; mention of that fact is made in the Commission Conclusions discussion, where appropriate.⁶⁵

298. **Article 1 – Definitions** – Proposed LGIA Article 1 contained the definitions of terms used throughout the NOPR LGIA. Many of these terms appear both in the NOPR LGIP as well as the NOPR LGIA and we have decided that a common list of all the defined terms should be included in both the Final Rule LGIA and Final Rule LGIP. However, for simplicity, discussion of commenters' concerns regarding defined terms are discussed in Part II.A.2, Section 1 (Definitions).

299. **Article 2 – Effective Date, Term and Termination** – Proposed LGIA Article 2 included the proposed effective date, the term of the proposed LGIA, and the procedures for its termination.

300. **Article 2.2 – Term of Agreement** – Article 2.2 proposed that the LGIA remain in effect for ten years, or longer by request, and be automatically renewed for each successive one year period thereafter.

Comments

301. Exelon, NYTO and PG&E believe that automatic renewal is unreasonable because it allows the LGIA to remain in effect for an indefinite period. PG&E argues that the LGIA should be for a fixed term (20 years, for example), because the ten year initial term coupled with automatic renewals could make it last forever without giving the Transmission Provider an opportunity to terminate the LGIA except in the case of a Default by the Interconnection Customer. PG&E further argues that a longer fixed term without automatic renewal gives the Parties the flexibility to change the terms of the LGIA at the end of the term to reflect new market structures as they may develop.

Commission Conclusion

302. We adopt Article 2.2 as proposed. Automatic renewal is an efficient mechanism to renew the LGIA. It mitigates a non-independent Transmission Provider's market power by allowing the Interconnection Customer to renew without renegotiation. At the same time, the interests of the Transmission Provider are adequately protected as it can terminate the LGIA in case of Default by the Interconnection Customer.

⁶⁵For some of the LGIA provisions that the Commission is adopting here, few if any written comments were submitted. Commenters tended to use the 30 pages to which they were limited to explain what they would change. They made statements of support for the rule in general, but did not make article-by-article comments on parts that they supported. As a result, the only comments received on some articles were calls for change, even if a majority of commenters may have indicated general support for the proposed articles that they did not specifically comment on.

303. The Commission also notes that the LGIA, in addition to addressing the electrical connection of the Interconnection Customer to the Transmission Provider's Transmission System, also fixes the performance, operational, and financial obligations of the Parties even after the Generating Facility begins commercial operation. These obligations and responsibilities are of indefinite duration, existing as long as the Generating Facility is connected to the Transmission Provider's Transmission System. Therefore, it is appropriate for the term of the LGIA to be indefinite as well.

304. In addition, a ten year minimum term allows the Parties to avoid tax liability for the payments to the Transmission Provider under current Internal Revenue Service policy.⁶⁶

305. **Article 2.3.1 – Written Notice** – Proposed LGIA Article 2.3.1 provides that the Interconnection Customer may terminate the LGIA after giving the Transmission Provider 30 Calendar Days advance written notice.

Comments

306. MidAmerican proposes requiring an Interconnection Customer to provide three years' advance notice to terminate the LGIA. According to MidAmerican, the unexpected retirement of the Generating Facility may result in reduced system reliability due to decreased generation resources, and a Transmission Provider may need to construct or upgrade its own generating or transmission facilities if this occurs. MidAmerican notes that three years is the time customarily required to construct such facilities. Therefore, a three year termination provision would provide a Transmission Provider the opportunity to maintain reliability if the Generating Facility shuts down unexpectedly.

Commission Conclusion

307. We are not persuaded to increase the advance notice and termination period to three years as proposed by MidAmerican. MidAmerican's concern appears to be that the Generating Facility, due to several years of load growth and other changes, may be essential to system reliability. Utilities should not allow themselves to become critically dependent on one generator; however, if they do, they can enter into a "reliability must-run" contract before the Interconnection Customer exercises its right to terminate. While there may be a problem if many Interconnection Customers were to cancel concurrently, we do not believe that the LGIA is the best vehicle for addressing this problem, or that every Interconnection Customer in every circumstance should be constrained by a three year termination provision whether or not such a general problem exists.

308. However, we extend the notice period to 90 Calendar Days in order to conform with the Commission's Regulations, which provide that the Transmission Provider is

⁶⁶See Part II.B.2 Article 5.14.1 (Interconnection Customer Payments Not Taxable).

required to notify the Commission of the proposed cancellation or termination of a contract at least 60 Calendar Days, but no more than 180 Calendar Days, before the cancellation or termination is proposed to take effect.⁶⁷

309. **Article 2.3.2 – No Commercial Operation** – Proposed LGIA Article 2.3.2 would have provided that the Transmission Provider be allowed to terminate the LGIA if the Interconnection Customer has not met its obligation to achieve commercial operation of its Generating Facility within five years of the scheduled Commercial Operation Date or fails to be available for operation for a period of five years unless a major Generating Facility upgrade is in progress.

Comments

310. Mirant favors deleting this provision. It asserts that there is no valid reason for a Transmission Provider to terminate the LGIA if the Interconnection Customer has paid for the necessary system upgrades and has met every other obligation under the LGIA. Others point out that PJM's interconnection agreement does not include such a provision. Mirant argues that the Transmission Provider should be able to terminate the LGIA only if the Interconnection Customer defaults under the terms and conditions of the LGIA. PSNM and Dairyland Power also favor deleting this provision altogether and claim that, at best, it should be left to the Parties to negotiate a reasonable period for not achieving commercial operation without risking termination of the LGIA.

311. Most Transmission Providers, on the other hand, object to the five year window for achieving commercial operation as being too long, claiming that one to three years is a more reasonable period of time.⁶⁸ They point out that the Interconnection Customer determines the Generating Facility's Commercial Operation Date without any input from the Transmission Provider and that the Interconnection Customer should not have an additional five years to achieve commercial operation.

312. Central Vermont PSC also advocates shortening the period from five to two years, and expresses concern that proposed LGIA Article 2.3.2, read with proposed Article 4.1.2, might require a Transmission Provider to reserve transmission capacity on its transmission system for an Interconnection Customer taking Network Resource Interconnection Service for up to five years if the Interconnection Customer fails to meet its scheduled Commercial Operation Date or fails to be operable for a consecutive five-year period.

Commission Conclusion

313. We agree with Mirant that the Transmission Provider should not be allowed to terminate the LGIA if the Interconnection Customer has paid all costs for which it is

⁶⁷18 CFR 35.15 (2003).

⁶⁸E.g., Central Vermont PSC, Cinergy, El Paso, Exelon, MidAmerican, and PG&E.

responsible and has met all of its other obligations under the LGIA. The Commission is removing this provision from the Final Rule LGIA because it contains other provisions for termination, such as failure to meet milestones and other obligations. Furthermore, we note that an Interconnection Customer cannot begin to receive credits for Network Upgrades until its Generating Facility has achieved commercial operation, thereby providing an incentive to the Interconnection Customer to perform.

314. **Article 2.4 – Termination Costs** – Proposed LGIA Article 2.4 would have required a Party terminating the interconnection agreement to pay for all costs incurred by the other Party (including costs of cancellation orders or contracts for Interconnection Facilities and equipment).

Comments

315. Mirant argues that an Interconnection Customer should be held responsible only for the Network Upgrades that it has agreed to pay for. It and others are concerned that a higher-queued Interconnection Customer responsible for numerous Network Upgrades might terminate its LGIA and leave lower-queued Interconnection Customers to pay for the Network Upgrades that would otherwise have been assigned to the higher-queued Interconnection Customer. Dominion Resources argues that if a higher-queued Interconnection Customer suspends or terminates construction of its Generating Facility, the lower-queued Interconnection Customers must be made responsible for the costs of the Network Upgrades.

316. Some Transmission Providers argue that this provision does not make the Interconnection Customer responsible for all costs associated with the termination of an interconnection agreement. For example, Southern says that proposed LGIA Article 2.4.1 covers only that portion of the Transmission Provider's Interconnection Facilities not yet constructed or installed, and should be modified to include all Network Upgrades for which the Transmission Provider has incurred expenses. BPA argues that proposed LGIA Article 2.4.1 should be clear about which Party is responsible for the termination costs and allocate costs accordingly. Central Maine believes that the Transmission Provider and its other customers should not incur any costs associated with the termination of the LGIA, regardless of who is responsible for the termination. The Midwest ISO also states that the termination provision must ensure that the Transmission Provider is made whole for the costs it incurs.

Commission Conclusion

317. As for the obligations of the lower-queued Interconnection Customer with respect to the Network Upgrades that would have been paid for by the terminating Interconnection Customer, this issue is addressed in our discussion of Article 5.13 (Suspension).

318. We clarify that if an Interconnection Customer terminates the LGIA, it will be held responsible for all costs associated with that Interconnection Customer's interconnection, including any cancellation costs relating to orders or contracts for

Interconnection Facilities and equipment, and any Network Upgrades for which the Transmission Provider has incurred expenses and has not been reimbursed by the Interconnection Customer. This clarification should resolve the Midwest ISO's and Mirant's concerns while ensuring that the Transmission Provider is made whole for the costs it incurs.

319. **Article 2.5 – Disconnection** – Proposed LGIA Article 2.5 would have provided that the cost of disconnecting the Generating Facility from the Transmission Provider's Transmission System be borne by the terminating Party unless the disconnection is the result of Default by the other Party.

Comments

320. A number of commenters express concern that this article suggests that the Transmission Provider may somehow be responsible for certain disconnection costs. For example, PacifiCorp emphasizes that the Transmission Provider must be able to disconnect (and not reconnect) a Generating Facility if the Interconnection Customer materially Breaches its obligations to maintain electrical standards or operational requirements, or in the event of Default by the Interconnection Customer. In such a situation, PacifiCorp argues, the Transmission Provider should not be required to bear the costs of disconnecting the Generating Facility. Southern and Dairyland Power ask that this article be revised to make the Interconnection Customer responsible for all costs of disconnection under all circumstances.

Commission Conclusion

321. We agree with PacifiCorp that the Transmission Provider must be able to disconnect the Generating Facility from the Transmission System to protect its system if the Interconnection Customer fails to maintain electrical standards and operational requirements. Accordingly, the Final Rule clarifies that all disconnection costs are borne by the terminating Party, unless the termination results from the non-terminating Party's Default of the LGIA.

322. **Article 2.7 – Reservation of Rights** – Proposed Article 2.7 would have reserved to each Party their rights to unilaterally seek modification to the executed LGIA pursuant to Sections 205 and 206 of the FPA, except as restricted by the other provisions of the executed LGIA.

Comments

323. Dynegy and Mirant note that this clause is redundant because another Reservation of Rights provision appears in proposed Article 30.11.

Commission Conclusion

324. We agree that this Article 2.7 is redundant, and we delete it from the Final Rule LGIA.

325. **Article 3 – Regulatory Filings** – Proposed LGIA Article 3 would have provided that the Transmission Provider is responsible for filing the LGIA with the appropriate state and federal regulatory authorities (collectively "Governmental Authorities") having jurisdiction over the Parties. Article 3 also describes how Confidential Information should be treated. It also prohibits an Interconnection Customer from protesting the filing of an LGIA or an amendment to an LGIA that the Interconnection Customer has executed.

Comments

326. MidAmerican recommends that Article 3 be modified to make both Parties responsible for maintaining the confidentiality of information provided by the other Party. The DG Alliance states that an Interconnection Customer has the right to file unilaterally an unexecuted LGIA if the Transmission Provider declines to negotiate in good faith.

Commission Conclusion

327. MidAmerican's concerns are addressed in Article 22 of the Final Rule LGIA, which deals with the rights and responsibilities of each Party with respect to treatment of Confidential Information. The DG Alliance's comments are addressed in Section 10.3 of the Final Rule LGIP, which contains the procedure for filing an unexecuted agreement.

328. Regarding the prohibition against the Interconnection Customer protesting an executed and filed LGIA or amendment, the Commission concludes that this is contrary to the reservation of rights provision of the LGIA, which allows the parties to retain their respective rights to unilaterally amend their executed LGIA under Sections 205 and 206 of the FPA. Because this prohibition effectively negates the Interconnection Customer's Section 206 rights under the LGIA, this clause favors the Transmission Provider at the expense of the Interconnection Customer with respect to rights that, if present, should be mutual. Accordingly, we delete this prohibition from the Final Rule LGIA.

329. **Article 4 – Scope of Service** – Proposed LGIA Article 4 identified two types of Interconnection Service from which the Interconnection Customer must choose: Energy Resource Interconnection Service, which is a basic or minimal service, and Network Resource Interconnection Service, which is a more flexible and comprehensive service. Because this topic generated so much controversy, and because the two services are addressed both in the NOPR LGIA and NOPR LGIP, discussion of proposed LGIA Articles 4.1 through 4.1.2.2 is included in Part II.C.2 (Interconnection Products and Scope of Service).

330. **Article 4.3.1 – Generator Balancing Service Arrangements** – Proposed LGIA Article 4.3.1 described certain requirements that the Interconnection Customer would have to satisfy before submitting a schedule for delivery service. In particular, the Interconnection Customer would have to ensure that the Generating Facility's actual output matches its scheduled delivery, on an integrated clock hour basis, including

ramping into and out of its schedule. The Interconnection Customer would have to arrange for the supply of energy when there is a difference between actual and scheduled output.

Comments

331. Some commenters, such as NERC, PacifiCorp and American Wind Energy, argue that the provision of energy imbalance service is not related to interconnection and should not be addressed in this rulemaking.

332. Cinergy and others object to the use of a clock hour basis to match Generating Facility output to delivery, indicating that a 10-minute interval basis may be more appropriate so that energy injections will be more consistent across the scheduled hour. NERC likewise has concerns about adopting an integrated clock hour specification, and notes that the Generating Facility's scheduling period may be something other than a clock hour, as specified in the Transmission Provider's Commission-approved Tariff or market structure. NERC recommends revising this provision to ensure consistency with the Tariff and market structure.

333. Cinergy argues that any balancing arrangement to be implemented by the Interconnection Customer should be determined to be technically feasible by the Transmission Provider and recommends that ramp time be excluded in the balancing arrangement because it may conflict with NERC scheduling requirements. Arkansas Coops notes that use of the clock hour may be inconsistent with operating procedures developed in RTOs.

Commission Conclusion

334. The Commission concludes that a provision for balancing service arrangements must be included in the Final Rule LGIA because it describes one of the important requirements that the Interconnection Customer must meet before it takes delivery service. Therefore, the Commission retains Article 4.3 in the Final Rule LGIA.

335. However, the Commission agrees with commenters that Article 4.3 of the NOPR LGIA is overly prescriptive. Accordingly, in the Final Rule, the Commission adopts NERC's proposal to revise NOPR LGIA Article 4.3.1 to omit the reference to an integrated clock hour basis, and to add the phrase, "consistent with the scheduling requirements of the Transmission Provider's Commission-approved Tariff and any applicable Commission-approved market structure."

336. **Article 5 – Interconnection Facilities Engineering, Procurement, and Construction** – Proposed LGIA Article 5 described procedures for designing, procuring, and constructing the Transmission Provider's Interconnection Facilities and Network Upgrades and the Interconnection Customer's Interconnection Facilities. Construction options, rights, and responsibilities were also presented. This article would have provided that the Interconnection Customer will not be directly assigned the costs of modifications made to the Transmission Provider's Interconnection Facilities or the

Transmission System to facilitate interconnection of a Generating Facility of another Interconnection Customer or to provide transmission service under the Transmission Provider's Tariff.

337. **Article 5.1 – Options** – Proposed LGIA Article 5.1 specified the method for determining which Party is responsible for the construction of the Transmission Provider's Interconnection Facilities and Network Upgrades. The Interconnection Customer would specify various construction completion dates (such as the In-Service Date, the Initial Synchronization Date, and the Commercial Operation Date), and the Transmission Provider would then choose among three options: (1) Option A would have provided that the Transmission Provider construct the Transmission Provider's Interconnection Facilities and Network Upgrades using Reasonable Efforts to complete construction by the dates designated by the Interconnection Customer, but would not be responsible for any liquidated damages in case it fails to meet the construction completion dates established by the Interconnection Customer; (2) Option B(i)a would have provided that the Transmission Provider construct the Transmission Provider's Interconnection Facilities and Network Upgrades according to the construction completion dates established by the Interconnection Customer, and if it fails to meet those dates, it may be liable for liquidated damages; however, the Transmission Provider can opt out of this provision by notifying the Interconnection Customer of its intention to do so within 30 Calendar Days; and (3) Option B(i)b would have provided that, if the Transmission Provider notifies the Interconnection Customer that it cannot meet the dates established by the Interconnection Customer, the Interconnection Customer could assume responsibility for the construction of the Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades.⁶⁹ This option would also provide that if the Interconnection Customer does not want to assume responsibility for construction, the Parties would negotiate in good faith to revise the construction completion dates and other provisions. Any agreement reached by the Parties during this negotiation shall be binding. However, if the Parties are unable to reach an agreement, the Transmission Provider would assume responsibility for construction of its Interconnection Facilities and Network Upgrades in accordance with Option A. Proposed LGIA Article 5.1 would establish standards for the Interconnection Customer to follow if it assumes responsibility for constructing the Transmission Provider's Interconnection Facilities and system upgrades that are not Stand Alone Network Upgrades. It does not grant any right to the Interconnection Customer to construct upgrades that are not Stand-Alone Network Upgrades.

Comments

⁶⁹ Stand-Alone Network Upgrades are those Network Upgrades that the Interconnection Customer may construct without affecting day-to-day operations of the Transmission System during their construction.

338. Cinergy states that the distinction between Options A and B(i)a is not clear. Monongahela Power recommends that the Commission rename Option B(i)a as Option B and Option B(i)b as Option C.⁷⁰

339. Cinergy and NSTAR seek clarification as to whether the Commission intended that the Interconnection Customer take the responsibility for the construction of upgrades that are not Stand-Alone Network Upgrades.

340. Several commenters, including Cinergy, NYTO, and SoCal PPA, argue that the Interconnection Customer may choose unrealistic construction completion dates and expose the Transmission Provider to liquidated damages. Cinergy states that if several Interconnection Customers choose their construction completion dates close to each other, the Transmission Provider may not be able to meet the dates due to limited construction staff. PacifiCorp recommends that any construction completion date should be treated as an estimate and that any delays on the part of the Interconnection Customer completing its Generating Facility should automatically extend the time for the Transmission Provider to complete its Interconnection Facilities and Network Upgrades.

341. A number of Transmission Providers oppose giving the Interconnection Customer the option to build or have a contractor build the Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades. TXU argues that this could threaten the reliability of the Transmission System. SoCal Edison argues that the Transmission Provider must retain adequate control of the engineering and construction of any Transmission Provider Interconnection Facilities and Stand Alone Network Upgrades because of its obligation to protect the safety of the public and maintain the reliability of the Transmission System. Cinergy and NYTO assert that if the Commission does not eliminate the Interconnection Customer's option to build, the Final Rule must provide that an Interconnection Customer exercising this right shall indemnify or hold harmless the Transmission Provider from any resulting liability.

342. Southern states that to ensure that construction of the Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades does not impair the reliability or safety of the Transmission System: (1) the Transmission Provider should be allowed to approve the Interconnection Customer's contractors and engineers, as well as the vendors from which equipment and materials are purchased; (2) the Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades should be constructed, and equipment and materials purchased, pursuant to contracts that are reasonably acceptable to the Transmission Provider, including acceptable equipment warranty provisions; (3) the Transmission Provider should retain some level of supervision over the construction, with unrestricted access to construction sites to perform inspections; (4) the Interconnection Customer should provide a construction schedule to the Transmission Provider before construction begins; (5) the Interconnection Customer should be required to respond promptly to all requests for information from the Transmission Provider; and (6) the Transmission Provider should

⁷⁰A typographical error in the NOPR added to the lack of clarity.

be able to require the Interconnection Customer or its contractors to remedy any situation that does not meet the Transmission Provider's specifications or standards.

343. Similarly, the Construction Issues Coalition argues that the Interconnection Customers' right to build the Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades should be under specific conditions, such as: (1) the Transmission Provider must provide approval and oversight during design and construction; (2) the Transmission Provider must approve contractors in advance; (3) adequate time should be provided to the Transmission Provider for approval of engineering and construction activities; and (4) all equipment and construction must carry warranties to avoid risk exposure to the Transmission Provider. SoCal Edison argues that costs associated with the Transmission Provider's oversight of the construction should be borne by the Interconnection Customer.

344. NERC argues that if the Interconnection Customer assumes responsibility for construction, it should comply with Good Utility Practice and the Transmission Provider's safety and reliability criteria.

345. NYTO claims that several essential elements of the ERCOT model are absent from the Commission's proposal. It argues, for example, that the Commission should adopt ERCOT's 15 month minimum time period for completing construction after siting permits and land rights have been obtained.

346. American Transmission argues that the Transmission Provider must have the right to step in and assume construction responsibilities to protect the integrity of the system and rights of the third parties in case of serious lapses by an Interconnection Customer.

347. Southern argues that the Final Rule LGIA should require the Interconnection Customer to transfer the Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades to the Transmission Provider for ownership and operation after it completes construction.

348. PJMTO asserts that Final Rule LGIA Article 5.1 should contain more explicit provisions addressing the Transmission Owner's role in: (1) obtaining permits and authorizations, (2) obtaining land rights, (3) performing direct line attachment tie-in work, and (4) calibrating remote terminal unit settings.

349. American Transmission states that proposed LGIP Section 8 (Interconnection Facilities Study) requires the Transmission Provider to develop detailed cost estimates for constructing the Transmission Provider's Interconnection Facilities and Network Upgrades under the assumption that the Transmission Provider will perform all of the construction, yet the Interconnection Customer may assume the responsibility for part of the construction. It asks the Commission to clarify whether there is any relationship between the Transmission Provider's cost estimates and the actual cost of construction performed by the Interconnection Customer. It wants to require approval by the Transmission Provider of the Interconnection Customer's budget for the construction of the Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades.

350. Dynegey asserts that the last sentence of Article 5.1.A(iv), which provides that the Interconnection Customer's selection of subcontractors is subject to the Transmission Provider's standards and specifications, is overly broad and conflicts with proposed LGIA Article 26.1 (Subcontractors – General), which states that "nothing in this Agreement shall prevent a Party from utilizing the services of any subcontractor as it deems appropriate to perform its obligations under this Agreement."

Commission Conclusion

351. The Commission is revising Proposed LGIA Article 5.1 to distinguish the various options more clearly. NOPR Option A is now renamed Standard Option. Under the Standard Option, the Transmission Provider shall construct the Transmission Provider's Interconnection Facilities and Network Upgrades using Reasonable Efforts to complete the construction by the dates designated by the Interconnection Customer, but shall not be responsible for any liquidated damages if it fails to complete the construction by the designated dates. The Standard Option also serves as the default in the event the Parties are unable to reach an agreement under the Negotiated Option

352. Option B(i)a is renamed Alternate Option. Under the Alternate Option, the Transmission Provider shall construct the Transmission Provider's Interconnection Facilities and Network Upgrades according to the construction completion dates established by the Interconnection Customer, and if it fails to meet those dates, it may be liable for liquidated damages; however, the Transmission Provider can decline to use this option by notifying the Interconnection Customer of its intention to do so within 30 Calendar Days of executing the LGIA.

353. The last option – Option B(i)b in the NOPR– gives the Interconnection Customer two choices in the Final Rule LGIA: the Option to Build and the Negotiated Option. This is because the proposed Option B(i)b actually presented two options. Under the Option to Build, the Interconnection Customer may assume responsibility for the construction of the Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades if the Transmission Provider notifies the Interconnection Customer that it cannot meet the dates established by Interconnection Customer. However, as clarified in Final Rule LGIA Article 5.1.3, it does not grant any right to the Interconnection Customer to construct upgrades that are not Stand-Alone Network Upgrades. Furthermore, both the Transmission Provider and the Interconnection Customer must agree on which facilities are the Stand Alone Network Upgrades and identify them in Appendix A to the LGIA.

354. The Negotiated Option provides that, if the Transmission Provider notifies the Interconnection Customer that it cannot meet the dates established by Interconnection Customer, and the Interconnection Customer does not want to assume responsibility for construction, the Interconnection Customer may decide that the Parties shall negotiate in good faith to revise the construction completion dates and other provisions under which the Transmission Provider is responsible for the construction. If the Parties are unable to reach an agreement, the Transmission Provider shall assume responsibility for

construction of the Transmission Provider's Interconnection Facilities and Network Upgrades in accordance with the Standard Option.

355. Regarding Cinergy, NYTO, and SoCal PPA's concerns about the selection of unrealistic construction completion dates by an Interconnection Customer, the Final Rule Alternate Option allows the Transmission Provider to avoid unrealistic construction completion dates by notifying the Interconnection Customer that it is unable to meet the established dates. We agree with PacifiCorp that any delay on the part of the Interconnection Customer in meeting its construction completion dates should grant an automatic extension to the Transmission Provider. We note that Final Rule LGIA Article 5.3 (Liquidated Damages) provides that no liquidated damages shall be paid to the Interconnection Customer if the Interconnection Customer is not ready to commence use of the Transmission Provider's Interconnection Facilities and Network Upgrades on the specified construction dates except if such delay is due to the Transmission Provider's delay.⁷¹

356. With regard to the concern that giving the Interconnection Customer the right to construct the Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades could threaten the safety and reliability of the Transmission System, Final Rule LGIA Article 5.2 (General Conditions Applicable to Options to Build) has several safeguards. For example, the Interconnection Customer is required to use Good Utility Practice and the standards and specifications provided in advance by the Transmission Provider. In addition, the Transmission Provider has the right to approve the engineering design, the equipment acceptance tests, and the construction of the Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades.

357. In response to those comments seeking an indemnification or hold harmless provision to protect the Transmission Provider from liability arising out of the Interconnection Customer's exercising its right to build, the Commission adds an indemnification clause to Final Rule LGIA Article 5.2 (General Conditions Applicable to Options to Build).

358. With respect to various modifications that Southern and the Construction Issues Coalition seek, Final Rule LGIA Article 5.2 (General Conditions Applicable to Options to Build) adds several provisions proposed by these commenters, such as a requirement that the Interconnection Customer (1) provide a construction schedule in advance of the start of construction, (2) remedy deficiencies brought to its attention by the Transmission Provider, and (3) carry warranties for equipment similar to those carried by the Transmission Provider. However, the Commission declines to grant fully the high level of Transmission Provider control that Southern and the Construction Issues Coalition seek, such as approval of subcontractors and vendors. Such control would be overly broad, and the Transmission Provider's ability to seek remedy of any deficiencies should enable it to carry out its responsibilities. The Commission also will deny SoCal Edison's

⁷¹Other comments on this issue are addressed in Part II.C.8.b (Liquidated Damages).

request that the Interconnection Customer bear the Transmission Provider's costs associated with the oversight of construction performed by the Interconnection Customer because such costs are de minimus.

359. With respect to NERC's comment that an Interconnection Customer should follow Good Utility Practice and the safety and reliability criteria of the Transmission Provider, such standards are in Final Rule LGIA Article 5.2 (General Conditions Applicable to Option to Build).

360. Regarding NYTO's argument that a minimum of 15 months is needed to complete construction of the Transmission Provider Interconnection Facilities and Network Upgrades, we conclude that specifying such a minimum period is unnecessary because under the Alternate Option, the Transmission Provider will be protected from incurring liquidated damages liability due to delays beyond its reasonable control or reasonable ability to cure.

361. The Commission rejects American Transmission's proposal that the Transmission Provider have a right to step in and assume construction responsibilities in case of lapses by an Interconnection Customer. Since Article 5.1 permits the construction of only Transmission Provider Interconnection Facilities and Stand Alone Network Upgrades, the Commission believes that any such lapses would affect only the Interconnection Customer. If it has the potential to affect anyone other than the Interconnection Customer, the Commission will address such concerns when brought to its attention.

362. The Final Rule does not require that the Interconnection Customer transfer ownership of the Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades to the Transmission Provider after the Interconnection Customer completes them; however, the Commission will require transfer of control of such facilities. Reliability does not require ownership, but it does require control by the Transmission Provider.⁷²

363. With respect to PJMTO's request for provisions regarding the Transmission Owner's role in obtaining permits and land rights, Final Rule LGIA Articles 5.12 (Access Rights) and 5.13 (Lands of Other Property Owners) do not distinguish between the role of the Transmission Provider and the Transmission Owner in assisting the Interconnection Customer in obtaining land rights and permits. The Final Rule LGIA is not the appropriate place to set forth the nature of the relationship between the Transmission Owner and Transmission Provider. In addition, the Commission is stating in this Final Rule that it will give an independent transmission provider such as an RTO or ISO the flexibility to propose different rules in its compliance filing.

⁷²See Arizona Public Service Company, 102 FERC ¶ 61,303 (2003). We also note that the ownership of Stand Alone Network Upgrades by an Interconnection Customer is discussed further under "Rules Governing the Payment of Credits" in Part C.1 of this Preamble.

364. The Commission denies American Transmission's request to include a provision in the Final Rule LGIA for the Transmission Provider to review and approve the Interconnection Customer's budget if an Interconnection Customer assumes the responsibility to construct the Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades. The Interconnection Customer is likely to act in its best interests to keep the costs down because it initially funds the construction costs. In addition, allowing a Transmission Provider unfettered discretion to review the budget would encourage anticompetitive behavior.

365. With regard to Dynegy's concern regarding subcontractors, Article 26.1 provides that nothing in the LGIA prevents a Party from using the services of any subcontractor to perform its obligations under the LGIA and that it is up to the Party to ensure that the subcontractor complies with the LGIA. In addition, the hiring Party remains primarily liable to the other Party for the performance of the subcontractor. Thus, if the subcontractor fails to meet the Interconnection Customer's obligations under the LGIA or to the Transmission Provider, the Interconnection Customer is obligated to remedy any deficiencies. Accordingly, the Commission is removing the words "including selection of subcontractors" from Article 5.1 to ensure consistency between that article and Article 26.1.

366. **Article 5.2 – Power System Stabilizers** (In the Final Rule LGIA: Article 5.4) – Proposed LGIA Article 5.2 would have required the Interconnection Customer to install, operate and maintain power system stabilizers, if required by the Interconnection System Impact Study. The Transmission Provider would establish minimal acceptable settings subject to the design and operating limitations of the Generating Facility.

Comments

367. Several commenters, including Cal ISO, Dairyland Power, Dominion Resources, and NSTAR, argue that the Transmission Provider's ability to require the installation of a power system stabilizer should not be limited to when required by the Interconnection System Impact Study because the Generating Facility may become a source of power system oscillations on the Transmission System many years after operations commence. Dominion Resources contends that a Transmission Provider should be able to require an Interconnection Customer to install a power system stabilizer any time it determines through its operating experience that a power system stabilizer is needed.

368. Cal ISO argues that the requirement to install a power system stabilizer should not be based on the "Interconnection System Impact Study," but should be based on the "guidelines and procedures of the Applicable Reliability Council." NERC points out that the Transmission System reliability criteria and use of power system stabilizers vary from one region to another, depending on the electrical characteristics of the system. NERC states that, as a result, it is important that the system operator be notified if a power system stabilizer is inoperable or removed from service.

Commission Conclusion

369. The Commission agrees with Cal ISO that an Interconnection Customer should be required to install a power system stabilizer in accordance with the standards of the Applicable Reliability Council. This also addresses Dominion Resources' concern that installation of a power system stabilizer on a Generating Facility may be needed at a later time; such a requirement should be covered in the guidelines of the Applicable Reliability Council. If the Applicable Reliability Council guidelines do not cover such matters, a Transmission Provider may justify its reasons for wishing to require a power system stabilizer despite the lack of such a requirement in the Applicable Reliability Council guidelines when it makes its compliance filing.

370. The Commission will adopt NERC's recommended language requiring notification when power system stabilizers are removed or are not available for automatic operation.

371. This article is designated Article 5.4 in the Final Rule LGIA.

372. **Article 5.8.1 – Generator Specifications** (In the Final Rule LGIA: Article 5.10.1) – Proposed LGIA Article 5.8.1 would have required that the Interconnection Customer submit the final specifications for the Interconnection Customer's Interconnection Facilities, including System Protection Facilities, to the Transmission Provider for review at least 90 Calendar Days prior to the Initial Synchronization Date. It proposed to require the Transmission Provider to provide comments to the Interconnection Customer within 30 Calendar Days of the Interconnection Customer's submission.

Comments

373. Cleco and NYTO assert that the Interconnection Customer should have to submit initial specifications for the Interconnection Customer's Interconnection Facilities to the Transmission Provider at least 180 Calendar Days prior to the Initial Synchronization Date with the understanding that the initial specifications are subject to change. Such initial specifications would give them an opportunity to perform the planning required for the new facilities and upgrade.

Commission Conclusion

374. The Commission agrees with Cleco and NYTO and adopts their proposal in the Final Rule.

375. This article is designated Article 5.10.1 in the Final Rule LGIA.

376. **Article 5.8.2 – Transmission Provider's Review** (In the Final Rule LGIA: Article 5.10.2) – Proposed LGIA Article 5.8.2 would have required that the Interconnection Customer to modify the Interconnection Customer's Interconnection Facilities as may be reasonably required by the Transmission Provider to ensure that they are compatible with the telemetry communications and safety requirements of the Transmission Provider.

Comments

377. NERC requests that the word "reasonably" be removed from the article and recommends referring to Good Utility Practice.

Commission Conclusion

378. The Final Rule revises this article to refer to Good Utility Practice, as requested by NERC, but it does not eliminate the term "reasonably." The Interconnection Customer's Interconnection Facilities are installed at the expense of the Interconnection Customer, but must be reviewed and meet the specifications and requirements established by the Transmission Provider. The term "reasonably" helps to ensure that the Transmission Provider does not require the installation of equipment beyond what is necessary for compatibility and reliability, or beyond the standards the Transmission Provider would apply to its own Interconnection Facilities.

379. This article is designated Article 5.10.2 in the Final Rule LGIA.

380. **Article 5.8.3 – Interconnection Customer Interconnection Facilities Construction** (In the Final Rule LGIA: Article 5.10.3) – Proposed LGIA Article 5.8.3 would have required the Interconnection Customer to provide to the Transmission Provider certain "as built" drawings, information, and documents pertaining to the construction of the Interconnection Customer's Interconnection Facilities.

Comments

381. NERC proposes that the Interconnection Customer also provide the Transmission Provider specifications for the excitation system, automatic voltage regulator, generator control and protection settings, transformer tap settings, and communications.

Commission Conclusion

382. The Commission adopts NERC's proposal and revises Proposed LGIA Article 5.8.3 to make clear that the list of information to be provided is not exhaustive.

383. This article is designated Article 5.10.3 in the Final Rule LGIA.

384. **Article 5.11 – Lands of Other Property Owners** (In the Final Rule LGIA: Article 5.13) – Article 5.11 proposed that Transmission Providers would be required to use Reasonable Efforts, including use of its eminent domain authority if necessary, to facilitate the interconnection of Generating Facilities. The Interconnection Customer would be required to pay any expenses related to obtaining rights of use, rights of way, easements, or eminent domain costs that the Transmission Provider might incur, up to the fair market value of the land or "such other price as required by the applicable inter-affiliate transaction requirements."

Comments

385. EPSA and several Interconnection Customers, including Calpine, El Paso, and Reliant Energy, request that the Transmission Provider or Transmission Owner be required to use its eminent domain authority to facilitate the exercise of the Parties' rights and obligations under the LGIA to the extent it is permitted to do so. Numerous Transmission Provider commenters express concern that the eminent domain provisions of the NOPR are too broad, placing the Transmission Provider in an untenable situation. Specifically, several argue that the Commission's proposal conflicts with state limitations on their eminent domain authority.⁷³ Cleco, for example, states that in Louisiana, a utility cannot legally request eminent domain on behalf of another entity. National Grid and the Construction Issues Coalition argue that many states require that eminent domain authority be used only "to further a public need" – something that is lacking in the NOPR. Cinergy proposes deleting the entire eminent domain provision, arguing that it imposes an inappropriate burden on the Transmission Provider and reiterates that it conflicts with existing state laws. Similarly, El Paso requests that the use of eminent domain be at the sole discretion of the Transmission Provider or Transmission Owner, citing the numerous factors that must be considered in such an undertaking.

386. Duke Energy proposes that the Commission require a Transmission Provider to use eminent domain only when it reasonably determines that (1) other alternatives are not available and (2) use of eminent domain is permissible under state law. Duke Energy also asserts that the Transmission Provider should provide a written explanation of why other alternatives are appropriate or why the use of eminent domain would not be permitted under state law.

387. National Grid argues that the Commission should eliminate the eminent domain provision, citing the long delays and heavy litigation that often accompany the seizure of property. National Grid, the Construction Issues Coalition, and others argue that regulation of eminent domain differs from state to state, making the type of national contract clause envisaged by the Commission impossible.

388. PJMTO also opposes the eminent domain provision, arguing that eminent domain is an unpopular last resort and one that is rarely exercised even by a Transmission Provider or Transmission Owner on its own behalf. Instead, it proposes requiring that a Transmission Provider or Transmission Owner, upon receipt of a reasonable request, to assist an Interconnection Customer in acquiring land rights using efforts similar to those it typically undertakes on its own behalf.

389. PJMTO also argues for eliminating the cap on land value, noting that individual state laws already contain mechanisms for valuing property. The Commission may lack authority to require a price cap on property sold by an Affiliate of a Transmission Provider, according to National Grid and the Construction Issues Coalition.

390. Salt River Project also opposes the eminent domain language and instead proposes that the Commission work with federal land holding agencies to streamline the

⁷³E.g., Cinergy, Cleco, the Construction Issues Coalition, Duke Energy, National Grid, PJMTO, Salt River Project, SoCal Edison, and Southern.

procurement of land rights. SoCal Edison adds that it does not believe the Commission has the authority to impose an eminent domain requirement. Instead, it proposes requiring Transmission Providers to exercise good faith efforts in using whatever eminent domain authority state law may allow on an Interconnection Customer's behalf.

Commission Conclusion

391. We agree that a mandatory eminent domain requirement can be difficult for a Transmission Provider or Transmission Owner. The Final Rule requires that a Transmission Provider or Transmission Owner use efforts similar to those it typically undertakes on its own behalf (or on behalf of an Affiliate) to secure land rights for the Interconnection Customer. We are also clarifying that the Transmission Provider or Transmission Owner's efforts must also comply with state law.

392. If the Transmission Provider is an independent entity, the Transmission Owner, the Transmission Provider, and the Interconnection Customer may all sign the LGIA. This allows a Transmission Owner and a Transmission Provider to jointly undertake efforts to secure land rights for the Interconnection Customer.

393. Regarding the cap on land value, while the Commission remains concerned that Affiliates of a Transmission Provider or Transmission Owner might request above-market compensation for land necessary to facilitate the interconnection, the Commission also recognizes that the valuation of property is a matter of state law. Therefore, we eliminate this cap in the Final Rule.

394. This article is designated Article 5.13 in the Final Rule LGIA.

395. **Article 5.12 – Early Construction of Base Case Facilities** – Proposed LGIA Article 5.12 would have required that, at the Interconnection Customer's request, the Transmission Provider must construct, using Reasonable Efforts to accommodate the Interconnection Customer's In-Service Date, all or any portion of Network Upgrades reflected in the Base Case of the Interconnection Customer's Facilities Study that are necessary to accommodate the Interconnection Customer's In-Service Date. Construction of the Network Facilities would be required even if the Network Facilities are shared with other interconnecting generators that would not be completed in time to meet the Generating Facility's In-Service Date.

Comments

396. MidAmerican contends that this article is inconsistent with Section 12.3 of the NOPR LGIP (Construction Sequencing), which requires that the Transmission Provider use Reasonable Efforts to accommodate the Generating Facility's In-Service Date. Accordingly, it proposes that Article 5.12 be revised.

397. Cleco argues that the Party requesting early construction should pay all Network Upgrade costs associated with the early construction. FP&L argues that to avoid the need to continuously restudy and revise Network Upgrades, the LGIA should require the

timely construction of Network Upgrades relied upon by lower-queued Interconnection Customers.

398. Entergy, Dairyland Power, and others state that the Final Rule should address which Interconnection Customer finances Network Upgrades in the event of a delay by the higher-queued Interconnection Customer to whom the Network Upgrades are assigned. Cal ISO states that language regarding milestones should be inserted between proposed LGIA Articles 5.12 and Article 5.13.

Commission Conclusion

399. In response to the concerns of Entergy and others, the Commission notes that a lower-queued Interconnection Customer always has the right under this article to accelerate its construction schedule by completing all required Network Upgrades on schedule despite any delays by higher-queued Interconnection Customers. This would require the lower-queued Interconnection Customer to fund those Network Upgrades at least initially; however, in the absence of participant funding, it would be reimbursed over time through credits, with interest. Article 5.12 does not need to be changed to allow this.

400. Regarding "best" versus "reasonable" efforts, the Commission agrees with MidAmerican that there was an inconsistency between proposed LGIA Article 5.12 and proposed LGIP Section 12.3, which requires the Transmission Provider to use Reasonable Efforts to accommodate the Interconnection Customer's requested In-Service Date. Article 5.12 is the more stringent of the two because it requires the Transmission Provider to construct facilities necessary to accommodate the Interconnection Customer's In-Service Date. The Commission's intent is to expedite the interconnection of new generators in a manner that does not undermine the reliability of a Transmission Provider's Transmission System. However, there may be circumstances beyond the Transmission Provider's control that would prevent it from meeting the construction deadline. To address this concern and to ensure consistency between this article and LGIP Section 12.3, the Commission agrees with MidAmerican's comment that the term "Reasonable Efforts" is appropriate. This article, which is designated Article 5.15 in the Final Rule LGIA, uses that term.

401. An additional article regarding milestones is not needed. By the time the LGIA is executed, the Parties will have already established under Article 5.1 the milestones Cal ISO refers to.

402. **Article 5.13 – Suspension** (In the Final Rule LGIA: Article 5.16) – Proposed LGIA Article 5.13 would allow the Interconnection Customer, upon written notice to the Transmission Provider, to suspend work on Interconnection Facilities or Network Upgrades as long as the Interconnection Customer agrees to be responsible for all reasonable and necessary costs incurred by the Transmission Provider in suspending work. This article proposed that the LGIA be deemed terminated if the Interconnection Customer has not requested the Transmission Provider to recommence work within three years from the date of the suspension request.

Comments

403. Peabody supports allowing an Interconnection Customer to suspend work on the interconnection for up to three years because this offers the Interconnection Customer the flexibility that large-scale generation projects need to accommodate permitting and other delays. Other commenters, including BPA, Cinergy, and SoCal PPA, argue that a three year suspension period is unreasonably long. SoCal PPA further states that substantial changes to the Transmission System could occur during that time. Western believes that letting an Interconnection Customer contract with a Transmission Provider for an interconnection and then suspend operation for as long as three years could allow the Interconnection Customer to game the system. Consequently, Western and other commenters argue that the suspension period should be limited to six months, while Cinergy recommends limiting the suspension period to one year. NYTO believes the entire provision is unreasonable.

404. Cinergy requests that Article 5.13 make it clear that if an Interconnection Customer gives a Transmission Provider written notice of suspension of work, the Transmission Provider does not have to obtain written permission from the Interconnection Customer to cancel or suspend material, equipment and labor contracts associated with that work, and that the Commission clarify what is included in the definition of "suspension of work." Further, to prevent gaming the process, Cinergy proposes that an Interconnection Customer be allowed to provide written notice of suspension of work only once per Generating Facility.

405. Dominion Resources questions whether the responsibility for funding the cost of Network Upgrades would fall on the Interconnection Customer suspending or terminating construction or on other Interconnection Customers remaining in the queue. The Interconnection Customer actually using the Network Upgrades should be required to pay for them. Dominion Resources recognizes that this may shift costs from the Interconnection Customer requesting the suspension to Interconnection Customers further down the queue, which could mean that an Interconnection Customer will be subject to potential cost increases even after signing an LGIA. However, it views this as a more acceptable allocation of cost responsibility than requiring an Interconnection Customer that desires to suspend or terminate its project to bear the full cost of Network Upgrades it may never use. In order to avoid gaming of the interconnection queue, if the suspending Interconnection Customer later continues with its project, it should be required to reimburse any lower-queued Interconnection Customers for any Network Upgrade costs related to its suspension.

406. NERC and MidAmerican comment that there must be a requirement to leave the system in a safe and reliable condition, consistent with Good Utility Practice, if a project is suspended in a partially complete state.

407. The Midwest ISO requests that Article 5.13 make it clear that a suspending Interconnection Customer must provide notice to the Transmission Owner and to any independent Transmission Provider.

408. The Midwest ISO and Georgia Transmission request clarification that the Transmission Provider will be reimbursed for any expenses related to the suspension.

Commission Conclusion

409. Many commenters express concern over the effect that a suspending Interconnection Customer might have on lower-queued Interconnection Customers. We agree with Dominion Resources that, in some cases, a subsequent (*i.e.*, lower queued) Interconnection Customer may be responsible for funding the costs of completing the Network Upgrades constructed for a higher-queued Interconnection Customer that suspends or terminates construction of such Network Upgrades. However, the Commission is not obligating in this Final Rule a subsequent (*i.e.*, lower queued) Interconnection Customer to pay for these costs regardless of whether that Interconnection Customer benefits from the facilities, since this would subject that Interconnection Customer to significant financial risk. Prices quoted for interconnection in the LGIA are estimates based on the results of studies conducted during the LGIP phase of the interconnection process. If it is apparent to the Parties at the time they execute the LGIA that contingencies (such as other Interconnection Customers terminating their LGIAs) might affect the financial arrangements, the Parties should include such contingencies in their LGIA and address the effect of such contingencies on their financial obligations. If no such contingencies are accounted for in the executed LGIA, since the costs of Network Upgrades may influence an Interconnection Customer's decision whether it can enter into an Interconnection Agreement, we leave it to the subsequent Interconnection Customer and the Transmission Provider to revisit the negotiated terms of their executed Interconnection Agreement. We deny the requests to revise or delete Proposed LGIA Article 5.13 on these grounds.⁷⁴

410. We also retain the three year period. The Commission agrees with Peabody that allowing the Interconnection Customer to have the Transmission Provider suspend work for up to three years allows generation projects the flexibility necessary to accommodate permitting and other delays that are particularly likely to affect large projects.

411. The Final Rule requires the Interconnection Customer to pay all reasonable costs that the Transmission Provider incurs in suspending work on its Interconnection Facilities, as well as costs that are reasonable and necessary to ensure the safety and integrity of the Transmission Provider's Transmission System during the suspension.

412. We reject Cinergy's proposal that an Interconnection Customer be limited to one suspension period per Generating Facility. The LGIA is designed to be a standard agreement that will operate in any number of situations, and to limit arbitrarily each Generating Facility to only one suspension period, regardless of circumstances, is unreasonable.

⁷⁴An RTO or ISO with participant funding may propose an alternative policy for Commission approval.

413. We adopt NERC's proposal that Article 5.13 require a suspending Interconnection Customer to leave the system in a safe and reliable condition in accordance with Good Utility Practice and the Transmission Provider's safety and reliability criteria.

414. In response to Cinergy's request for clarification of the term "suspension of work," the Commission clarifies that a Transmission Provider, upon receiving written notice of suspension from the Interconnection Customer, is authorized to cancel or suspend material, equipment and labor contracts associated with that work. If reliability could be compromised by stopping construction, the Transmission Provider must continue construction until it reaches a stage where it can safely discontinue work. Any costs associated with suspension (or of completing a discrete Network Upgrade) shall be deducted from the Interconnection Customer's security deposit.

415. With respect to the Midwest ISO's request to require an Interconnection Customer to notify both the Transmission Owner and the Transmission Provider, we clarify that if both Parties are signatories to the LGIA, the Interconnection Customer is required to notify both the Transmission Owner and the Transmission Provider.

416. This article is designated Article 5.16 in the Final Rule LGIA.

417. **Article 5.14– Taxes** – Proposed LGIA Article 5.14 addressed the allocation of responsibilities that would apply with respect to the tax treatment of an Interconnection Customer's payments or property transfers to the Transmission Provider for the installation of the Transmission Provider's Interconnection Facilities and Network Upgrades.

418. Internal Revenue Service policy, as expressed in IRS Notice 2001-82 and IRS Notice 88-129, delineates the standards under which an Interconnection Customer's payments to build interconnections facilities will not create a current tax liability for a Transmission Provider. The "safe harbor" provisions described in these notices generally prevent the transaction from being considered a taxable transfer. If the IRS changes its policy, or if the transaction no longer qualifies for safe harbor protection and tax liability results, under the provisions in Article 5.14 the Interconnection Customer would indemnify the Transmission Provider for any tax liability that may arise from the payments to build the Transmission Provider's Interconnection Facilities and Network Upgrades.

Comments

419. Several entities argue that the IRS safe harbor does not eliminate all risk of these payments being treated as taxable income to the Transmission Provider because the IRS may revisit its policies in a manner that establishes tax liability for interconnections, including the credits provided against transmission service in exchange for the

reimbursement of Network Upgrades.⁷⁵ These commenters argue that Article 5.14 should account for these risks.

420. Some commenters, including Duke, EPSA, NYTO, and PG&E, argue that the Commission should adopt Article 5.16.5 of the Consensus LGIA, which ensures that a Transmission Owner is made whole when a contribution from an Interconnection Customer is non-taxable when made, but the IRS later imposes tax liability. NYTO further suggests that the two revisions to Consensus LGIA Article 5.16.5 that were proposed by the Transmission Owners should be retained. These provisions would ensure that the Transmission Owner would be reimbursed for taxes imposed more than ten years after the date the Interconnections Facilities are placed in service and allow for security for such potential tax liability.

Commission Conclusion

421. The Commission finds that Article 5.14 as proposed appropriately addresses the risk that the contracting Parties face because of the uncertainties regarding IRS policy, because it requires the Interconnection Customer to indemnify the Transmission Provider in the event that the IRS changes or clarifies its policy.

422. The Commission concludes that a discussion of subsequent taxable events is appropriate for the Final Rule LGIA.⁷⁶ The two additions NYTO requests are unnecessary because Final Rule LGIA Article 5.17.3 addresses limitation of indemnification and the ability of the Transmission Provider to require security from the Interconnection Customer.

423. **Article 5.14.1 – Interconnection Customer Payments Not Taxable** (In the Final Rule LGIA: Article 5.17.1) – Proposed LGIA Article 5.14.1 would have provided that, consistent with IRS Notice 2001-82 and IRS Notice 88-129 (discussing the IRS safe harbor provisions), all payments made by the Interconnection Customer to the Transmission Provider for the installation of Transmission Provider's Interconnection Facilities and Network Upgrades are non-taxable, either as contributions to capital, or as advances.

Comments

424. Peabody endorses this proposed provision. It argues that it is in the best interest of Interconnection Customers, Transmission Providers and customers to take advantage of the tax exemption for payments that Interconnection Customers make to Transmission Providers for Network Upgrades made pursuant to an LGIA.

425. Progress Energy argues that an Interconnection Customer's right to terminate the LGIA on 30 Calendar Days' written notice may jeopardize the safe harbor treatment of

⁷⁵E.g., EEI, FP&L, MidAmerican, and TXU.

⁷⁶Subsequent taxable events are discussed in Final Rule LGIA Article 5.17.6. This discussion retains the article numbers that appeared in the NOPR LGIA.

Interconnection Customer contributions because the IRS safe harbor provisions apply only to interconnection agreements with a minimum term of ten years.

Commission Conclusion

426. In response to Progress Energy, the mere existence of the 30 day termination provision does not mean that the Interconnection Agreement conflicts with the IRS minimum term requirement of ten years. Nevertheless, if either Party in fact terminates the LGIA before ten years have passed, the IRS may then conclude that the Interconnection Customer's payments are indeed taxable. Accordingly, the Parties should consider these possible tax consequences when deciding whether to terminate an LGIA within ten years.

427. This article is designated Article 5.17.1 in the Final Rule LGIA.

428. **Article 5.14.2 – Representations and Covenants** (In the Final Rule LGIA: Article 5.17.2) – Proposed LGIA Article 5.14.2 set forth the representations and covenants that would be agreed to by the Parties to conform to the requirements of the IRS safe harbor provisions set forth in the relevant IRS Notices.

Comments

429. FirstEnergy argues that in order for the Interconnection Customer's payments to the Transmission Provider to be deemed non-taxable under the IRS safe harbor provisions, ownership of the electricity generated at the Generating Facility must pass to another entity prior to the transmission of the electricity on the Transmission System. FirstEnergy asks the Commission to clarify the representations and proposed covenants in proposed LGIA Article 5.14.2 to refer to the Point of Interconnection or Point of Change of Ownership.

Commission Conclusion

430. We do not intend to interpret the IRS safe harbor provisions, and so we leave it to the Parties to ensure that their conduct, including the point at which the ownership of electric energy produced by the Generating Facility changes hands, conform to IRS policy.

431. This article is designated Article 5.17.2 in the Final Rule LGIA.

432. **Article 5.14.3 – Indemnification for Taxes Imposed Upon Transmission Provider** – Proposed LGIA Article 5.14.3 would have required that the Interconnection Customer indemnify (hold harmless) the Transmission Provider from income taxes imposed against the Transmission Provider as a result of payments or property transfers made by Interconnection Customer to the Transmission Provider under the LGIA – that is, if the IRS safe harbor provisions do not keep the Transmission Provider from having

to pay income taxes. The Transmission Provider would not include a gross-up⁷⁷ for income taxes unless either it has made a good faith determination that the payment or transfers should be recorded as income subject to taxation, or any Governmental Authority directs Transmission Provider to treat the payment or transfers as subject to taxation. As an alternative to the gross-up, the Transmission Provider would be able to require the Interconnection Customer to provide security in a form reasonably acceptable to the Transmission Provider and in an amount equal to the Interconnection Customer's estimated tax liability.

Comments

433. MidAmerican supports Article 5.14.3 and recommends that the Transmission Owner be added to this provision by changing Transmission Provider to Transmission Provider or Transmission Owner.

434. LADWP argues that although Section 5 of the Commission's OATT provides that the transmission customer must indemnify the Transmission Provider that owns facilities financed by tax-exempt debt, it is not clear whether that provision would apply to an Interconnection Customer. LADWP asks the Commission to clarify that an Interconnection Customer is liable for the cost of any adverse tax consequences visited on the public power Transmission Owner because of the interconnection.

435. SoCal PPA believes that the Interconnection Customer's obligation to reimburse the Transmission Provider for taxes should cover ad valorem property taxes and other taxes assessed against the Transmission Provider.

436. NE Utilities seeks an alternative method for a Transmission Provider to recover tax liability for which it is not reimbursed due to circumstances beyond its control – for example, if the security instrument provided by the Interconnection Customer does not cover the full tax liability or if the Interconnection Customer defaults on its obligation to indemnify the Transmission Provider. It argues that in these situations, the Commission should authorize the Transmission Provider to recover the remaining balance from customers.

437. TXU says that the Commission should provide comprehensive protection for a Transmission Provider if the IRS decides that Interconnection Customer payments are taxable. A letter of credit, as provided for in proposed LGIA Article 5.14.3, would provide some security for the Transmission Provider, but may limit the process of contesting IRS positions and may prove otherwise difficult to administer. Without elaborating, TXU requests that a more comprehensive security device be required until definitive guidance is received from the IRS.

⁷⁷A gross-up for income taxes is a dollar amount calculated to determine the Interconnection Customer's estimated tax liability to the Transmission Owner.

438. SoCal Edison states that if a Transmission Provider or Transmission Owner is unable to recover from a generator any income tax incurred as a result of an interconnection arrangement, the Commission should provide Transmission Providers and Transmission Owners with a regulatory backstop that would guarantee the recovery of these income taxes in transmission rates. It adds that to the extent that a Transmission Provider or Transmission Owner is unable to include income taxes in transmission rates because of other regulatory restrictions (such as a rate freeze or the requirement to have state commission approval for such rates), the Transmission Provider or Transmission Owner should have discretion in determining the appropriate form and level of security required from the generator at the time the IA becomes effective, and a right to offset any tax liability against any transmission credit owed. Further, SoCal Edison says Article 5.14 must state that any future payment shall include interest and penalties, as well as any other costs imposed by the IRS.

439. Progress Energy advocates that Article 5.14.3 include certain requirements regarding the Interconnection Customer-provided financial guaranty, such as requiring that the guaranty be issued by a financial entity acceptable to the Transmission Provider and that it be non-revocable for the term of the LGIA.

440. Dynegy proposes that the Commission make the security obligation mutual. The Final Rule should state that, when the Transmission Provider requires the Interconnection Customer to pay a tax gross-up because the Transmission Provider has determined in good faith that the payments or property transfers made to Transmission Provider should be reported as income subject to taxation, the Transmission Provider must post security for the amount of the gross-up, plus interest. This will protect the Interconnection Customer from becoming an unsecured creditor in the event of a Transmission Provider insolvency before the issuance of a private letter ruling that could result in the refund of the tax gross-up payment and interest to the Interconnection Customer.

441. Calpine argues that the security requirement should bear a reasonable relationship to the risk to which a transmission owner is exposed. Instead of allowing the Transmission Provider to require an Interconnection Customer to meet a costly security requirement – using funds that the Interconnections Customer could put to better use developing generation and infrastructure – the Commission should authorize the Transmission Provider to recover in its rates any future tax liability. If the Commission is unwilling to expose ratepayers to this risk, it should modify the Final Rule to ensure that any residual security that the Interconnection Customer would be obligated to post be reasonably related to the actual risk to which the Transmission Provider is exposed.

442. EPSA argues that an Interconnection Customer should not be required to pay the taxes of a Transmission Owner unless the Interconnection Customer is entitled to a refund if it is ultimately determined that the amounts paid for Interconnection Facilities and Network Upgrades are not subject to tax. If the Transmission Owner in an Affected System is not a Party to the Interconnection Customer's LGIA, the Interconnection Customer will have no means to enforce its right to a refund of any amounts it has previously paid in taxes. A Transmission Owner is able to insist on security indefinitely,

to protect against the remote possibility of a change in circumstances that might become a subsequent taxable event, the balance reflected in the Consensus Tax Provisions would be upset.

Commission Conclusion

443. In response to MidAmerican's request that proposed LGIA Article 5.14.3, which is designated Article 5.17.3 in the Final Rule LGIA, specify that the Transmission Owner as well as the Transmission Provider is indemnified, the term "Transmission Provider" in the LGIA includes the Transmission Owner, where applicable. Accordingly, there is no need to revise this provision.

444. SoCal PPA raises tax issues beyond the scope of Article 5.17, since this article addresses only federal tax liability. The Commission rejects the proposal that ad valorem property taxes be included in the Interconnection Customer's obligation to reimburse the Transmission Provider for taxes, since these expenses are annual and are more analogous to operating expenses that are not covered under the LGIA.

445. The Commission rejects requests that the Transmission Provider may recover any outstanding federal tax liability balance from customers. A Transmission Provider is to use the security option in Article 5.17.3 to protect itself from the risk that an Interconnection Customer will not pay the potential tax liability, so there should not be any outstanding liability. This, along with the ability to require security or, where appropriate, a gross-up, should sufficiently protect the Transmission Provider from potential tax liability. Should the Transmission Provider be unable for some reason to recover the full cost of its tax liability, it may propose to recover such costs in its rates, but the Commission is not pre-authorizing the recovery of these costs generically.

446. In response to SoCal Edison's request for a requirement that future payment include interest and penalties, as well as any other costs imposed by the IRS, this requirement is in Article 5.17.3.

447. The Commission rejects as unnecessary Progress Energy's request for greater specificity regarding the guaranty because Article 5.17.3 already gives the Transmission Provider the discretion to choose the security in a form "reasonably acceptable" to the Transmission Provider. Accordingly, the Transmission Provider has the discretion to require the Interconnection Customer to offer security that meets the criteria Progress Energy specifies.

448. The Commission agrees with Dynegy that the Interconnection Customer should receive security if a Transmission Provider determines that the payments or property transfers should be reported as income subject to taxation. It is reasonable to require the Transmission Provider to post security, since the gross-up puts the Interconnection Customer at risk in the event that it turns out that taxes do not have to be paid, but the Transmission Provider has become insolvent. Final Rule LGIA Article 5.17 gives the

Interconnection Customer the option to request such security when the Transmission Provider has made an independent determination that taxes should be payable.⁷⁸

449. Regarding EPSA's argument that an Interconnection Customer should not be required to pay a gross-up unless it is entitled to a refund if the amounts paid ultimately are not taxed, the Commission notes that the refund protection is already in Article 5.17.7. This protection, together with the ability to require security for a gross-up, should afford an Interconnection Customer sufficient protection against the risk of nonrecovery.

450. EPSA raises issues regarding tax liability and Network Upgrades on Affected Systems. Obligations regarding tax liability and related indemnification should be set forth in a separate agreement between the Interconnection Customer and the Affected System related to the Network Upgrade.⁷⁹

451. Finally, in response to EPSA's argument that proposed LGIA Article 5.14.3 of the LGIA permits a Transmission Provider to insist on security indefinitely, the Final Rule has been revised to state that indemnification will terminate at the earlier of the expiration of the ten year testing period, as contemplated by the IRS safe harbor provisions, or the applicable statute of limitations, or the occurrence of a subsequent taxable event contemplated by this article and the payment of any related indemnification obligation. These are reasonable end points for the indemnification obligation because once the earlier of either of these events occurs, there is no further risk of new tax liability and, therefore, no further need for indemnification.

452. **Article 5.14.4 – Tax Gross-Up Amount** (In the Final Rule LGIA: Article 5.17.4) – Proposed LGIA Article 5.14.4 described how the Parties would calculate the Tax Gross-Up Amount.

Comments

453. FP&L argues that the tax gross-up methodology in proposed LGIA Article 5.14.4, when combined with the requirement that the Transmission Provider provide refunds in the form of transmission service credits for its full costs of Network Upgrades (including income taxes), will not allow the Transmission Provider to be made whole for the income tax payments for Network Upgrades. It states that Article 5.14.4 requires the Interconnection Customer to pay up front the net present value of the income taxes due on Network Upgrades, based on the assumption that the Transmission Provider will get income taxes back through the future stream of tax depreciation benefits. But if the Transmission Provider is also required to give back to the Interconnection Customer the net present value of income tax payments, plus interest, through refunds, then the Transmission Provider is paying the full cost of income taxes on assets that it is purchasing and it will not be made whole. FP&L further states that the Commission

⁷⁸Security will not be available when a Governmental Authority directs a Transmission Provider to report payments of property as income subject to taxation.

⁷⁹See Part II.A.2 – Section 3.5 (Coordination with Affected Systems).

should authorize two alternatives for the tax gross-up methodology: (1) the Interconnection Customer pays the full amount of taxes up front, but then receives refunds for its tax payments; or (2) the Interconnection Customer pays a reduced amount for the taxes up front, which is the present value of the Transmission Provider's carrying costs, calculated at its current weighted average cost of capital, for its tax payment associated with the contribution in aid of construction until it receives the payment back over time through tax depreciation, but then does not receive refunds for the payment of taxes. Under either alternative, it is essential that the Interconnection Customer not receive interest from the Transmission Provider on tax payments actually made to the government because, if it does, the Transmission Provider will not be made whole.

454. Southern asks the Commission to modify this article so that the calculation of the tax gross-up for payments that entitle the Interconnection Customer to credits is not reduced by depreciation deductions available to the Transmission Provider. FirstEnergy says the method of calculating the Present Value Depreciation Amount, should be clarified by adding the phrase "used for Federal and state purposes" after ". . . Transmission Provider's anticipated tax deductions as"

455. EPSA supports the tax gross-up calculation in Proposed LGIA Article 5.14.4. It argues that the calculation was drafted by tax professionals during the ANOPR process in an effort to ensure that the Transmission Provider is made whole. The drafting group determined that the most appropriate manner for calculating the tax gross-up is the methodology set forth in Ozark Gas Transmission Corp., 56 FERC ¶ 61,349 (1991). EPSA also states that this formula has been approved by the Commission and many existing interconnection agreements use the Ozark Gas methodology to compute tax gross-ups for both interconnection facilities and network upgrades, without regard to whether the Interconnection Customer will receive transmission credits. EPSA further argues that the calculation takes into account a Transmission Provider's federal and state tax rate and the present value of all tax depreciation deductions to which the Transmission Provider is entitled over the life of the Interconnection Facilities and Network Upgrades. Finally, EPSA argues that the tax benefits associated with depreciation are not returned to the Interconnection Customer as transmission credits, as some commenters contend. Although the Transmission Provider will return the gross tax costs to the Interconnection Customer in the form of Transmission Credits, the Transmission Provider still benefits from being able to deduct the cost of the Interconnection Facilities and Network Upgrades.

Commission Conclusion

456. The Commission agrees with EPSA that Proposed LGIA Article 5.14.4 offers the appropriate methodology for ensuring that a Transmission Provider is fully compensated for tax consequences. FP&L and Southern have not sufficiently explained how the calculation fails to make the Parties whole, and we do not revise this article.

457. This article is designated Article 5.17.4 in the Final Rule LGIA.

458. **Article 5.14.5 – Private Letter Ruling or Change or Clarification of Law** (In the Final Rule LGIA: Article 5.17.5) – Proposed LGIA Article 5.14.5 would have required that, at the Interconnection Customer's request and expense, a Transmission Provider file with the IRS a request for a private letter ruling as to whether any property transferred or sums paid or to be paid by the Interconnection Customer to the Transmission Provider under the LGIA would be subject to federal income taxation. The point of obtaining such a ruling is to get a definitive answer up front as to whether taxes will be due. If a private letter ruling concludes that such sums are not taxable, the Interconnection Customer's obligations would be reduced accordingly.

Comments

459. Commenters criticize the proposed relationships between the Interconnection Customer and the Transmission Provider in seeking a private letter ruling. El Paso argues that the Transmission Provider should have sole discretion to decide how to minimize its taxes, including whether to seek a private letter ruling or to contest a tax determination. While the Interconnection Customer must indemnify the Transmission Provider for tax liability, El Paso argues that this does not justify allowing the Interconnection Customer to require the Transmission Provider to dedicate its taxpayer status, time, and resources to seeking a private letter ruling or contesting a tax determination. This inappropriately places the Interconnection Customer in the position of deciding how the Transmission Provider will meet its obligations to the Interconnection Customer. In addition, even if the Interconnection Customer pays filing and legal fees associated with a private letter ruling or contest, this does not compensate the Transmission Provider for its internal costs of prosecuting such proceedings.

460. Dynegy generally supports this provision but contends that it should be revised because it (1) fails to recognize that the Interconnection Customer is the Party at risk of paying a tax gross-up that turns out not to have actually been required by the tax laws, and (2) unduly restricts the Interconnection Customer's ability to make the arguments it wants made in pursuing a private letter ruling. For instance, Dynegy says, Article 5.14.5 allows the Interconnection Customer to prepare only the "initial draft" of the private letter ruling request, and Article 5.16.6 provides for only one level of judicial review for appeals of adverse rulings. Such restrictions should be removed because it is the Interconnection Customer, not the Transmission Provider, that is paying the gross-up and funding the efforts to obtain a private letter ruling.

461. Salt River Project notes that this provision would require a Transmission Provider to file a private letter ruling, at an Interconnection Customer's request and expense, but establishes that the Interconnection Customer would prepare the initial draft of the letter. This will give rise to disclosure and confidentiality problems and is a bad business practice.

462. FP&L proposes, without elaboration, that the Commission modify proposed LGIA Article 5.14.5 to permit the Transmission Provider to require a jointly filed request for a private letter ruling.

463. FirstEnergy asks the Commission to clarify that the last sentence of this article refers to the need to maintain a parental guarantee or letter of credit as required by proposed LGIA Article 5.14.3, and not the Interconnection Customer's indemnification obligations under proposed LGIA Article 5.14 generally.

464. NYTO argues, without elaboration, that a provision is needed to ensure that a Transmission Owner can ask the Interconnection Customer to provide financial security to backstop its potential tax liability where the Transmission Owner has not asked for a gross-up payment from the Interconnection Customer pending any ruling from the IRS.

Commission Conclusion

465. The Commission rejects comments that seek to deny the Interconnection Customer the right to ask the Transmission Provider, at the Interconnection Customer's expense, to seek a private letter ruling from the IRS. The Interconnection Customer would otherwise be without recourse if it disagrees with the Transmission Provider's conclusion regarding either tax liability (and gross-up) or the need for security, and it is the Interconnection Customer that pays the taxes.

466. In response to Dynegy, we will not grant the Interconnection Customer greater latitude with respect to the Transmission Provider's request for a private letter ruling because the proposed provision already offers a fair balance between the interests of the Parties. While the Interconnection Customer funds the request for a private letter ruling, permitting it to submit an "initial draft" of the private letter ruling request, and to insist on a single appeal, allows the Interconnection Customer to have adequate participation in the effort to secure an IRS determination.

467. The Commission disagrees with Salt River Project's argument that allowing the Interconnection Customer to prepare the initial draft of the request for a private letter ruling from the IRS gives rise to disclosure and confidentiality problems. The Commission leaves it to the Parties to work within the confidentiality and other provisions of the LGIA to determine the most appropriate means for allowing the Interconnection Customer to draft the request.

468. FP&L offers no explanation for why the Transmission Provider should be permitted to require a jointly filed request for a private letter ruling. As a result, we reject FP&L's request.

469. The Commission agrees with FirstEnergy that the last sentence of Proposed LGIA Article 5.14.5 should be revised. This sentence refers to the Interconnection Customer's obligations if a private letter ruling concludes that the transfers or sums paid to the Transmission Provider are not subject to federal income taxation. In this event, the

Interconnection Customer's obligations with respect to the guaranty or gross-up allowed under Final Rule LGIA Article 5.17.3 will be reduced or eliminated. The private letter ruling would not eliminate the Interconnection Customer's obligation to indemnify the Transmission Provider in the event that the IRS changes its ruling or policy or a subsequent taxable event occurs.

470. As for NYTO's argument that the Transmission Provider should be able to ask the Interconnection Customer to provide financial security when the Transmission Provider has foregone the gross-up, such authority is already in Final Rule LGIA Article 5.17.3. Under this article, the Transmission Provider may secure a guaranty from the Interconnection Customer in an amount equal to the Interconnection Customer's estimated tax liability. Since the article does not specify the timing of such a request, the request may be made at any time the Transmission Provider believes that it is appropriate.

471. This article is designated Article 5.17.5 in the Final Rule LGIA.

472. **Article 5.14.6 – Contests** – Proposed LGIA Article 5.14.6 described the obligations that would apply if any Governmental Authority determines that the Transmission Provider's receipt of payments or property is income subject to taxation. At the Interconnection Customer's sole expense, the Transmission Provider would appeal or oppose such a determination. Proposed LGIA Article 5.14.6 also described the procedures for settling the contested ruling.

Comments

473. Southern proposes clarifying that the Interconnection Customer's obligation for the settlement amount is calculated on a basis that is fully grossed-up for taxes.

474. NYTO argues that the Transmission Owner's obligation to contest a determination by a Governmental Authority should be subject to the Interconnection Customer providing an opinion of tax counsel that there is high likelihood of success.

Commission Conclusion

475. The Commission rejects the commenters' requests. The Transmission Provider may determine if the settlement amount is appropriate under Article 5.14.6, which is designated Article 5.17.7 in the Final Rule, and, therefore, has the opportunity to ensure that the amount is calculated in an acceptable manner. The Commission will not require that the Interconnection Customer tender a tax counsel opinion. Under Article 5.17.7, the Interconnection Customer must pay all of the costs of an appeal of the ruling. The Commission believes that the prospect of paying for an appeal with a low likelihood of success should be a sufficient incentive not to pursue a weak case.

476. **Article 5.14.7 – Refund** (In the Final Rule LGIA: Article 5.17.8) – Proposed LGIA Article 5.14.7 described the conditions under which a refund would be payable to the Interconnection Customer for any payments made related to income tax liability and the formula for calculating the refund.

Comments

477. The Florida PSC recommends that the indemnification treatment in the LGIA be subject to review by state commissions on a case-by-case basis since there are local consequences. In some instances, indemnification alone is insufficient and letters of credit, parental involvement or other forms of guarantees may be required to protect retail customers adequately from becoming the default responsible Party. The Transmission Provider should be able to petition the state commission for a more stringent indemnification standard.

Commission Conclusion

478. The Commission does not grant Florida PSC's request. When the Commission, under the authority of sections 201, 205 and 206 of the Federal Power Act⁸⁰ sets a rate, term or condition for such transmission, a state may not exercise its jurisdiction over a retail rate to review the reasonableness of the rate, term or condition set by the Commission.⁸¹

479. This article is designated Article 5.17.8 in the Final Rule LGIA.

480. **Article 5.14.8 – Taxes Other Than Income Taxes** (In the Final Rule LGIA: Article 5.17.9) – Proposed LGIA Article 5.14.8 described the Parties' obligations if taxes other than federal or state income taxes, and for which the Interconnection Provider may be required to reimburse the Transmission Provider under the terms of the LGIA, are imposed. At the Interconnection Customer's expense, the Transmission Provider would appeal or oppose such a determination. Proposed LGIA Article 5.14.8 also described the procedures for settling the contested ruling.

Comments

481. FP&L asks the Commission to clarify Article 5.14.8 to require the Interconnection Customer to pay tax costs, other than income tax, related to interconnection payments.

⁸⁰16 U.S.C. 824, 824d and 824e (2000).

⁸¹See, e.g., *Mississippi Power & Light v. Mississippi ex rel. Moore*, 487 U.S. 354, 371-72 (1988); *Nantahala Power & Light Co. v. Thornburg*, 476 U.S. 953, 970 (1986) (both applying the same principle to the Commission's jurisdiction over wholesale sales of electric energy).

Commission Conclusion

482. The Commission notes that Article 5.14 does not limit recovery to state or federal income taxes related to interconnection payments. This provision by itself does not create additional tax liability beyond income taxes. Because FP&L offered no justification for why additional tax protection is necessary, the Commission rejects its request.

483. This article is designated Article 5.17.9 in the Final Rule LGIA.

484. **Article 5.15 – Tax Status** (In the Final Rule LGIA: Article 5.18) – Proposed LGIA Article 5.15 provided that each Party cooperate with the other to maintain the other Party's tax status. It also proposed that the LGIA would not be intended to adversely affect any Transmission Provider's tax exempt status with respect to the issuance of bonds.

Comments

485. NYTO proposes modifying the LGIA to be consistent with the tax-exempt bond provisions of the Transmission Owner's (or the ISO's) OATT. Thus, the LGIA would provide that the Transmission Owner is not obligated to take any action, and the Interconnection Customer is prohibited from taking any action, that would adversely affect the tax-exempt status of the Transmission Owner's (or the ISO's) local furnishing bonds.

486. Several commenters, including LADWP and TANC, are concerned about the effect that providing Interconnection Service will have on the tax-exempt status of their bond funding. TANC asks the Commission to provide flexibility for municipal utilities that adopt the Tariff additions. NRECA-APPA is concerned that contributions by an Interconnection Customer for construction of interconnection facilities and Network Upgrades may result in loss of its tax-exempt status. A tax-exempt cooperative must ensure that at least 85 percent of its income comes from members.

487. LPPC urges the Commission to give public power utilities the option to: (1) refuse to provide an interconnection if doing so would jeopardize the tax-exempt status of the public power utility's financing; or (2) proceed with the interconnection with an indemnification provision that would require Interconnection Customers to reimburse public power entities if any aspect of compliance with the Final Rule causes the utility to lose the tax-exempt status of its bonds.

Commission Conclusion

488. The Commission concludes that the tax status of the Parties is sufficiently protected by Proposed LGIA Article 5.15.

489. As described more fully in the reciprocity discussion in this preamble, public power and other nonjurisdictional entities with "safe harbor" tariffs may add the Final Rule LGIP and Final Rule LGIA to their safe harbor tariffs if they wish to continue to have safe harbor protection.⁸² The Commission limits reciprocity compliance to those services a nonjurisdictional entity is capable of providing on its system.⁸³ The Commission will consider the restrictions on nonjurisdictional and jurisdictional entities' conduct that would endanger the tax exempt status of their bond funding during compliance or upon submission of amended safe harbor tariffs, and we will act to ensure that they retain their tax-exempt status. Accordingly, the Commission need not address further here the argument raised by LPPC.

490. This article is designated Article 5.18 in the Final Rule LGIA.

491. **Article 6 – Testing and Inspection** – Proposed LGIA Article 6 provided that, prior to the Commercial Operation of the Generating Facility, the Transmission Provider shall test the Transmission Provider Interconnection Facilities and Network Upgrades, and the Interconnection Customer shall test the Generating Facility and the Interconnection Customer's Interconnection Facilities to ensure their safe and reliable operation. The Interconnection Customer would bear the cost of these tests and any modifications. After the Commercial Operation Date, each Party shall conduct routine inspection and testing of its own facilities, at its own expense, in accordance with Good Utility Practice.

Comments

492. Entergy generally supports the testing and inspection provisions, but urges that Article 6.1 provide the Parties with additional scheduling flexibility if testing reveals the need for modifications to the Generating Facility. Entergy therefore proposes that the Parties' schedules for completing their respective obligations to construct and install facilities shall be extended to the extent reasonably necessary to complete any necessary modifications to the Generating Facility.

493. Arkansas Coops propose that Article 6.1 of the NOPR LGIA be modified to prohibit a Transmission Provider from preventing an Interconnection Customer sale of test energy to an entity other than the Control Area operator.

Commission Conclusion

494. The Commission does not believe that a change to the LGIA is required in order to satisfy Entergy's concern. The LGIA is premised on the idea that the Interconnection Customer and Transmission Provider will coordinate the interconnection of the Interconnection Customer's Interconnection Facilities on an ongoing basis. If the testing

⁸²See Part II.C.7 (OATT Reciprocity Requirements Applied to the Final Rule LGIP and Final Rule LGIA).

⁸³Order No. 888-A, FERC Stats. & Regs ¶ 31,048 at 30,286.

reveals a problem with the Interconnection Facilities or Network Upgrades, the LGIA contemplates that the Parties will work together to modify the schedule.

495. In response to Arkansas Coops, the Interconnection Customer may sell its energy to anyone; the LGIA does not need to address this matter, as it is not an interconnection matter.

496. **Article 7 – Metering** – Proposed LGIA Article 7 would have required that, unless otherwise agreed to by the Parties, the Transmission Provider shall install, own, operate, and maintain Metering Equipment at the Point of Interconnection, with the Interconnection Customer bearing all reasonable documented costs.

497. **Article 7.2 – Check Meters** – Proposed LGIA Article 7.2 provided that the Interconnection Customer, at its own expense, may install one or more meters on its side of the Point of Interconnection to check the accuracy of Transmission Provider's meters.

498. **Article 7.3 – Standards** – Proposed LGIA Article 7.3 provided that if Article 7 conflicts with the manuals, standards or guidelines of the Applicable Reliability Council, the latter shall control.

499. **Article 7.4 – Testing of Metering Equipment** – Proposed LGIA Article 7.4 provided that if at any time Metering Equipment fails to register or is found to be inaccurate by more than one percent, the Transmission Provider shall correct all measurements made by the inaccurate meter.

500. **Article 7.5 – Metering Data** – Proposed LGIA Article 7.5 provided that the official measurement of the amount of energy delivered from the Generating Facility to the Point of Interconnection is the metered data, which would be telemetered to one or more locations designated by the Transmission Provider and one or more locations designated by the Interconnection Customer.

Comments

501. Cal ISO and SoCal Edison argue that, in California, it is the Cal ISO Tariff that governs metering provisions. They further argue that many provisions of proposed LGIA Article 7 appear to be at odds with Cal ISO's Tariff and WECC requirements. For example, Cal ISO points out that proposed Article 7.1 appears to require metering only at the Point of Interconnection which would mean "net metering," whereas WECC requires Cal ISO to meter a generator's gross output.

502. SoCal Edison and WEPCO argue that the Transmission Provider should not be required to own the meters because owning meters carries with it some liability associated with inaccurate meter readings.

503. Dynegy comments that meters should be installed at an agreed-upon location rather than at the Point of Interconnection, and metering information should be provided in analog and digital form to no more than two locations specified by the Transmission Provider. It also proposes that check meter measurements be used when the primary

meter is inaccurate, and that the Final Rule specify in more detail the cost responsibility of the Transmission Provider if it does not properly maintain the metering equipment.

504. Baker & McKenzie and Dynegy argue that proposed LGIA Article 7.2 incorrectly references Article 7.3 and should refer instead to Article 7.4. Several commenters, including Baker & McKenzie, the Bureau of Reclamation, Dynegy, and Monongahela Power, propose that language should be added to Article 7.4 to use check meters to correct the measurements read by failed or inaccurate Metering Equipment. Baker & McKenzie proposes several editorial changes to clarify Article 7.4.

505. FirstEnergy argues that the one percent metering accuracy is very difficult to achieve and its current interconnection agreement as well as the industry standard allows for a two percent metering error. It asserts that the provision should be changed to allow for a metering error of two percent. Monongahela Power argues that the allowed metering error should be 1.5 percent.

506. Several commenters including EEI, FirstEnergy, and Southern argue that the last sentence of proposed LGIA Article 7.5 incorrectly states that "metering data [is] provided by the Interconnection Customer" because the metering data is being provided by the Transmission Provider to the Interconnection Customer.

Commission Conclusion

507. Cal ISO's concern with regard to metering being allowed only at the Point of Interconnection is misplaced. Proposed LGIA Article 7.1, which provides that "[u]nless otherwise agreed by the Parties, Transmission Provider shall install Metering Equipment at the Point of Interconnection," clearly allows Metering Equipment to be placed at an agreed upon location different from the Point of Interconnection. However, in response to Cal ISO's and SoCal Edison's concern that their metering provisions are governed by WECC requirements, we are adding the following language to Article 7.1: "Each Party shall comply with the Applicable Reliability Council requirements." The Commission does not expect that Applicable Reliability Council requirements will conflict with our provisions in Final Rule LGIA Article 7. Accordingly, we find the following language to be unneeded and are deleting it from Article 7.3 (Standards): "To the extent this Article 7 conflicts with the manuals, standards, or guidelines of the Applicable Reliability Council regarding interchange metering and transactions, the manuals, standards and guidelines of such Applicable Reliability Council shall control."

508. In response to SoCal Edison and WEPCO, we are not revising proposed LGIA Article 7.1 because the Final Rule contains the phrase "[u]nless otherwise agreed by the Parties" which allows any Party to own the meters. In response to Dynegy and Baker & McKenzie we are changing the reference in Final Rule LGIA Article 7.2 to Article 7.4. We are also adding language in Final Rule LGIA Article 7.4 for the use of check meters to correct the measurements read by failed or inaccurate Metering Equipment. In response to FirstEnergy and Monongahela Power's argument, the Commission adopts a metering error of two percent because, as pointed out by FirstEnergy, two percent is the industry standard. Finally, we are correcting the error in the last sentence of proposed LGIA Article 7.5 noted by EEI, FirstEnergy and Southern.

509. **Article 8 – Communication** – Proposed LGIA Article 8 described the operating communications and dedicated data circuits between the Parties that would be necessary and the cost and maintenance responsibility for such equipment.

510. **Article 8.1 – Interconnection Customer Obligations** – Proposed LGIA Article 8.1 would have required the Interconnection Customer to maintain satisfactory operating communications with the Transmission Provider's Transmission System dispatcher or designated representatives.

Comments

511. NERC and Western recommend that a Transmission Provider be permitted to use a voice communications system that does not rely on the public telephone system.

512. Dairyland Power proposes that maintenance be performed by the Transmission Provider, in an agreed upon manner, at the Interconnection Customer's expense.

513. Cleco and FirstEnergy propose that the Interconnection Customer be responsible for the cost of maintaining any communications and computer equipment belonging to either Party, as well as the hardware and software necessary for the Transmission Provider to interface properly with the Interconnection Customer's system.

514. Progress Energy requests that the first sentence of proposed LGIA Article 8.2 be rewritten to read: "Prior to the Initial Synchronization Date of the [Generating] Facility, a remote terminal unit, or equivalent data collection and transfer equipment acceptable to both Parties shall be installed"

515. The Bureau of Reclamation believes that cyber-security and data security issues should be addressed in the body of the LGIA, and not in an Appendix.

Commission Conclusion

516. The Commission concurs with the recommendations of NERC, Western and Progress Energy, and revises Proposed LGIA Articles 8.1 and 8.2 to allow greater flexibility.

517. In response to the Bureau of Reclamation, the Commission notes that the Appendices are as binding as provisions within the body of the LGIA.

518. Articles 8.1 and 8.2 require that the Interconnection Customer transmit the data to a point specified by the Transmission Provider. Once the data has reached that point, it becomes the responsibility of the Transmission Provider to maintain its own hardware and software equipment. In response to Dairyland Power, the Commission notes that the Parties may enter into an agreement regarding which Party actually performs the data system maintenance, but the Interconnection Customer is ultimately responsible for paying for that maintenance.

519. **Article 9 – Operations** – Proposed LGIA Article 9 would have required the Interconnection Customer and Transmission Provider to operate their facilities in a safe and reliable manner. It also proposed reactive power requirements and provided that the Interconnection Customer will be compensated for capital expenses incurred based on the use of the Interconnection Facilities by the Transmission Provider, all third party users, and the Interconnection Customer.

520. **Article 9.1 – General** – Proposed LGIA Article 9.1 would have required the Parties to comply with LGIA Appendix G (Interconnection Guidelines). It would also require that each Party provide to the other Parties all information that may be required to comply with Applicable Laws and Regulations.

Comments

521. Southern, Lakeland, and FirstEnergy state that Article 9.1 should refer to Applicable Reliability Council requirements instead of Appendix G Interconnection Guidelines, which is blank. FirstEnergy states that each Party should be required to comply with the requirements of any RTO or ISO and any procedures agreed to by the Joint Operating Committee.

522. Exelon requests that proposed LGIA Article 9.1 be modified to include the following language: "To the extent interconnection requirements are inconsistent with ISO/RTO rules, the ISO/RTO rules shall govern."

Commission Conclusion

523. In the Final Rule, Article 9.1 refers to Applicable Reliability Council requirements. The Commission is deleting Appendix G (Interconnection Guidelines). With respect to FirstEnergy's request that Parties be required to comply with any procedures agreed to by the Joint Operating Committee, the Commission does not believe that any language changes are required. We clarify that the Parties are expected to comply with the procedures established by the Joint Operating Committee. We also clarify that the RTO or ISO rules, once approved by the Commission, shall govern the LGIA.

524. **Article 9.2 – Control Area Notification** – Proposed LGIA Article 9.2 would have required the Interconnection Customer to notify the Transmission Provider in writing of the location of its Control Area at least three months before the Generating Facility's Initial Synchronization Date. The proposed article also provided that the Interconnection Customer has the right to change the Control Area after the Initial Synchronization Date.

Comments

525. Some commenters, including PG&E and Cal ISO, believe that the Generating Facility must be the Control Area to which it is electrically connected.

526. MidAmerican believes that the Interconnection Customer must provide the metering and communications necessary to be a part of a Control Area other than the Transmission Provider's Control Area. Cleco proposes that since switching Control Areas is labor-intensive for the employees of both Control Areas, the Interconnection Customer should be required to remain in a Control Area for at least 12 months before switching.

527. NERC asks that proposed LGIA Article 9.2 be clarified to ensure that the host Control Area (the Control Area to which the Interconnection Customer is physically connected, regardless of whether the Generating Facility is electrically telemetered to another Control Area through a dynamic transfer) can enforce an Interconnection Customer's power factor, voltage control, and other similar obligations. Others commenters, including WEPCO, MidAmerican, Avista, National Grid, Southern, express concerns that a separate agreement and control equipment modification should be required, and that if the Interconnection Customer designates a different Control Area, it should be required to follow the rules for all applicable Control Areas.

528. Duke Energy asks what the consequence would be if an Interconnection Customer fails to notify a Transmission Provider of its Control Area three months prior to its Commercial Operating Date. The Maine PSC requests that Article 9.2 permit waiver of Control Area notification in certain situations.

Commission Conclusion

529. In response to Cal ISO, PGE, and Cleco, the Commission does not prohibit dynamic scheduling of a Generating Facility physically connected in one Control Area but scheduled into another. Nor does it place restrictions on changing Control Areas and how long an Interconnection Customer must remain in a Control Area. Moreover, in Order No. 888 the Commission did not require that Transmission Providers offer dynamic scheduling.⁸⁴ However, we also agree with the concerns expressed by NERC and other commenters that the process of changing Control Areas and the attendant implementation brings about requirements for coordination, control equipment modification, and agreement on operational details. In such cases, the Commission confirms that the Transmission Provider's OATT shall apply.

530. We also confirm that the Interconnection Customer must notify the Transmission Provider at least three months before the Initial Synchronization Date of the Control Area in which it will be located. Failure of an Interconnection Customer to make the appropriate Control Area designation would be treated as a Breach of the Final Rule LGIA, subject to opportunity to cure. Similarly, while an Interconnection Customer could request that the Transmission Provider waive the three month notice requirement, we decline to make that a provision of the Final Rule LGIA.

⁸⁴Order No. 888 at 31,709-10.

531. **Article 9.3 – Transmission Provider Obligations** – Proposed LGIA Article 9.3 would have required the Transmission Provider to operate and maintain its Transmission System in a safe and reliable manner and in accordance with the LGIA. It also proposed that the Interconnection Customer would not be obligated to follow the Transmission Provider's instructions if those instructions would undermine the safe and reliable operation of the Generating Facility.

Comments

532. NERC proposes deleting the proposed language allowing an Interconnection Customer to not follow the Transmission Provider's instructions if doing so would cause material damage to the Generating Facility. NERC is concerned that the language appears to grant the Interconnection Customer a blanket right not to follow operating instructions of the Transmission Provider.

533. NYTO proposes revising Article 9.3 of the NOPR LGIA to remove any incentive for the Interconnection Customer to "create" circumstances (e.g., emergencies) that would warrant noncompliance.

534. Southern asserts that it is inappropriate to impose broad obligations on a Transmission Provider's Transmission Systems in the LGIA. The LGIA should govern only the interconnection of an Interconnection Customer and the Interconnection Facilities necessary to achieve the interconnection, not the entire Transmission System.

535. Dynegy states that proposed LGIA Article 9.3 fails to consider the economic effect of operating instructions on the Interconnection Customer, which could be financially devastating, and that the article should make clear that the Transmission Provider must compensate the Interconnection Customer for responding to such operating instructions

Commission Conclusion

536. We agree with NERC's concern that the proposed language appears to grant the Interconnection Customer a blanket right not to follow the operating instructions of the Transmission Provider during normal operating conditions and accordingly delete the proposed language in the Final Rule. We expect a Transmission Providers to follow NERC procedures and to take every precaution not to cause any material adverse impact on the safe and reliable operation of the Generating Facility. It is essential that the Interconnection Customer follow all orders given by the Transmission Provider, unless they would result in impairment to public health or safety, since otherwise the Transmission Provider would be unable to effectively manage its Transmission System.⁸⁵ Final Rule LGIA Article 13.6 (Interconnection Customer Authority) allows Interconnection Customers to take "actions or inactions" necessary to "preserve the

⁸⁵Pacific Gas and Electric Company, et al., 81 FERC ¶ 61,122 at 61,456 (1997).

reliability of the Interconnection Customer's Generating Facility" during an Emergency Condition.

537. In response to NYTO's comments, all Parties are obligated to follow Good Utility Practice and to abide by their obligations under the LGIA. If a Party were to manufacture an Emergency Condition, it would be a violation of the LGIA, as well as a serious Breach of NERC and other reliability rules.

538. Southern's concerns are misplaced. Proposed LGIA Article 9.3 simply stated that the Transmission Provider shall maintain its system in a safe manner and that the Interconnection Customer is required to follow the instructions of the Transmission Provider under normal circumstances.

539. Dynegy's comment also appears to be misplaced. Proposed LGIA Article 9.3 dealt with the obligations of the Transmission Provider, not the obligations of the Interconnection Customer. Assuming that Dynegy's comment applies to Article 9.4 instead, we clarify that a Party is not obligated to follow a Transmission Provider's instructions that would cause harm to its Generating Facility, unless public health and safety would be threatened by noncompliance.

540. **Article 9.6.1 – Power Factor Design Criteria** – Proposed LGIA Article 9.6.1 would have required the Generating Facility to be designed so that at the continuous rated power output, its power factor would be within a range of 0.97 leading to 0.95 lagging, unless the Transmission Provider has established different requirements applicable to all Interconnection Customers in the Control Area on a comparable basis.

Comments

541. NERC proposes that the Commission require power factor capabilities to be "within a range required by Good Utility Practice," which incorporates NERC standards by reference. It cites its own Planning Standard, which allows a generator to be within the range of 0.95 leading to 0.90 lagging and argues that such a range provides more responsive reactive absorption and supply than the range proposed in Article 9.6.1. That Planning Standard also requires that if the Generating Facility does not meet the requirements, the Interconnection Customer must make alternate arrangements for supplying dynamic reactive power to meet the area's reactive power requirements. However, NERC concedes that a power factor requirement of 0.95 leading to 0.95 lagging is a common practice in some NERC regions.

Commission Conclusion

542. We adopt the power factor requirement of 0.95 leading to 0.95 lagging because it is a common practice in some NERC regions. If a Transmission Provider wants to adopt a different power factor requirement, Final Rule LGIA Article 9.6.1 permits it to do so as long as the power factor requirement applies to all generators on a comparable basis.

543. **Article 9.6.3 – Payment for Reactive Power** – Proposed LGIA Article 9.6.3 would have provided that the Transmission Provider pay the Interconnection Customer for reactive power that the Generating Facility provides or absorbs. Such payment would be in accordance with the Interconnection Customer's rate schedule unless service is subject to a Commission-approved RTO or ISO rate schedule. If no rate schedule is in effect, the Transmission Provider would compensate the Interconnection Customer in an amount that would be due the Interconnection Customer had the rate schedule been in effect when the service commenced; provided, however, that the rate schedule must be filed with the Commission within 60 Calendar Days of the commencement of service.

Comments

544. El Paso and others maintain that the Interconnection Customer should not be compensated for reactive power provided or absorbed within the power factor range established in Article 9.6.1 (Power Factor Design Criteria) since it is only meeting its obligation to do so. MidAmerican, Cleco, El Paso, Nevada Power, PG&E, and Western state that the Interconnection Customer should be compensated for the reactive power it provides or absorbs when the Transmission Provider asks the Interconnection Customer to operate its Generating Facility outside the established power factor range. Cleco and Nevada Power also contend that if the Transmission Provider pays for reactive power, so should the Interconnection Customer, when it does not meet the Transmission Provider's voltage schedule that can be met by the established power factor range.

545. MidAmerican and Cleco argue that reactive power should be paid for only if the Interconnection Customer has filed a rate schedule with the Commission prior to the commencement of service. Duke argues that the last sentence of the NOPR LGIA Article 9.6.3 that provides for filing of a rate schedule within 60 Calendar Days of having provided reactive service without a rate schedule should be moved to Article 11.6 (Interconnection Customer Compensation) to cover a similar situation during an Emergency Condition. Cal ISO believes that the procurement of reactive power should be left to another proceeding (such as a Regional Market Design proceeding), and NYISO states that this issue is already being dealt with in its Market Administration and Control Area Services Tariff.

Commission Conclusion

546. We agree that the Interconnection Customer should not be compensated for reactive power when operating its Generating Facility within the established power factor range, since it is only meeting its obligation. Proposed Article 9.6.3 required payment for reactive power to an Interconnection Customer only when the Transmission Provider requests the Interconnection Customer to operate its Generating Facility outside the range established in Article 9.6.1 (Power Factor Design Criteria). In response to Cleco and Nevada Power, we agree that the Interconnection Customer should be penalized or otherwise compensate the Transmission Provider if the Interconnection Customer does not meet the Transmission Provider's voltage schedule requirements, so long as the voltage schedule requirements can be met by the established power factor range. The Commission is not including a standard penalty or compensation provision here, but will

entertain reasonable requests to do so on compliance. We agree with Duke and move the last sentence of Article 9.6.3 to 11.6.

547. With respect to the argument that payment for reactive power should be required only if the Interconnection Customer has a rate schedule on file when service commences, we note that the Commission's Regulations allow an applicant to file a rate schedule within 60 days of the commencement of service.⁸⁶

548. An RTO or ISO, at the time its compliance filing is made, may propose variations from this policy, as discussed below.⁸⁷ An RTO or ISO has different operating characteristics depending on its size and location and is less likely to act in a discriminatory manner than a Transmission Provider that is also a market participant. An RTO or ISO will have greater flexibility to customize its LGIP and LGIA to respond to regional needs.

549. **Article 9.7.1.2 – Outage Schedule** – Proposed LGIA Article 9.7.1.2 would have a Transmission Provider post transmission facility outages on the Open Access Same-Time Information System (OASIS) and require an Interconnection Customer to schedule its maintenance on a rolling 24 month basis. It also stated that a Transmission Provider may ask the Interconnection Customer to reschedule its maintenance as necessary to maintain the reliability of the Transmission System; however, the Transmission Provider will compensate the Interconnection Customer for any costs of rescheduling such maintenance.

Comments

550. Several commenters argue that the Transmission Provider should not be required to compensate the Interconnection Customer for the costs of rescheduling maintenance when the purpose of rescheduling the maintenance is to ensure the reliability of the Transmission System. For example, Cal ISO claims that the compensation issue should be resolved by deferring to the RTO or ISO outage coordination provisions in its Tariff. Southern contends that the Interconnection Customer benefits from a reliable Transmission System and should therefore maintain the reliability of the Transmission System without any compensation for rescheduling its outages. Southern also argues that the provision seems to require the Transmission Provider to compensate the Interconnection Customer for rescheduling maintenance even if such rescheduling is required to interconnect another Interconnection Customer. If the provision is adopted, Southern requests clarification that the Interconnection Customer, not the Transmission Provider, is required to pay the costs that other Interconnection Customers incur to reschedule their maintenance. Southern also requests clarification that the reimbursed costs are limited to direct costs and will not include consequential or indirect costs (such as lost profits).

⁸⁶See 18 CFR 35.3 (2003).

⁸⁷See Part II.C.5 (Variations from the Final Rule and Regional Differences).

551. Dairyland Power, PSNM, and Western assert that an Interconnection Customer may try to game the outage scheduling process. It could revise its maintenance schedule to coincide with a maintenance project (by listing it on the Transmission Provider's OASIS) and thus create congestion or reliability conditions on the Transmission System for the purpose of receiving compensation from the Transmission Provider. PSNM further states that while curtailment and redispatch costs under the OATT generally are shared on a pro rata basis when transmission service is not available, this article anticipates that the Transmission Provider will compensate an Interconnection Customer for changes in the Interconnection Customer's maintenance plan, with no reciprocal compensation if the Interconnection Customer changes its own plans.

552. Western believes that requiring the Transmission Provider to compensate for "any costs" leaves too much to interpretation. The provision should be limited to actual costs incurred by the Interconnection Customer, such as remobilization costs, to prevent gaming. AEP believes that compensation should be provided on rare occasions when maintenance must be rescheduled for reliability purposes. Cleco believes that the payment to the Interconnection Customer should occur only if the Transmission Provider is initially allowed to approve the maintenance schedule proposed by the Interconnection Customer.

Commission Conclusion

553. We agree that the proposed requirement to compensate Interconnection Customers for "any costs" incurred in rescheduling maintenance is overly broad. Compensation should be limited to the additional, direct costs that the Interconnection Customer incurs as a result of having to reschedule maintenance.

554. We also agree that this article, as proposed, could create an opportunity for gaming on the part of the Interconnection Customer, which might schedule its maintenance at a time when the Transmission Provider could be expected to ask it to reschedule. Therefore the proposed article is modified so that an Interconnection Customer will not receive compensation if it had modified its schedule of maintenance activities during the year before the date of the initially scheduled maintenance.

555. **Article 9.7.1.3 – Outage Restoration** – Proposed LGIA Article 9.7.1.3 would have provided that if an outage on a Party's Interconnection Facilities or Network Upgrades harms the other Party's facilities, the Party owning or controlling the facility that is out of service will use Reasonable Efforts to promptly restore it to a normal operating condition.

Comments

556. NERC proposes to require the first Party to provide the other Party information on the nature of the Emergency Condition, including an estimated time of restoration, and on any corrective actions required, as soon as practical, followed by a written explanation of the nature of the outage. The clarification is necessary because the outage may affect outage clearances on other equipment, calculation of transfer capabilities, system deratings, and so on.

Commission Conclusion

557. We incorporate NERC's proposed change. NERC's proposal recognizes not only the importance of restoration after an outage, but the necessity of coordinated restoration and information-sharing to make all affected Parties aware of the restoration, the corrective actions taken, and the time the restoration occurred, so that all Parties may determine whether the interconnected system has been returned to a normal operating condition.

558. **Article 9.7.2 – Interruption of Service** (In the NOPR: Continuity of Service) – Proposed LGIA Article 9.7.2 would have provided that the Transmission Provider may require the Interconnection Customer to reduce or interrupt deliveries of electricity if such delivery of electricity would adversely affect the Transmission Provider's ability to perform activities that are necessary to safely and reliably operate and maintain the Transmission System. It also would require the Transmission Provider to schedule the reduction or interruption to either coincide with the scheduled outage of the Generating Facility or during periods of low demand.

Comments

559. Several commenters, mostly Transmission Providers such as Exelon, MidAmerican, PG&E and Southern, argue that the last sentence of proposed LGIA Article 9.7.2.4 that requires the Transmission Provider to schedule the reduction or interruption to either coincide with the scheduled outage of the Generating Facility or during periods of low demand unreasonably limits the Transmission Provider when it can perform maintenance and repair work. PG&E asserts that the periods of low demand either occur at night or during winter, and those times are not suitable for performing maintenance and repair work because it may jeopardize the safety of maintenance personnel. MidAmerican argues that the impact on both the Transmission Provider and Interconnection Customer should be considered when scheduling maintenance and repair work on the Transmission System. MidAmerican offers this alternative last sentence of proposed LGIA Article 9.7.2.4: "Transmission Provider shall coordinate with the Interconnection Customer using Good Utility Practice to schedule the interruption or reduction during periods of least impact to the Interconnection Customer and the Transmission Provider."

560. Exelon argues that a separate provision should be added to require the Transmission Provider to notify the Interconnection Customer before the Transmission Provider undertakes any construction, repair or maintenance work on its Transmission System that may require the Interconnection Customer to reduce output from its Generating Facility.

Commission Conclusion

561. In response to MidAmerican and PG&E's concern, we adopt MidAmerican's proposed language because it balances the interests of both the Transmission Provider

and the Interconnection Customer. With regard to Exelon's argument, we note that Article 9.7.2.4 of the Final Rule LGIA provides that: "Except during the existence of an Emergency Condition, when the interruption or reduction can be scheduled without advance notification, Transmission Provider shall notify Interconnection Customer in advance regarding the timing of such scheduling and further notify Interconnection Customer of the expected duration."

562. **Article 9.7.3 – Under-Frequency and Over-Frequency Conditions** (In the NOPR: Under-Frequency Load Shed Event) – Proposed LGIA Article 9.7.3 stated that the Transmission System is designed to activate a load-shed program automatically in the event of an under-frequency system disturbance. It proposed that an Interconnection Customer shall implement an under-frequency relay set point for the Generating Facility to ensure "ride through"⁸⁸ capability of the Transmission System, to the extent allowed by equipment limitations or warranties.

Comments

563. NERC, MidAmerican, and SoCal Edison state that the scope of Article 9.7.3 should be expanded to include over-frequency conditions as well.

564. NERC, Florida RCC, and TECO Energy oppose relying on equipment limitations or warranties as an excuse for an Interconnection Customer to avoid following Applicable Reliability Council rules. They claim that in a limited number of instances where equipment limitations do exist, the Applicable Reliability Council's rules permit the Interconnection Customer to propose alternative load shedding procedures. They also express concern that should the Commission retain the language relating to equipment limitations or warranties, load shedding procedures may not be effective to prevent full collapse of an electrical "island," thereby threatening the reliability of the Transmission System.

565. NERC recommends that the Generating Facility's response to both under- and over-frequency conditions be studied and coordinated with the Transmission Provider's Transmission System in accordance with Good Utility Practice.

Commission Conclusion

566. We agree with many commenters that their proposed changes would better protect reliability. Therefore, we revise Article 9.7.3 to refer to Applicable Reliability Council requirements and to include over-frequency conditions. Equipment limitations or warranties should not be an excuse for not following Applicable Reliability Council rules; in case of genuine equipment limitations, Applicable Reliability Council rules permit the Interconnection Customer to offer alternative proposals. As such, the

⁸⁸"Ride through" means a Generating Facility staying connected to and synchronized with the Transmission System during system disturbances within a range of over- and under-frequency conditions, in accordance with Good Utility Practice.

Commission eliminates the phrase "equipment limitations or warranties" in the Final Rule. In addition, the Commission is adopting NERC's proposed language regarding studies to determine the Generating Facility's response to frequency deviations because of its importance in stabilizing the power system during an electrical disturbance.

567. **Article 9.7.4.1 – System Protection Facilities** (In the NOPR: Protection and System Quality) – Proposed LGIA Article 9.7.4.1 would have required that the Interconnection Customer, at its expense, install, operate and maintain System Protection Facilities.

Comments

568. NERC states that the title of proposed LGIA Article 9.7.4.1 should be changed from "Protection and System Quality" to "Protection Required by Study" because system quality issues are not addressed here.

Commission Conclusion

569. The title of Final Rule LGIA Article 9.7.4.1 is changed to "System Protection Facilities." This change addresses the NERC comment to eliminate reference to "System Quality."

570. **Article 9.7.4.2 – Proposed LGIA Article 9.7.4.2** would have required that each Party's facility be designed to isolate any fault or abnormality that would negatively affect the other Party or third parties connected to the Transmission Provider's Transmission System.

Comments

571. NERC notes that the term "negatively affect" is too vague. It proposes that proposed LGIA Article 9.7.4.2 be revised to state that each Party's protection facilities will be designed and coordinated with other systems in accordance with Good Utility Practice.

Commission Conclusion

572. The Commission adopts NERC's proposed change.

573. **Article 9.7.5 – Requirements for Protection** – Proposed LGIA Article 9.7.5 would have required the Interconnection Customer, in compliance with Applicable Reliability Standards, to install, operate and maintain protective devices necessary to remove faults "promptly" and to protect the Generating Facility from other conditions, such as negative sequence currents and over- or under-frequency.

Comments

574. NERC comments that the term "promptly" is not useful when describing requirements for, or actions taken to preserve, system reliability. It also notes that the Generating Facility's fault protection must be coordinated with system protection. "Good Utility Practice" should replace "Applicable Reliability Standards," since Applicable Reliability Standards is a subset of Good Utility Practice.

Commission Conclusion

575. The Commission agrees NERC and adopts its proposals.

576. **Article 9.9 – Use of Transmission Provider's Interconnection Facilities by Third Parties** – Proposed LGIA Article 9.9 would have provided, among other things, that third parties may use the Transmission Provider's Interconnection Facilities if required by Applicable Laws and Regulations, or if the Parties agree.

Comments

577. APS believes that it is inappropriate to prohibit the use of Interconnection Facilities for other functions such as the housing of fiber optic circuits.

Commission Conclusion

578. Since proposed LGIA Article 9.9 specifically allows the Parties to agree to permit third party usage of the Interconnection Facilities, there is no need to revise it.

579. **Article 9.10 – Disturbance Analysis Data Exchange** (In the NOPR: Data Exchange) – Proposed LGIA Article 9.10 would have provided that the Parties cooperate with one another in the analysis of disturbances to either the Generating Facility or the Transmission Provider's Transmission System by the gathering and sharing of any information related to any disturbance.

Comments

580. NERC states that since this article is limited to data exchange for disturbance analysis, the title should be "Disturbance Analysis Data Exchange." NERC also recommends covering "and any disturbance information required by Good Utility Practice."

Commission Conclusion

581. The Commission adopts NERC's proposals in the Final Rule.

582. **Article 10 – Maintenance** – Proposed LGIA Article 10 would have made the Interconnection Customer responsible for all reasonable expenses of owning, operating and maintaining Interconnection Customer and Transmission Provider Interconnection

Facilities (except for operations and maintenance expenses associated with modifications necessary for providing service to a third party that pays for such expenses). No significant comments were submitted on this article. Accordingly, the Commission adopts in the Final Rule LGIA Article 10 as proposed.

583. Article 11 – Performance Obligation – Proposed LGIA Article 11 described the Transmission Provider's and the Interconnection Customer's obligations with respect to construction of Interconnection Facilities and Network Upgrades, security arrangements and deposits, refunds in the form of transmission credits with interest for amounts funded by the Interconnection Customer, and compensation to the Interconnection Customer for services the Transmission Provider requests.

584. Most of the issues in Proposed LGIA Article 11 relate to pricing. All pricing matters are discussed in Part II.C.1 (Interconnection Pricing Policy).

585. Article 11.5 – Financial Security Arrangements – Proposed LGIA Article 11.5 would have required the Interconnection Customer to provide the Transmission Provider with a form of security at least 90 Calendar Days before the procurement, installation, or construction of discrete Transmission Provider Interconnection Facilities or Network Upgrades begins. The security amount would have had to be sufficient to cover the costs of procuring, constructing, and installing the Transmission Provider's Interconnection Facilities or Network Upgrades, and it would have been reduced on a dollar-for-dollar basis as payments were made. Articles 11.5.1.1, 11.5.1.2 and 11.5.1.3 would have required that the issuer of the guarantee, letter of credit, surety bond or other form of security meet the creditworthiness requirements of, or be acceptable to, the Transmission Provider and that the security instrument contain specified provisions, such as a reasonable expiration date.⁸⁹

Comments

586. Commenters identify three areas of concern with this provision. First, some commenters believe that 30 days is insufficient time for the Interconnection Customer to provide a reasonable form of security to the Transmission Provider. For example, Dairyland Power argues that 30 days is not enough time for delivery of the necessary equipment and materials. SoCal PPA maintains that the security should be provided 90 days in advance. Progress Energy argues that security should be provided when an interconnection agreement is executed, and FP&L requests that security should be provided within 30 days of either execution of the interconnection agreement or its acceptance by the Commission.

⁸⁹NOPR LGIA Article 11.5.1 is identical to Article 11.5 except that the former required the Interconnection Customer to provide the Transmission Provider with a form of security at least 30 Calendar Days prior to the commencement of the procurement, installation, or construction of discrete Transmission Provider Interconnection Facilities or Network Upgrades. The inclusion of both provisions in the NOPR LGIA was an error. As explained below, we are eliminating Article 11.5 in the Final Rule LGIA.

587. Exelon argues that the amount of the security should be allowed to increase (or decrease), based on any changes in the construction cost estimate. According to Progress Energy, the Interconnection Customer should offer security to cover the full cost of the Network Upgrades. EPSA contends that the Interconnection Customer should be allowed to provide security on a rolling six month basis based on the Transmission Provider's cost exposure at each six month interval to ensure that the security costs paid by the Interconnection Customer are reasonable at any given time and are consistent with the Transmission Provider's obligations. In the alternative, EPSA supports the 30 day period. Duke Energy also supports the 30 day requirement.

588. NMA and Peabody state that while a Transmission Provider should not be placed at risk financially if an Interconnection Customer either terminates its interconnection agreement or Breaches its obligation to make monthly payments to the Transmission Provider, at no time will the Transmission Provider be exposed to the financial costs of all the amounts of Network Upgrades or additions as contemplated under the NOPR LGIA. Requiring an Interconnection Customer to guarantee the total cost of the Network Upgrades is unfair because it causes the Interconnection Customer seeking to interconnect a very large generator to incur significant interest costs that it will never be able to recover, and this does not represent the true financial exposure the Transmission Provider faces for Network Upgrades. Further, limiting the security requirement to an amount that reflects the Transmission Provider's cost exposure during a 120 day forward-looking period is more appropriate than requiring an Interconnection Customer with a very large generator to provide security for the total cost of the project. Calpine warns that unnecessary financial security would be a barrier to entry.

589. Several commenters, mostly Transmission Providers, believe that the Transmission Provider or Transmission Owner should determine the form of security to be provided by the Interconnection Customer,⁹⁰ since they bear the risk if an Interconnection Customer abandons a project. The Financial Security Issues Coalition argues that the specific reference to surety bonds should be deleted from proposed LGIA Article 11.5 because surety bonds are not in the OATT as an acceptable form of collateral. Also, to reduce bankruptcy and fraudulent conveyance issues, any proposed guaranty should be from a parent, and not merely an Affiliate, of the Interconnection Customer. Finally, any proposed guarantor should have a BBB+ bond rating or higher.

590. Sempra argues that proposed LGIA Article 11.5.1 should be revised to clarify that the decision whether to provide security is the option of the Interconnection Customer. The provision should require an Interconnection Customer to provide a substitute security if it suffers serious financial erosion and financial-ratings downgrades that could lead the Transmission Provider to require assurances of a guarantor's ability to perform its financial and performance obligations. Dominion Resources does not object to the NOPR provision, provided that a subsequent Interconnection Customer is responsible for

⁹⁰E.g., BPA, Central Maine, Duke Energy, Exelon, the Financial Security Issues Coalition, Georgia Transmission, NSTAR, and NYTO.

the costs of completing Network Upgrades if a higher-queued Interconnection Customer chooses to suspend or terminate construction of the Interconnection Facilities.

591. Arkansas Coops argue that Article 11.5.1 should require the Transmission Provider to accept security from the National Rural Utilities Cooperative Finance Corporation (CFC), since this is critical for cooperatives that obtain financing from the CFR.

Commission Conclusion

592. We note at the outset that Article 11.5 and Article 11.5.1 are substantially identical, and the inclusion of both provisions in the NOPR was redundant. We are therefore deleting Article 11.5 in the Final Rule, and renumbering the remaining articles accordingly. The discussion that follows, however, will refer to article numbers contained in the NOPR LGIA.

593. With respect to commenters' concern that the 30 day window for providing a reasonable form of security is too short, the NOPR stated that the form of security must be provided by the Interconnection Customer at least 30 Calendar Days in advance of the procurement, installation, or construction of Interconnection Facilities or Network Upgrade projects. Parties, therefore, remain free to agree to an earlier deadline for the security if they foresee circumstances such as a long lead time for delivery of equipment. We expect that an Interconnection Customer will honor a reasonable request for an earlier deadline for providing a reasonable form of security. And, we will not require that the security be available at an earlier time, or at some specified period after execution of an interconnection agreement, because the purpose of the security is to fund procurement and construction. Since it is uncertain when procurement and construction will begin, it is reasonable to make such activity the trigger for tendering the security.

594. We are not persuaded that providing security on a 120 day or six month rolling basis is superior to the approach proposed in the NOPR. We retain the article as proposed for the following reasons. First, the Final Rule LGIA provides for the reduction of the security amount on a dollar-for-dollar basis as payments are made; this protects the Interconnection Customer against providing too much security and ensures that the Transmission Provider is always adequately protected against its cost exposure. Second, commenters provide inadequate support for their claim that they would be unduly burdened if the article remained unchanged, or that a Transmission Provider and its other customers would suffer no financial harm if the Commission adopted a rolling 120 Calendar Days or six month security period. Third, retaining the proposed language will help to ensure that only a financially sound generation project will advance to the point where a Transmission Provider must make an irreversible financial commitment on its behalf. Fourth, the approach proposed by the commenters could expose a Transmission Provider and its other customers to financial risk if the Interconnection Customer defaults before the construction of new facilities and Network Upgrades have advanced to the point where those facilities can be put to productive use.

595. In response to Exelon's concern that the amount of security be permitted to increase as well as decrease, Final Rule Article 11.5 does not prohibit the Parties from increasing the total amount of security required under an executed LGIA. The prices quoted for interconnection in the LGIA are estimates based on the results of studies conducted during the LGIP phase of the interconnection process. As a result, the final cost of Network Upgrades may rise or fall and with it, the security required under the LGIA

596. We disagree with commenters' contention that the article requires the Interconnection Customer to guarantee the total cost of the Network Upgrades. Final Rule Article 11.5 requires the Interconnection Customer to provide security to the Transmission Provider for discrete portions of the Transmission Provider's Interconnection Facilities or Network Upgrades, not the total amount of the Network Upgrades. It also provides that the security amount is reduced on a dollar-for-dollar basis for payments made to the Transmission Provider, thereby protecting the Interconnection Customer from having to provide too much security.

597. With respect to commenters' arguments as to the form of security, the Final Rule states that the Interconnection Customer has the right to select a form of security that is acceptable to the Transmission Provider and that the Transmission Provider cannot unreasonably refuse to accept a particular form. As the Commission has noted in recent orders, allowing the Interconnection Customer to provide an "irrevocable letter of credit . . . or an alternative form of security proposed by the Transmission Customer and acceptable to the Transmission Provider and consistent with commercial practices" is not unreasonable, and no commenter has convinced us otherwise.⁹¹ Granting the Transmission Provider absolute discretion on what forms of security to allow would provide too great an opportunity to erect hurdles to new generation, by allowing it to act in an unduly discriminatory or preferential manner.⁹² Moreover, Final Rule Article 11.5 grants the Transmission Provider the discretion to reject security from a financial institution that is not reasonably acceptable. As a result, the Commission rejects comments that would grant the Transmission Provider greater discretion with respect to the Interconnection Customer's chosen security or eliminate forms of credit specified in the article.

598. In response to Sempra, Final Rule Article 11.5 clearly states that the Interconnection Customer "shall provide" security to the Transmission Provider. It is only the form of that security that is the Interconnection Customer's option, within the restrictions specified. We are not adding language to the provision to establish requirements if an Interconnection Customer receives a financial downgrade that make it

⁹¹See Florida Power & Light Company, 98 FERC ¶ 61,226 at 61,893-94, reh'g granted in part on other grounds, 99 FERC ¶ 61,318 (2002); Florida Power & Light Company, 98 FERC ¶ 61,324 at 62,358-59 (noting that Florida Power & Light Company's practice of limiting interconnection customers to a letter of credit is unreasonable), reh'g rejected as moot, 100 FERC ¶ 61,094 (2002).

⁹²Southwest Power Pool, Inc., 100 FERC ¶ 61,096 at P 12 (2002).

difficult to secure a guaranty. The Interconnection Customer remains responsible for providing an acceptable form of guaranty under the existing terms of the article.

599. Regarding Dominion Resources' comment, this issue is addressed in our discussion of Article 5.13 (Suspension).

600. Regarding the Arkansas Coops' concern that a Transmission Provider would not accept security from the CFC, we would not consider such a rejection to be a reasonable decision on the part of the Transmission Provider under the existing terms of Article 11.5. Accordingly, we are not revising the provision.

601. **Article 12 – Invoice** – Proposed LGIA Article 12 set out a monthly invoice and billing dispute procedure. The Transmission Provider would have been required to provide an invoice for the final cost of construction of the Transmission Provider's Interconnection Facilities and Network Upgrades within six months, in sufficient detail to enable the Interconnection Customer to compare actual costs with estimates. No significant comments were submitted on this article. Accordingly, the Commission adopts in the Final Rule LGIA Article 12 as proposed.

602. **Article 13 – Emergencies** – Proposed LGIA Article 13 explained the Transmission Provider's and the Interconnection Customer's responsibilities when Emergency Conditions arise.

603. **Article 13.1 – Definition** – Proposed LGIA Article 13.1 would define Emergency Condition as a condition or situation: (1) that in the judgment of the Party making the claim is imminently likely to endanger life or property, or (2) that, in the case of the Transmission Provider making the claim, is imminently likely (as determined in a non-discriminatory manner) to cause a material adverse effect on the security of, or damage to the Transmission System, the Transmission Provider Interconnection Facilities, or the Transmission Systems of others to which the Transmission System is directly connected, or (3) that, in the case of the Interconnection Customer making the claim, is imminently likely (as determined in a non-discriminatory manner) to cause a material adverse effect on the security of, or damage to, the Generating Facility or its Interconnection Facilities. Any condition or situation that results from a lack of sufficient generating capacity to meet load requirements and that results solely from economic conditions would not, on its own, be an Emergency Condition.

Comments

604. PG&E and Cal ISO believe that lack of sufficient generation to meet load requirements that results solely from economic conditions can be a genuine Emergency Condition. PG&E states that when insufficient generation occurs, regardless of the reason, the Transmission Provider is still responsible for maintaining system stability to the extent possible. It believes that taking away the tools necessary in such an emergency could harm the Transmission System. Cal ISO and Salt River Project make a similar point; they consider lack of generation, for any reason, to be an Emergency Condition that can endanger reliability and, at a minimum, warrants an emergency notification such

as those provided for under the Cal ISO's procedures. According to Cal ISO, without a declaration of an Emergency Condition, the Transmission Provider will not be able to invoke its obligation under Article 13.5 of the NOPR LGIA to take actions necessary to preserve reliability.

605. El Paso seeks to revise both the proposed definition of the term Emergency Conditions and NOPR LGIA Article 13 to include a definition of an abnormal condition and to provide the Transmission Provider and Interconnection Customer the discretion to prevent an Emergency Condition (by taking action or inaction) during an abnormal condition.⁹³ El Paso notes that such action or inaction would require prompt oral notification to the other Party as well as compensation for changes in real power output and reactive power production.

Commission Conclusion

606. The Commission agrees with the comments concerning the potential harm to the Transmission Provider's Transmission System by reducing its flexibility to respond during Emergency Conditions. The Commission is removing from the Final Rule LGIA Article 13.1 definition of Emergency Condition the sentence that reads, "Any condition or situation that results from a lack of sufficient generating capacity to meet load requirements that results solely from economic conditions shall not, on its own, constitute an Emergency Condition." The Commission denies El Paso's request to add a definition of an abnormal condition and to provide the Transmission Provider and Interconnection Customer the discretion to take certain actions or inactions in the event of an Emergency Condition. The Commission would expect the Parties to treat any abnormal conditions appropriately, regardless of whether it is a defined term in the Final Rule.

607. **Article 13.5.1 – Transmission Provider Authority – General** – Proposed LGIA Article 13.5.1 provided that the Transmission Provider would be able to take whatever actions or inactions it deems necessary during an Emergency Condition to preserve the safety and reliability of the Transmission System or the Transmission Provider Interconnection Facilities.

Comments

⁹³El Paso would define Abnormal Condition as "any condition at the [Generating] Facility, on the Interconnection Facilities, on the Transmission System, or on the transmission system of other utilities which is outside normal operating parameters such that facilities are operating outside their normal ratings or reasonable operating limits have been exceeded and would result in an Emergency Condition if these conditions continue. Any condition or situation that results from lack of sufficient planned generating capacity to meet load requirements or that results solely from economic conditions will not, standing alone, constitute an Abnormal Condition."

608. Dynege contends that during an Emergency Condition, the Transmission Provider should compensate the Interconnection Customer for starting up or shutting down a Generating Facility or increasing or decreasing its real or reactive output.

Commission Conclusion

609. Compensation during an Emergency Condition is appropriately addressed in Final Rule LGIA Article 11.6.1 (Generator Compensation for Actions During Emergency Conditions).

610. **Article 13.6 – Interconnection Customer Authority** – Proposed LGIA Article 13.6 would allow the Interconnection Customer to take actions or inactions necessary to protect the integrity of its Generating Facility or Interconnection Facilities during an Emergency Condition.

Comments

611. NERC proposes that Article 13.6 be revised to read as follows: "Consistent with Good Utility Practice and the [LG]IA and [LG]IP, the Interconnection Customer may take actions or inactions with regard to the [Generating] Facility or the [Interconnection Customer's] Interconnection Facilities during an Emergency Condition in order to (1) preserve public health and safety, (2) preserve the reliability of the [Generating] Facility or the [Interconnection Customer's] Interconnection Facilities, (3) limit or prevent damage, and (4) expedite restoration of service." Central Maine requests that proposed LGIA Article 13.6 be revised to require that an Interconnection Customer exercise its rights in an Emergency Condition in accordance with Good Utility Practice.

Commission Conclusion

612. We adopt NERC's proposed language in Final Rule Article 13.6 because it provides greater specificity concerning the Interconnection Customer actions or inactions that may be taken during the course of an Emergency Condition.

613. **Article 14 – Regulatory Requirements and Governing Law** – Proposed LGIA Article 14 described the regulatory requirements and governing law for each Party's obligations under the LGIA.

614. **Article 14.1 – Regulatory Requirements & Article 14.2 – Governing Law and Applicable Tariffs** – Article 14.1 of the NOPR LGIA proposed that each Party's obligations shall be subject to its receipt of any required approval or certificate from Governmental Authorities in a form and substance satisfactory to the applying Party, or the Party making any required filings with, or providing notice to, such Governmental Authorities. Article 14.1 also stated that nothing in the LGIA shall require an Interconnection Customer to take any action that could result in its inability to obtain, or its loss of, status or exemption under the Federal Power Act or the Public Utility Holding Company Act of 1935, as amended. Article 14.2 of the NOPR LGIA provided that the LGIA is governed by the laws of the state where the Point of Interconnection is located,

without regard to conflicts of state law principles, and that the LGIA is subject to all Applicable Laws and Regulations.

Comments

615. The Bureau of Reclamation states that it does not have investors or shareholders, is not subject to the Commission's jurisdiction under sections 205 or 206 of the Federal Power Act, and is not subject to the jurisdiction of state public utility commissions. The Bureau of Reclamation has sovereign immunity except to the extent that immunity has been waived by Congress. It believes that proposed LGIA Article 14.2 does not reflect that, as a federal agency, it must comply with the Constitution of the United States and all applicable laws. It states that this includes statutory and regulatory limitations on its ability to submit disputes to arbitration. SoCal PPA requests that Parties have the option of selecting the laws of a state other than the state where the interconnection will occur as the governing law for the LGIA.

Commission Conclusion

616. The Bureau of Reclamation and SoCal PPA argue that public power entities cannot adopt Article 14 without variation. We will not require these entities to adopt provisions that they are legally forbidden to adopt in order to have their reciprocity tariffs approved. As described more fully in the reciprocity discussion,⁹⁴ nonjurisdictional entities with safe harbor status for their tariffs may add the Final Rule LGIP and Final Rule LGIA if they wish to continue to have safe harbor protection, but only need to provide services they are "capable" of providing.⁹⁵ We will consider the legal restrictions on nonjurisdictional entities when we evaluate their reciprocity compliance filings.

617. **Article 15 – Notices** – Proposed LGIA Article 15 contained the addresses at which the Transmission Provider and Interconnection Customer will receive, among other things, notices, bills and payments. No significant comments were submitted on this article. Accordingly, the Commission adopts this article in the Final Rule as proposed.

618. **Article 16 – Force Majeure** – A Force Majeure clause excuses performance under a contract due to an event beyond a Party's control. Article 16 of the NOPR LGIA proposed to adopt the Force Majeure language of the OATT. It defined Force Majeure events as: "[A]ny act of God, labor disturbance, act of the public enemy, war, insurrection, riot, fire, storm, or flood, explosion, breakage or accident to machinery or equipment, any curtailment order, regulation or restriction imposed by governmental military or lawfully established civilian authorities, or any other cause beyond a Party's control" The NOPR provision would have required the Parties "to make all

⁹⁴See Part II.C.7 (OATT Reciprocity Requirements Applied to the Final Rule LGIP and Final Rule LGIA).

⁹⁵Order No. 888-A, FERC Stats. & Regs ¶ 31,048 at 30,286.

Reasonable Efforts" to comply with their obligations and resolve the Force Majeure condition.

Comments

619. Several commenters ask that the Commission establish a list of non-Force Majeure events.⁹⁶ More specifically, some commenters believe that Article 16 should exclude economic hardship from the definition of Force Majeure,⁹⁷ while the Coalition for Contract Terms and PSEG comment that the Commission should not treat "removable or remediable causes" as Force Majeure.

620. Some commenters request that the Commission establish a formal notice requirement that Parties must follow when claiming Force Majeure.⁹⁸ NYTO asks the Commission to require the Party claiming Force Majeure to notify those affected of what steps the Party is taking to remedy the Force Majeure condition. Dominion Resources and Progress Energy request that the Commission clarify the obligations and responsibilities of each Party during a Force Majeure occurrence. Specifically, they ask the Commission to clarify how a Party invokes the Force Majeure provision.

621. A number of commenters ask the Commission to clarify that the Party claiming Force Majeure must return to complying with the LGIA as soon as the Force Majeure event ends and that the other Party's obligation to pay for services rendered is not suspended during the Force Majeure event.⁹⁹

622. PacifiCorp argues that the Force Majeure clause should cover acts of negligence or intentional wrongdoing by someone other than the claimant, while MidAmerican requests the opposite. Cinergy comments that the NOPR does not define curtailment, and is concerned that this term might unnecessarily broaden the definition of Force Majeure.

Commission Conclusion

623. We agree that the contracting Parties would benefit from greater specificity in the Force Majeure provision, so the Final Rule LGIA sets forth the procedural obligations and responsibilities of the Parties during a Force Majeure event. We adopt a requirement that the Party experiencing a Force Majeure event formally notify the other Party and that it keep the other Party informed about its attempt to remedy the situation. A Party shall

⁹⁶E.g., The Coalition for Contract Terms, Monongahela Power, PJMTO, and PSEG.

⁹⁷E.g., The Coalition for Contract Terms, Entergy, Mirant, PJMTO, and PSEG.

⁹⁸E.g., The Coalition for Contract Terms, Dominion Resources, Mirant, Monongahela Power, and Progress Energy.

⁹⁹E.g., The Coalition for Contract Terms, Exelon, PSEG, and PJMTO.

exercise due diligence to remove the disability with reasonable dispatch, and it will resume its duties under the LGIA as soon as reasonably possible. For instance, a fire that triggers a Force Majeure claim may be put out within hours, but it may take the Party days or weeks to resume normal operation. The Party would not be in Default of its obligations during that time. The Final rule article also clarifies that the obligation to pay money when due is not suspended by reason of Force Majeure.

624. We agree that it would be useful to identify economic hardship as a non-Force Majeure event. Economic hardship is not considered an event outside the control of the Party. However, it is unnecessary to specify that a "removable or remediable" cause does not qualify as Force Majeure event. Final Rule Article 16 defines a Force Majeure event as one that is "beyond a Party's control."

625. NOPR Article 16.1 proposed to except from the list of Force Majeure events acts of "negligence or intentional wrongdoing." We clarify in the Final Rule LGIA that acts of negligence or intentional wrongdoing committed by an entity other than the Party claiming Force Majeure would qualify for Force Majeure protection. This is an event beyond a Party's reasonable control.

626. With respect to Cinergy's comments regarding use of the term "curtailment," we conclude that while the curtailments imposed by governmental military or lawfully established civilian authorities are considered Force Majeure events under Section 10.1 of the OATT, it is an inappropriate Force Majeure event in the Final Rule LGIA. Curtailments to transmission service should not serve as the cause for excusing performance under an interconnection contract. As a result, the Commission omits curtailment from the definition of Force Majeure in the Final Rule LGIA.

627. **Article 17 – Default** – Proposed LGIA Article 17 defined Default as the failure of either Party to perform any obligation in the time or manner provided in this LGIA. No Default would exist as a result of Force Majeure or an act or omission of the other Party. Article 17 also described notice and cure procedures: the defaulting Party would have 30 Calendar Days from receipt of a Default notice to cure the Default; or, if the Default cannot be cured within 30 Calendar Days, the defaulting Party must begin the cure within 30 Calendar Days and must complete the cure within 90 Calendar Days. NOPR Article 17.1.2 provided the non-defaulting Party with the right to terminate the LGIA and recover damages if a Default is not cured, or is not capable of being cured, within the time provided in Article 17.1.1.

Comments

628. Calpine is concerned that not all Defaults are capable of being cured within 90 Calendar Days, especially if they involve the purchase, modification or installation of equipment. It therefore argues that it is sufficient to require that the cure begin in 30

Calendar Days, and that the defaulting Party "continuously and diligently complete such cure," as required under Article 17.1.1.

Commission Conclusion

629. The Commission declines to adopt Calpine's proposed change. The non-defaulting Party needs to be protected from lengthy Defaults by having the right to terminate, even if the Default cannot be cured within 90 Calendar Days through diligent action by the defaulting Party. The LGIA does not prevent the Parties from agreeing to an extension of the time permitted to cure a Default. Calpine's proposal would provide the non-defaulting Party with too little protection.

630. **Article 18 – Indemnity** – Indemnification is defined as compensating another for a loss suffered due to a third party's act or Default.¹⁰⁰ In the NOPR, we proposed that the LGIA incorporate the indemnity provision currently found in the OATT. Thus, the indemnification provision in NOPR LGIA Section 18.1 would indemnify the Transmission Provider and Interconnection Customer for legal costs due to claims by third persons arising from performance of the Transmission Provider's or Interconnection Customer's obligations under the LGIA on behalf of the other contracting Party, and would not explicitly allow indemnification for disputes arising over enforcement of this provision. The Commission sought comments on this approach and the relative merits of the alternative provisions in the Consensus LGIA and ERCOT interconnection agreement. The Consensus LGIA does not extend indemnity protection to cases of ordinary negligence or willful misconduct, and the ERCOT provision does not extend indemnity protection to cases of gross negligence or intentional wrongdoing. Additionally, the Consensus LGIA, unlike the ERCOT interconnection agreement, sets forth detailed procedures for pursuing an indemnity claim and makes the recovery of legal costs available as part of an indemnity claim.

Comments

631. Commenters generally support the inclusion of an indemnification provision, but ask that the Final Rule cover other charges, such as attorneys' fees, and explain the process for invoking this protection.¹⁰¹ Several commenters, including Duke Energy, Monongahela Power, PacifiCorp, and Sempra, point out a typographical error that would have excepted negligence or intentional wrongdoing by the indemnifying Party rather than the indemnified Party. Some commenters recommend extending the protection to ordinary negligence by the Transmission Provider, but denying protection for gross negligence.¹⁰² NYTO and Cinergy request that the provision cover an Interconnection

¹⁰⁰Black's Law Dictionary 772 (7th ed. 1999).

¹⁰¹E.g., Central Maine, Dominion Resources, Exelon, Monongahela Power, NYTO, and Progress Energy.

¹⁰²E.g., Central Maine, the Coalition for Contract Terms, Midwest ISO TO,

Customer's performance of construction activities. PSEG requests that the provision be revised to offer specific limitations on the damages provision and a provision limiting liability arising from an emergency. El Paso requests that the Final rule specifically indemnify the Transmission Provider from penalties incurred due to the actions or inactions of the Interconnection Customer.

632. PJMTO argues that the OATT provision does not contain enough specific provisions and inadequately constrains the potential financial risk to each Party. Specifically, it argues that the provision should limit damages and set forth the proper standard for assessing liability (*i.e.*, gross negligence and willful misconduct). It also expresses concern that lending institutions would shy away from investing in new generation without liability limits.

633. Southern proposes to require that each Party indemnify and hold the other Party harmless from any liability resulting from activities on the indemnifying Party's own side of the Point of Change of Ownership, except in cases of gross negligence or intentional misconduct. Each Party should also indemnify the other Party for failure to adhere to operating requirements and Breaches of the LGIA. SoCal PPA notes that it applies a more stringent "willful action" standard. It warns that if the Commission retains the proposed standard, a Transmission Owner will have to procure insurance to cover this exposure, for which the Interconnection Customer should pay.

634. NYTO takes issue with the provision's bilateral effect, arguing that a Transmission Owner should not have to indemnify an Interconnection Customer, since the Interconnection Customer requests interconnection for its own benefit. Similarly, NYISO argues that the provision should protect the active Parties to an agreement, here the Transmission Owner or ISO, but not the Interconnection Customer.

635. Salt River Project notes that it is unclear whether the Commission intends to preempt the appropriate tribunal's consideration of whether liability should attach for injuries to third parties.¹⁰³ It also argues that compliance with an Interconnection Customer's request should not be required if it will result in violation of statutory restrictions, bond covenants, creditor agreements or private use restrictions.

Commission Conclusion

636. We are amending the proposed indemnity standard to match the customary legal standard of conduct and better address the potential for liability. Because risk exposure can increase interconnection costs, we are revising the indemnity standard to provide protection for acts of ordinary negligence, but not for acts of gross negligence or intentional wrongdoing. Similarly, commenters have convinced us that interconnection presents a greater risk of liability than exists for the provision of transmission service and

¹⁰²(...continued)
PSEG, Salt River Project, and Southern.

¹⁰³Citing Avista Corp., 96 FERC ¶ 61,058 at 61,181 (2002).

that, therefore, the OATT indemnity provision is not suitable in the interconnection context. While several commenters request a dollar limit on liability, we conclude that the tightened standards serve as an acceptable limit on liability and that a monetary limitation on damages is not necessary to adequately protect the Parties.

637. Because construction of Interconnection Facilities may expose both a Transmission Provider and an Interconnection Customer to liability for acts taken on the other Party's behalf, we are retaining the bilateral nature of the provision. In response to the concern of some commenters, the indemnity provision of the Final Rule also describes the process for pursuing and securing indemnity from claims in more detail. Additionally, the Final Rule LGIA gives an indemnified Party the right to collect the legal costs of defending an indemnification claim if the indemnifying Party fails to adequately defend the claim on its own. We also adopt El Paso's proposal that indemnification be available because of action or inaction by the Interconnection Customer, and modify the provision accordingly.

638. In response to NYTO's request that the provision cover an Interconnection Customer's construction activities, the Final Rule provision covers construction activities as well as all other activities performed on behalf of the other Party. Where an Interconnection Customer constructs the Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades under the Option to Build in Final Rule LGIA Article 5.1, a Transmission Provider will be protected by the indemnification clause that appears in that article. Indemnification applies to all work, regardless of the side of the Point of Interconnection on which the work occurs.

639. With regard to cost allocation, we clarify that each Party is responsible for paying its own insurance. This is equitable and helps keep the costs of interconnection low, which should encourage the construction of new generation resources. Additionally, we are eliminating indemnification for gross negligence or intentional wrongdoing, which will also reduce the Parties' risk exposure and cost of insurance.

640. It is not our intent to preempt the "appropriate tribunal's" assignment of liability for injuries to third parties, as proposed by Salt River Project. The indemnification provision is a common contractual risk-sharing provision and does not strip any court or other tribunal of jurisdiction. To the extent that this provision would cause a specific Transmission Provider to violate statutory or other restrictions, the issue should be raised on compliance in a filing explaining the special circumstances.

641. **Article 19 – Assignment** – Proposed LGIA Article 19 provided the conditions for assigning the LGIA to another entity. It stated that any assignment under the LGIA shall not relieve a Party of its obligations, nor shall a Party's obligations be expanded.

642. **Article 19.1 – Assignment** – Article 19.1 of the NOPR LGIA stated that written consent ordinarily would be required to assign the LGIA, but assignment may be secured without consent if the assignee is an Affiliate that meets certain qualifications. Article 19 also provided that no consent would be required if an Interconnection Customer assigns the LGIA for collateral security purposes to aid in financing.

Comments

643. The Bureau of Reclamation argues that there are limitations on its ability to comply with Article 19.1. It does not typically allow assignments without approval by both entities and assurance that assigns and successors are bound by the original terms of the interconnection agreement. It states that there are standard articles that it would be required to include that are not contained in the NOPR, such as "Officials Not to Benefit," "Use of Convict Labor," "Prompt Payment Provisions," and "Tort Claims."

Commission Conclusion

644. The Bureau of Reclamation's concerns are addressed in the reciprocity discussion at Article 14.1 (Regulatory Requirements) and Article 14.2 (Governing Law and Applicable Tariffs).

645. **Article 20 – Severability** – Article 20 of the NOPR LGIA explained that if a court or Governmental Authority determines that any provision of the LGIA is invalid, void, or unenforceable, such determination would not invalidate any other provision in the LGIA. No significant comments were submitted on this article. Accordingly, the Commission adopts this article in the Final Rule LGIA as proposed.

646. **Article 21 – Comparability** – Article 21 of the NOPR LGIA would have required that the Parties comply with all applicable comparability requirements and code of conduct laws, rules and regulations. No significant comments were submitted on this article. Accordingly, the Commission adopts this article in the Final Rule LGIA as proposed.

647. **Article 22 – Confidentiality** – Article 22 of the NOPR LGIA described what constitutes Confidential Information and the protection proposed for such information when shared between Parties. It set forth proposed procedures for the release of Confidential Information and guidelines regarding how Confidential Information should be treated when it is subject to a request from the Commission as part of an investigation. The information of both Parties is protected by this article as long as the information is identified as Confidential Information in accordance with the article.

Comments

648. Cal ISO argues that an RTO or ISO should have access to operational, performance and maintenance data.

649. The Bureau of Reclamation argues that it may not be able to conform to the proposed confidentiality provisions because it must adhere to the Freedom of Information Act (FOIA)¹⁰⁴ when addressing confidentiality. It further explains that FOIA requires federal agencies to release most documents in their possession upon

¹⁰⁴5 U.S.C. 552(a) (2000).

request, except to the extent their contents meet certain exceptions. The Bureau of Reclamation also notes that Article 22 should be revised to reflect security concerns raised by the release of information.

Commission Conclusion

650. In the Final Rule, the Commission adopts NOPR Article 22, with minor modifications, as described below.

651. In response to Cal ISO, the Final Rule allows an RTO or ISO to have access to certain data. Final Rule Article 22.1.11 permits a Transmission Provider to make available information "necessary to fulfill its obligations . . . as a transmission service provider or a Control Area operator including disclosing the Confidential Information to the RTO/ISO." A Transmission Provider that is obliged to disclose information to an RTO or ISO must notify the other Party in writing, assert confidentiality, and cooperate in seeking to protect the Confidential Information from public disclosure "by confidentiality agreement, protective order or other reasonable measures." Thus a Transmission Provider may make available any required operational, performance or maintenance data as long as it maintains the confidentiality of the requested Confidential Information.

652. Regarding the Bureau of Reclamation's argument about its obligations under FOIA, the Commission recognizes that Parties may be subject to statutory or regulatory information restrictions, some of which may address security concerns. If state or federal laws indeed conflict with the Final Rule's confidentiality and information sharing provisions, the Commission expects that public utilities will make conforming changes to these provisions in their compliance filings and explain the statutory basis for such changes. This also applies to non-public utilities that plan to amend their safe harbor tariffs with a conforming Final Rule LGIP and Final Rule LGIA.

653. The Commission is also making several minor changes to NOPR LGIA Article 22.1.10 that addresses disclosure to the Commission or its staff. A Party must provide requested information to the Commission or its staff, even when the Party otherwise would be required by the LGIA to maintain this information in confidence. The Party receiving the request must ask the Commission to treat this information as confidential and non-public, consistent with Section 388.112 of the Commission's Regulations.¹⁰⁵ A Party must notify the other Party when it learns that the Commission has received a request that such information be made public pursuant to Section 388.112. Commission policy prohibits a contracting Party from revealing to a counter-Party that it has received a request for information from the Commission, when such request is made pursuant to an investigation or otherwise.¹⁰⁶ The Commission likewise prohibits a Party from

¹⁰⁵ 18 CFR 388.112 (2003).

¹⁰⁶ American Electric Power Service Corp., 99 FERC ¶ 61,312 at PP 22-24 (2002).

notifying the other Party prior to the release of the Confidential Information to the Commission or its staff.¹⁰⁷

654. The Commission is also revising Article 22.1.10 in the Final Rule LGIA to clarify that the Party receiving the request from the Commission or its staff will not contact the other Party before releasing the Confidential Information. In addition, because requests for information may be made under the investigation rules in Section 1b.20 of the Commission's Regulations, the Final Rule article includes this reference.

655. **Article 23 – Environmental Releases** – Proposed LGIA Article 23 described the procedures that would be required for notifying the other Party of the release or remediation of Hazardous Substances. No significant comments were submitted on this article. Accordingly, the Commission adopts this article in the Final Rule as proposed.

656. **Article 24 – Information Requirements** – Proposed LGIA Article 24 described the proposed requirements for sharing information regarding the electrical characteristics of the Parties' respective facilities, including monthly status reports on construction and installation of the Transmission Provider's Interconnection Facilities and Network Upgrades.

657. **Article 24.4 – Information Supplementation** – Proposed LGIA Article 24.4 required the Parties, before the Commercial Operation Date of the Interconnection Customer's Generating Facility, to provide either updated test and other technical information or written confirmation that the new technical data and the originally submitted data are consistent. It also describes the types of voltage tests that would be conducted by the Interconnection Customer and the type of recordings it is required to provide to the Transmission Provider. It provides that when there are multiple units at a Generating Facility, the Interconnection Customer would be required to provide recordings for only one generating unit if the other units have identical design and response characteristics.

Comments

658. NERC recommends that Article 24.4 be revised to require that tests conducted on the Generating Facility be consistent with Good Utility Practice. It also recommends requiring the Interconnection Customer to provide the Generating Facility's characteristics based on validated test recordings, as opposed to raw test data. It asks that the Commission not permit the test results for one generating unit to be allowed to represent the characteristics of all generating units, if there is more than one unit at the Generating Facility with the same design characteristics. NERC believes that it is necessary to verify modeling characteristics of each generating unit for system planning purposes and to verify the operational capabilities of each generating unit for operations purposes. NERC states that the electrical characteristics of each Generating Facility are unique.

¹⁰⁷Id.

Commission Conclusion

659. We concur with NERC's position and adopts its recommended revisions.

660. **Article 25 – Information Access and Audit Rights** – Proposed LGIA Article 25 required that each Party make information available to the other Party necessary to verify costs for which the other Party is responsible under this LGIA and to carry out its obligations and responsibilities under the LGIA. No significant comments were submitted on this article. Accordingly, the Commission adopts this article in the Final Rule as proposed.

661. **Article 26 – Subcontractors** – Proposed LGIA Article 26 provided that the Parties would be able to use subcontractors to perform obligations under the LGIA if the subcontractors comply with the applicable terms and conditions of the LGIA and each Party remains liable to the other for the subcontractor's performance. The hiring Party would retain all of its obligations under this article. No significant comments were submitted on this article. Accordingly, the Commission adopts this article in the Final Rule as proposed.

662. **Article 27 – Disputes** – Proposed LGIA Article 27 explained the Dispute Resolution and arbitration procedures that would apply to the LGIA. No significant comments were submitted on this article. Accordingly, the Commission adopts this article in the Final Rule as proposed with one change to emphasize that Parties should consider using informal dispute resolution as well as more formal options.

663. **Article 28 – Representations, Warranties and Covenants** – Proposed LGIA Article 28 would have required that each Party be organized and qualified to do business in the relevant jurisdiction. Each Party would be required to have the authority to enter into this LGIA, and performance of its duties would not conflict with organizational or formation documents. No significant comments were submitted on this article. Accordingly, the Commission adopts this article in the Final Rule as proposed.

664. **Article 29 – Joint Operating Committee** (in the NOPR: Operating Committee) – Proposed LGIA Article 29 provided that the Transmission Provider shall set up: (1) an Operating Committee made up of a member from the Interconnection Customer and a member from the Transmission Provider, and (2) a Joint Operating Committee made up of members of all of its Operating Committees, in order to coordinate operating and technical considerations of Interconnection Service. The Operating Committee would meet when necessary, but not less than once each calendar year. The duties of the Operating Committee would include, among other things, establishing and maintaining control and operating procedures, data requirements and operating record requirements, reviewing outage forecasts, and coordinating outage schedules.

Comments

665. Avista and FirstEnergy oppose this requirement as unduly burdensome and unnecessary because it will impose additional costs on them. Moreover, some of the tasks envisioned for the Operating Committee are being performed either by NERC or an Applicable Reliability Council. For example, Avista argues that NERC is responsible for establishing standards for operating and control procedures for generators. Dynegy, on the other hand, would keep the Operating Committee and proposes some minor changes to the proposed language of this provision.

666. PJM and Cal ISO argue that ISOs should be exempt from this requirement because they already perform the tasks envisioned for Operating Committee in the normal course of their business.

Commission Conclusion

667. The Final Rule LGIA eliminates the requirement that the Transmission Provider constitute an Operating Committee for each Interconnection Customer. However, we are requiring a Joint Operating Committee because it provides Interconnection Customers and Transmission Providers a forum in which to discuss and coordinate operating and technical considerations of Interconnection Service. We are revising Final Rule LGIA to eliminate tasks that are already being performed by NERC, thereby responding to Avista's concern.

668. Finally, we agree with PJM and Cal ISO's proposal that the Final Rule article exempt an RTO or ISO from this requirement because an RTO or ISO performs Joint Operating Committee-type functions in their normal course of business.

669. **Article 30 – Miscellaneous** – Proposed LGIA Article 30 addressed matters such as rules of interpretation, a prohibition on third party beneficiaries, and the right to amend the LGIA by mutual agreement. No significant comments were submitted on this article. Accordingly, the Commission adopts this article in the Final Rule as proposed.

670. **Article 30.11 – Reservation of Rights** – Proposed Article 30.11 would have reserved to each Party their rights to unilaterally seek modification to the LGIA pursuant to sections 205 and 206 of the FPA, except as restricted by the other provisions of the executed LGIA.

Comments

671. Dynegy and Mirant note that this clause is redundant because another Reservation of Rights provision appears in Proposed Article 2.7.

Commission Conclusion

672. The Commission deletes proposed Article 2.7, and modifies proposed Article 30.11 in this Final Rule. As proposed, Article 30.11 contains a redundancy. The Commission deletes the second paragraph of this Article, because it repeats the reservation of rights set forth in the first paragraph of the Article.

673. **Appendices** – The NOPR LGIA contained appendices for Interconnection Facilities and Network Upgrades, time schedule, interconnection details, standard LGIA, security arrangement details, Commercial Operation Date, and interconnection guidelines. The Commission adopts these appendices in the Final Rule LGIA, with the exception of Appendix G (Interconnection Guidelines) since the Final Rule LGIA captures the provisions of that Appendix elsewhere.

C. Other Significant Policy Issues

674. A number of issues such as interconnection pricing policy, permitted variations in the terms of the Final Rule for independent transmission entities, and legal issues such as consequential damages and liquidated damages transcend individual sections in the Final Rule LGIP or articles in the Final Rule LGIA. Accordingly, they are addressed in the individual discussions that follow.

1. Interconnection Pricing Policy

675. In the NOPR, the Commission proposed to adopt its existing interconnection pricing policy for a Transmission Provider that is not independent of market participants, and invited comments on whether it should depart from this policy for a Transmission Provider that is independent.

676. Since the NOPR was written to reflect the Commission's current pricing policy, NOPR LGIA Article 11 proposed that the Interconnection Customer be solely responsible for the costs of Interconnection Facilities, which are defined as all facilities and equipment between the Generating Facility and the Point of Interconnection with the Transmission System. Network Upgrades, which are defined as all facilities and equipment constructed at or beyond the Point of Interconnection for the purpose of accommodating the new Generating Facility,¹⁰⁸ would be funded initially by the Interconnection Customer unless the Transmission Provider elects to fund them. The Interconnection Customer would then be entitled to a cash equivalent refund (i.e., credit) equal to the total amount paid for the Network Upgrades, including any tax gross-up or other tax-related payments. The refund would be paid to the Interconnection Customer on a dollar-for-dollar basis, as credits against the Interconnection Customer's payments for transmission services, with the full amount to be refunded, with interest calculated in accordance with 18 CFR § 35.19a(a)(2)(ii), within five years of the date the Network Upgrades are placed in service, so long as the Transmission Provider continues to receive payments for transmission service with respect to the Generating Facility during this

¹⁰⁸The proposed definition also states that the "facilities and equipment are used by and benefit all users of the transmission grid, without distinction or regard as to the purpose of the upgrade (e.g., to relieve overloads, to remedy stability and short circuit problems, to maintain reliability, or to provide protection and service restoration) including the fact that these facilities and equipment are being replaced or upgraded to accommodate the interconnection request."

period. The NOPR proposed that the Interconnection Customer may assign its refund rights to any person.

677. Also, in the NOPR, the Commission asked for comments on appropriate interconnection pricing consistent with the use of the locational marginal pricing methodology. This method was proposed in the Standard Market Design proceeding that the Commission had previously announced.¹⁰⁹ The Commission noted that in a region that uses locational pricing, the RTO or ISO usually assigns to the Interconnection Customer the cost of any new network facilities that would not be in its transmission expansion plan but for the interconnecting Generating Facility. The Interconnection Customer then typically receives transmission rights in return for the capacity that is created. The Commission explained that this pricing method has been allowed only in regions where the Transmission Provider is independent of market participants, because certain aspects of this method can be subjective. These subjective aspects include the determination of congestion prices, rules for deciding which Interconnection Customer in the queue should be responsible for which facilities, the cost of the facilities, and the assumptions underlying the power flow analysis needed for system impact and facilities studies. The Commission noted that a Transmission Provider that is not an independent entity would have the ability and the incentive to exploit this subjectivity to its own or its affiliates advantage if it is able to allocate the costs of Network Upgrades between the Interconnection Customer and other transmission customers, where the Transmission Provider may be the principal other customer. The Commission invited comments on whether it should accept an approach that departs from the current Commission policy of providing transmission credits, and stated its willingness to consider alternative proposals as long as the cost causation determinations are made on an objective and non-discriminatory basis by an independent entity such as an RTO.

678. The Commission has traditionally favored a "rolled-in" transmission pricing policy of the type that formed the basis for the pricing proposal in the Interconnection NOPR. However, such a policy may limit economic expansions that would remove congestion and allow customers to reach more distant power supplies. This may occur at least in part because state siting authorities may have little interest in siting a transmission facility that benefits mainly a particular Interconnection Customer or customers in another state if doing so would require the retail sales customers on the constructing public utility's system to pay for the new facilities.

679. The Standard Market Design NOPR proposed that a policy of participant funding, where those who benefit from a particular project pay for it, may help to solve this problem. The Commission then reiterated its concern that certain functions that the Transmission Provider must perform to implement participant funding can be subjective. Also in this docket, the Commission encouraged the formation of Regional State Committees, which would allow states to work together to identify beneficiaries of

¹⁰⁹Remedying Undue Discrimination Through Open Access Transmission Service and Standard Electricity Market Design, Notice of Proposed Rulemaking, 67 FR 55542 (Aug. 29, 2002), FERC Stats. & Regs. ¶ 32,563 (2002).

expansion projects and make recommendations on pricing proposals and cost recovery that may include rolling in, assignment to beneficiaries, or some combination of the two.

680. Finally, the Commission also addressed in the NOPR the question of the appropriate rate treatment for the cost of Interconnection Facilities that the Transmission Provider constructs for its own Generating Facilities. The Commission noted that, in Southern Company Services, Inc. (Southern), the company proposed to continue to treat the cost of Interconnection Facilities for its own Generating Facilities as part of the network while directly assigning the cost of the same type of facilities to its competitors' Generating Facilities. Southern raised the issue of how to ensure consistency between interconnection and transmission pricing. Recognizing the need to address this issue on a generic basis, the Commission made Southern subject to the outcome of this rulemaking. The Commission proposed in the NOPR to require all transmission rates to be designed in a manner that is consistent with whatever interconnection pricing policy is approved in the Final Rule. Thus, the Commission proposed that, to the extent its current interconnection pricing policy is adopted, each Transmission Provider must remove from its transmission rates the costs of all Interconnection Facilities, not just generator step-up transformers, constructed for the Transmission Provider's own Generating Facilities. The Commission proposed that the costs of these sole use facilities be directly assigned as generation-related costs. The Commission explained that this would be consistent with its current pricing of generator step-up transformers, and it would send a more accurate price signal by assigning the cost of Interconnection Facilities to the generation customers using them.

Comments

681. A large number of commenters argue that the Commission's proposed crediting policy provides an undesirable subsidy to the Interconnection Customer and thereby creates incentives for the Interconnection Customer to make poor siting and investment decisions. Many commenters express concerns about the relationship between this policy and the Commission's Standard Market Design proposal, and several provide recommendations on how the two rules could be made compatible. In addition, many commenters object to specific features of the proposed crediting policy. For example, several transmission owners cite problems (e.g., regulatory lag, retail rate freezes) related to their ability to recover in transmission rates the costs of interconnections, including the credits that they pay to an Interconnection Customer. Many commenters object to the five year "sunset" date for refunding all amounts paid by the Interconnection Customer. They are concerned that transmission customers could be left with the financial burden and no offsetting benefits if the Interconnection Customer's Generating Facility ceases to operate. Some commenters argue that the Interconnection Customer's receipt of credits should not be limited to those occasions when the Interconnection Customer takes transmission service with respect to the output of the Generating Facility. Others argue that the payment of interest on unpaid credits is not appropriate or that the rate prescribed is either too high or too low.

682. The following is a summary of the comments received, organized according to the issues addressed. After each issue summary, the Commission presents its conclusions for that issue.¹¹⁰

Concerns about the Fairness and Efficiency of the Commission's Crediting Policy

683. Transmission Owners, such as Entergy, and others argue that the Commission's current crediting policy requires all transmission customers to subsidize the cost of facilities that would be unnecessary "but for" a particular Interconnection Customer's Generating Facility and that provide no benefits to the other transmission customers on the Transmission System. They also argue that this policy encourages inefficient siting decisions because the Interconnection Customer has no incentive to consider the full impact of its decision regarding where to locate its Generating Facility on the Transmission System. They claim that, when selecting a site, an Interconnection Customer will pay more attention to fuel supply and water availability than to its impact on the Transmission System.

684. The Alabama PSC argues that a pricing policy that spreads the costs of all interconnection-related facilities situated "at and beyond" the Point of Interconnection to all transmission customers results in a subsidy to the Interconnection Customer, causes inefficiencies in siting, and is inconsistent with longstanding cost causation principles. The Coalition for Pricing claims that the policy of assigning cost responsibility simply based on the physical location of the facilities (*i.e.*, relative to the Point of Interconnection) is contrary to the Commission's "system-wide benefit test" and violates the Energy Policy Act of 1992. It argues that certain facilities installed at and beyond the Point of Interconnection may not provide a system-wide benefit and, as such, should be directly assigned to the Interconnection Customer. Entergy argues that grave consequences can be avoided through the interim use of the system-wide benefit test, and the assignment of costs to those who benefit, prior to the establishment of participant funded expansion regimes in RTOs.

685. PSEG notes that in PJM the cost of any Network Upgrades that would not be required "but for" the interconnection of a Generating Facility to the Transmission System is assigned to the Interconnection Customer, and the Interconnection Customer receives financial transmission rights associated with the Network Upgrades that it pays for. PJM and others argue that an established RTO or ISO should be allowed to continue to use this policy, as the NOPR proposes. PJM states that its experience under its interconnection rules confirms that such pricing promotes economic efficiency including efficient use of the Transmission System. However, KeySpan cautions that the "but for" test can become meaningless if a fictitious transmission planning study can be used to

¹¹⁰ Issues regarding the pricing of Network Resource Interconnection Service are addressed in Part II.C.2 (Interconnection Products and Scope of Service).

identify the Transmission System needs required to meet load growth. It states that the independence of the Transmission Provider completing the study is the key to this process.

686. The Maine PUC contends that the Commission's reasoning for refusing to socialize system expansion costs in the natural gas pipeline context applies with equal force in the generator interconnection context. It states that, just as subsidization of gas pipeline expansion costs could lead to non-optimal or unnecessary capacity expansion, so too will subsidization of Network Upgrades associated with new generation projects. The Maine PUC also states that, just as rolled-in pricing gives an existing gas pipeline an unfair economic advantage over potential new entrants, subsidization of Network Upgrades for Generating Facility interconnections could interfere with price signals for alternatives to traditional congestion solutions, such as load response from customers or merchant transmission.

687. Many other commenters, including state commissions, are especially concerned about an Interconnection Customer that intends to sell its output off-system or out of state. These commenters claim that the current policy requires transmission customers of the local Transmission Provider to subsidize the cost of Network Upgrades that would, in the latter case, provide them with no benefits. NRECA-APPA recommends that, without a commitment by the Interconnection Customer to serve power customers within the Transmission Provider's footprint, the Commission should require the Interconnection Customer to pay for the Network Upgrades. Some commenters, such as the Midwest ISO, further claim that the law in some states may not allow Network Upgrade costs to be rolled into the base rates of the local customers that are not the beneficiaries of the upgrades.

688. Other commenters, including EPSA, voice strong support for the crediting approach. EPSA states that the crediting mechanism works well at this time and should not be adjusted until the Commission has put in place a specific market design that would require such an adjustment. American Transmission and SoCal Edison also support the crediting approach. Indeed, American Transmission supports the crediting approach even if the Transmission Provider is an independent entity. American Transmission states that it discounts the argument advanced by critics of this policy that the Interconnection Customer must receive stronger price signals through direct assignment of the costs of Network Upgrades to bring about efficient location of new generation. It believes that requiring participant funding for Network Upgrades is akin to moving backward to the vertically integrated industry structure that existed prior to open access.

689. Cleco supports participant funding that would eliminate the need for the costs of Network Upgrades being refunded through transmission crediting. In the absence of such an approach, Cleco recommends that an Interconnection Customer should be credited for only half of the transmission service it has subscribed to for the first five years. Under Cleco's proposal, there would be no interest paid, and after five years no additional payment to the Interconnection Customer would be made. Western also recommends that the Commission adopt a method to recover the costs of the Network Upgrades from the benefitting entities. It believes that current transmission customers

should be held harmless from the cost impact of Network Upgrades that is not mitigated by increased transmission usage and associated revenues.

690. The North Carolina Commission recommends that the Commission modify its proposed rule to explicitly adopt the "but for" pricing policy for interconnection and transmission service in those states that have not yet unbundled retail electric service or implemented retail competition.

691. Several commenters, including National Grid, propose that the pricing issue can be resolved by analogy to the process of cost allocation for public roads. According to this analogy, the Interconnection Customer will have virtually sole use of the leads to the substation, just like the homeowner has sole use of his or her driveway. Thus, the cost of Interconnection Facilities, which are for the sole use of the Interconnection Customer, should be the responsibility of the Interconnection Customer. Next, the substation facilities needed to connect the sole-use facilities of the Interconnection Customer to the general delivery system are shared-use facilities, much like a local street. National Grid states that the cost of such facilities could be allocated partially to load and partially to the new Interconnection Customer. It explains that Network Upgrades that are remote from the Generating Facility typically allow movement of aggregate generation to aggregate load. National Grid contends that the benefits and use of such Network Upgrades are spread much more broadly and, like the highway system, could be rolled in and allocated to aggregate load within the market, or throughout an RTO if one exists. Finally, it argues that it may be appropriate to maintain an incremental charge for market-to-market transactions, but only where Network Upgrades in one market are needed by another market.

692. Peabody asserts that the NOPR contains certain provisions that are unjust and unreasonable as applied to large-scale base-load generation projects, especially coal-based projects. It urges the Commission to modify its interconnection pricing policy in such cases to require the Transmission Provider to roll the costs of Network Upgrades into its transmission rate base without requiring the Interconnection Customer to fund the costs in advance.

Commission Conclusion

693. For Transmission Providers that are not independent entities, the Commission will continue to apply its current interconnection pricing policy, with certain revisions that are discussed below.

694. The Commission recognizes that its policy of requiring refunds to be paid to an Interconnection Customer for the cost of Network Upgrades constructed on its behalf is a controversial one. However, the Commission instituted this policy to achieve a number of important goals. First, consistent with the Commission's long-held policy of

prohibiting "and" pricing¹¹¹ for transmission service, the crediting policy ensures that the Interconnection Customer will not be charged twice for the use of the Transmission System. The Commission determined that it is appropriate for the Interconnection Customer to pay initially the full cost of Interconnection Facilities and Network Upgrades that would not be needed but for the interconnection, but once the Generating Facility commences operation and delivery service begins, it must receive transmission service credits for the cost of the Network Upgrades. This ensures that the Interconnection Customer will not ultimately have to pay both incremental costs and an average embedded cost rate for the use of the Transmission System. Second, the Commission's crediting policy helps to ensure that the Interconnection Customer's interconnection is treated comparably to the interconnections that a non-independent Transmission Provider completes for its own Generating Facilities. The Transmission Provider has traditionally rolled into its transmission rates the cost of Network Upgrades required for its own interconnections, and the Commission's crediting policy ensures that Network Upgrades constructed for others are treated the same way. Finally, the policy is intended to enhance competition in bulk power markets by promoting the construction of new generation, particularly in areas where entry barriers due to unduly discriminatory transmission practices may still be significant. The policy is therefore consistent with the Commission's long-held view that competitive wholesale markets provide the best means by which to meet its statutory responsibility to assure adequate and reliable supplies of electric energy at just and reasonable prices.¹¹²

695. While the Commission still finds these to be appropriate goals for an interconnection pricing policy, the commenters that object to the Commission's crediting policy make a number of valid points. Most importantly, as many point out, providing transmission service credits to an Interconnection Customer for the cost of Network Upgrades that would not be needed but for the interconnection of the new Generating Facility mutes somewhat the Interconnection Customer's incentive to make an efficient

¹¹¹When a Transmission Provider must construct Network Upgrades to provide new or expanded transmission service, the Commission generally allows the Transmission Provider to charge the higher of the embedded costs of the Transmission System with expansion costs rolled in, or incremental expansion costs, but not the sum of the two. Hence, "and" pricing is not permitted.

¹¹²The Commission's crediting policy has also withstood judicial review. In an opinion issued February 18, 2003, the D.C. Circuit Court of Appeals affirmed Commission orders requiring a Transmission Provider to provide credits to Interconnection Customers for the cost of short-circuit and stability Network Upgrades. *Entergy Services, Inc. v. FERC*, 319 F.3d 536 (D.C. Cir. 2003). The court stated that "[t]he Commission's rationale for crediting network upgrades, based on a less cramped view of what constitutes a 'benefit,' reflects its policy determination that a competitive transmission system, with barriers to entry removed or reduced, is in the public interest." *Id.* at 543-44. The court concluded that "the Commission has reasonably explained that its crediting pricing policy avoids both gold plating and less favorable price signals such that the enlarged transmission system, which it views as a public good, can function reliably and continue to expand." *Id.* at 544.

siting decision that takes new transmission costs into account, and it provides the Interconnection Customer with what many view as an improper subsidy, particularly when the Interconnection Customer chooses to sell its output off-system. In this regard, the Commission believes that, under the right circumstances, a well-designed and independently administered participant funding policy for Network Upgrades offers the potential to provide more efficient price signals and a more equitable allocation of costs than the crediting approach. The Commission notes that the transmission pricing policies that the Commission has permitted for an RTO or ISO with locational pricing, in which the Interconnection Customer bears the cost of all facilities and upgrades that would not be needed but for the interconnection of the new Generating Facility and receives valuable transmission rights in return, are acceptable forms of participant funding.

696. However, the Commission remains concerned that, when the Transmission Provider is not independent and has an interest in frustrating rival generators, the implementation of participant funding, including the "but for" pricing approach, creates opportunities for undue discrimination. As the Commission stated in the NOPR, a number of aspects of the "but for" approach are subjective, and a Transmission Provider that is not an independent entity has the ability and the incentive to exploit this subjectivity to its own advantage. For example, such a Transmission Provider has an incentive to find that a disproportionate share of the costs of expansions needed to serve its own power customers is attributable to competing Interconnection Customers. The Commission would find any policy that creates opportunities for such discriminatory behavior to be unacceptable. Furthermore, none of the commenters in this proceeding has convinced the Commission that, in the absence of independence, it is possible to implement a "but for" pricing approach that avoids this inherent subjectivity. Therefore, the Commission continues in this Final Rule its current policy, as modified below, of requiring a Transmission Provider that is not an independent entity to provide transmission credits for the cost of Network Upgrades needed for a Generating Facility interconnection.

697. The Commission notes, however, that the current pricing policy does not explicitly address instances where the Generating Facility interconnects with a Transmission Provider's jurisdictional distribution facility and, as a result, upgrades are needed on the Distribution System to accommodate the interconnection. The Commission clarifies here that, if any such interconnection is jurisdictional, the cost of such upgrades must be directly assigned to the Interconnection Customer. This is because an upgrade to the Distribution System generally does not benefit all transmission customers. Distribution facilities typically deliver electricity to particular localities, and do not serve a bulk delivery service for the entire system as is the case for transmission facilities. Accordingly, it is not appropriate that all transmission customers share the cost of Distribution Upgrades.

698. For a Transmission Provider, such as an RTO or ISO, that is an independent entity, the Commission continues to allow flexibility regarding the interconnection pricing policy that each independent entity chooses to adopt, subject to Commission approval. We invite a Regional State Committee to establish criteria that an independent entity would use to determine which Transmission System upgrades, including those

required for generator interconnections, should be participant funded and which should not.

699. The Commission will permit, for a period of transition to the start of RTO or ISO operations, not to exceed a year, participant funding to be used for Network Upgrades for generator interconnections as soon as an independent administrator has been approved by the Commission and the affected states. Allowing participant funding, *i.e.*, direct assignment of the cost of Network Upgrades is reasonable, if an independent administrator performs transmission planning and related cost allocation, as a transitional approach that may be used in anticipation of an RTO or ISO assuming operational control of the regional transmission grid within a year.¹¹³ Based on the comments in this interconnection rulemaking, we find this approach to be appropriate here. Therefore, the Commission adopts this policy in this Final Rule.

700. However, the Commission wishes to emphasize that, by allowing an independent Transmission Provider to adopt a pricing policy, such as the "but for" approach, that differs from the crediting approach that the Commission is requiring for non-independent entities, the Commission is not abandoning the goals that the Commission has established for interconnection pricing, as described above. First, even though the "but for" approach allows the cost of certain Network Upgrades to be assigned to the Interconnection Customer, it is not "and" pricing if, for example, the Interconnection Customer is allowed to receive well-defined capacity rights that are created by the upgrades. For example, PJM, which uses locational pricing, gives Firm Transmission Rights (FTRs) and Capacity Interconnection Rights (CIRs) to the Interconnection Customer in exchange for a "but for" cost payment. These are rights that are created by the Network Upgrades for which the Interconnection Customer pays, and they are well-defined, long-term and tradeable. Moreover, the Commission concludes that, even if the Interconnection Customer (or its power sales customer) is also required to pay an embedded cost-based charge for transmission service, this is not "and" pricing. This is because the Interconnection Customer pays separate charges for separate services. It pays an access charge for transmission service that may involve an obligation to pay congestion charges, and in exchange for its "but for" payment, it receives these well-defined capacity rights, which provide some protection from having to actually pay the congestion charges.

701. Second, when the Transmission Provider is an independent entity, the Commission is much less concerned that all generation owners will not be treated comparably because independence ensures that the Transmission Provider has no incentive to treat Interconnection Customers differently.

702. Third, in this context, "but for" pricing is consistent with the Commission's policy of promoting competitive wholesale markets because it causes the Interconnection Customer to face the same marginal cost price signal that it would face in an efficient,

¹¹³ See *Cleco Power LLC, et al.*, 103 FERC ¶ 61,272 (2003); *Southern Company Services, Inc.*, 103 FERC ¶ 61,279 (2003), *reh'g pending*.

competitive market. This means that, in a competitive market environment, market forces could act freely to achieve the desirable level of entry of new generating capacity.

703. Finally, participant funding of transmission upgrades may provide the pricing framework needed to overcome the reluctance of incumbent Transmission Owners in many parts of the country to build transmission, with the result that badly needed transmission infrastructure could be put in place quickly.

Interconnection Pricing and the Transition to Standard Market Design

704. Several commenters assert that certain proposed Standard Market Design policies, such as locational marginal pricing, congestion revenue rights, transmission expansion pricing, and transmission planning, could affect interconnection pricing, but that the full effect cannot be determined until the Standard Market Design Final Rule is issued. Nevertheless, many of these commenters propose that, until Standard Market Design is implemented, the Commission should continue to require the Interconnection Customer to pay for Network Upgrades in exchange for future transmission service credits. Duke Energy proposes that after Standard Market Design is implemented, the crediting policy could be replaced with one that provides the Interconnection Customer with financial transmission rights in exchange for funding Network Upgrades.

705. Exelon and Sithe recommend that, for the Transmission Provider that is not yet part of an RTO, and for an RTO that has not yet implemented LMP-based congestion pricing, the Commission continue its current policy of requiring the Transmission Provider to provide an Interconnection Customer that funds Network Upgrades with credits against future transmission service. As a transition plan, Exelon and Sithe recommend that an Interconnection Customer that is receiving credits when Standard Market Design is implemented be awarded financial transmission rights in an amount based on the Interconnection Customer's remaining credits as a proportion of its total credits. Some commenters, such as Cleco Power and Monongahela Power, emphasize that a Transmission Provider should not be required to provide both transmission credits and congestion rights to the same Interconnection Customer. Mirant believes that the two practices can coexist and that the Interconnection Customer should have the option to elect either transmission credits or the equivalent firm transmission rights as comparable compensation for Network Upgrades.

706. Other commenters believe that attempting to resolve pricing issues in this rulemaking presents significant problems. New York Transmission Owners declares that the "Commission's [Standard Market Design and LMP] policies and this NOPR are regulatory ships traveling in the night on a collision course, each completely unaware of the other's existence." They propose that the Commission limit the interconnection rulemaking to non-price issues. EPSA proposes that the Commission need not resolve in this proceeding what, if any, changes in the crediting mechanism might be necessary to implement Standard Market Design and the formation of RTOs. Calpine submits that the transmission credit policy should not be abandoned in the transition to Standard Market Design. It states that relying on recovery of the costs of Network Upgrades solely

through assignment of FTRs under Standard Market Design would ignore the network access aspect of Standard Market Design and would not provide a practical means of recovering all costs of Network Upgrades. Although a change in policy may be appropriate after the Standard Market Design is in place, Calpine recommends that such a change not be made in this proceeding.

Commission Conclusion

707. The timing and content of any Final Rule in the Standard Market Design proceeding will not be determined in this proceeding. In the meantime, it is important to include interconnection pricing rules in this Final Rule, based on the record of this proceeding.

The Inability of a Transmission Owner to Recover the Costs of Network Upgrades

708. A number of Transmission Owners express concern that they may not be able to recover in a timely fashion the costs that they will incur under the proposed pricing policy. Monongahela Power states that a Transmission Owner faces three problems in this regard. First, it notes that a Transmission Owner faces the expense, delay, and uncertainty of a full transmission rate case before the Commission to roll in the costs of system upgrades associated with new generation projects. Second, it claims that even if the Commission grants full cost recovery, costs may be "trapped" by an inability to pass them through to the majority of customers due to a state retail rate freeze. Third, a Transmission Owner may face lost revenues associated with a new generating project once transmission service begins because of the requirement to provide a financial credit to the Interconnection Customer. Monongahela Power asks that the Commission permit a Transmission Owner to make a limited Section 205 filing for the immediate roll in of these costs, and that it work with the States to accommodate the flow-through of these costs to retail customers. At a minimum, both Monongahela Power and Dominion Resources ask that the Commission provide for deferred accounting treatment with assurances of future cost recovery when the Transmission Owner must record a transmission revenue credit with no income to offset it.

Commission Conclusion

709. The Commission concludes that it is not necessary to provide for the Transmission Provider to make a limited Section 205 filing as proposed by Monongahela Power for the immediate roll in of the costs it will incur under the crediting policy. In the ordinary course of business, a public utility frequently incurs costs for which it has no immediate revenue offset, just as it routinely experiences revenue increases that are not accompanied by commensurate increases in costs. When a public utility believes that its revenues are not adequate, it is permitted by Section 205 of the FPA to make a rate filing. The

commenters have provided no evidence to convince the Commission that the burden created by its crediting policy is so great that the Commission should change its regulations to permit a limited Section 205 transmission rate filing that addresses only credit-related cost increases, or deferred accounting treatment for transmission credits, as sought by Monongahela Power and Dominion Resources.

Responsibility for Line Outage Costs Resulting from Interconnection

710. The NOPR did not address the allocation of costs that may be incurred when a transmission line must be taken off-line in order to complete an interconnection. In an order issued November 20, 2001,¹¹⁴ however, the Commission stated that it would consider in this rulemaking the question of who should bear these costs.

711. Commenters express a variety of views on this issue. The Coalition for Pricing states that these costs should be a component of the costs paid by generators for interconnection service under the Final Rule IA. It asserts that any other policy would result in all transmission customers unfairly subsidizing Generating Facility interconnections. The Coalition for Pricing proposes that the Parties to individual interconnection agreements be allowed to agree on the specific line outage costs for which the Interconnection Customer should be responsible. The Coalition for Pricing argues that, since the Parties' agreement would necessarily be filed with the Commission, it would retain its regulatory control over line outage cost allocations. However, Reliant states that the Commission has had a policy of not requiring that the Interconnection Customer pay for outage-related costs, and argues that the Coalition for Pricing has provided no justification for departing from this policy. Reliant recommends rejecting the modifications that the Coalition for Pricing proposes.

712. AEP recommends that the Interconnection Customer be required to reimburse all affected generation owners for outage-related costs that they incur, whether or not such generation owners are affiliated with the Transmission Provider. AEP believes that this can be done in a manner that properly identifies the costs, minimizes the Transmission Provider's discretion, and allows for adequate regulatory scrutiny. It recommends a method of compensation that it claims avoids the exercise of discretion. That is, the Interconnection Customer should replace the energy that would otherwise have been generated by the affected Generating Facility. AEP states that if the Interconnection Customer is unwilling to replace the lost energy, it would be up to the affected generation owner to file with the Commission a proposal to recover its costs. Further, AEP believes that the Interconnection Customer, the existing generation owner and the

¹¹⁴ American Electric Power Service Corporation, 97 FERC ¶ 61,200 (2001) (AEP).

Transmission Provider should be obligated to use Reasonable Efforts to minimize the impact of any outage.

713. ATC states that dividing the costs between the Interconnection Customer and the Transmission Provider may provide the most equitable results. It believes that a reasonable approach might be to allocate up to the full costs of the line outage to the Interconnection Customer so long as the timing is primarily under the Interconnection Customer's control. However, if the Transmission Provider has substantial influence over the timing and engineering aspects of the outage, ATC recommends that all or a large percentage of the new facility costs may be appropriate for rolling into transmission rates.

Commission Conclusion

714. The Final Rule does not permit the Transmission Provider to allocate interconnection-related outage costs to the Interconnection Customer. The Commission recognizes that the Transmission Provider and the owners of other generators may incur costs as a result of having to take a transmission line out of service in order to complete an interconnection. Such costs may include generator shut-down and restart costs, redispatch and purchased power costs, lost opportunity costs on sales not made, costs of power to compensate for additional line losses, and possibly other costs. In prior orders,¹¹⁵ the Commission has generally rejected, without prejudice, proposals by a Transmission Provider to allocate these costs to the Interconnection Customer. Among other things, the Commission has found that the proposals are vague, leave too much discretion to the Transmission Provider, and do not provide for adequate regulatory oversight by the Commission. For example, in NSTAR, the Commission stated that "determining how much cost responsibility to assign to an interconnecting generator, when other factors also may contribute to the need to redispatch contemporaneously, would be unacceptably arbitrary: for example, higher redispatch costs may be the result of a planned or unplanned outage, maintenance that requires a line to be taken out of service temporarily, or an unexpected shift in load."¹¹⁶ Furthermore, while the Transmission Provider may be able to propose an objective method for determining its own outage-related costs, estimating the outage-related costs of unaffiliated generation owners could pose a significant problem. The Commission does not believe that AEP's proposal to have the Interconnection Customer replace the energy that would otherwise have been generated by the affected Generating Facility solves this problem in part because the value of the replacement energy may bear no relationship to the actual outage-related costs.

715. As the Commission concluded above, when the Transmission Provider asks the Interconnection Customer to reschedule a planned maintenance outage of the Generating Facility (per Article 9.7 – Outages, Interruptions, and Disconnection), the Interconnection Customer should be compensated for only the direct costs that the

¹¹⁵See, e.g., *id.*; ISO New England, Inc., 91 FERC ¶ 61,311 (2000).

¹¹⁶Cambridge Electric Light Co., *et al.*, (NSTAR), 95 FERC ¶ 61,339 (2001).

Interconnection Customer incurs. It should not be compensated, for example, for lost opportunity costs. One reason is that outages of transmission and generation facilities for maintenance and other purposes are a routine part of electric system operations and, in fairness, these costs also should be considered a normal part of doing business. Moreover, the determination of the appropriate level of costs to be allocated involves a process that is inevitably arbitrary and contentious, particularly when the determination is made by a Transmission Provider that is not an independent entity. Therefore, in the Final Rule we are codifying our policy of not allowing interconnection-related outage costs to be allocated to the Interconnection Customer.

Issues Concerning the Five Year Refund Period and the Payment of Interest

716. Many commenters object to the proposal to require the Interconnection Customer to be reimbursed for the costs of Network Upgrades within a five year period. Several also object to the payment of interest on outstanding balances or to the formula for determining the rate of interest.

717. Duke Energy generally supports the provisions as proposed but, to be consistent with the Commission's policy of allowing the Transmission Provider to collect the higher of incremental or embedded costs for transmission service, it recommends elimination of the five year "sunset" provision in Section 11.4.1 of the NOPR LGIA. Cleco is concerned that a Transmission Provider may be liable for payment of refunds after a five year period has elapsed because the Interconnection Customer has not taken enough transmission service to be credited the full amount for upgrades originally paid for. Westconnect RTO submits that arbitrarily setting a five year term is unjustified and unreasonable. It proposes that a more appropriate approach would be to allow unused transmission credits to expire after a set term. However, Mirant argues that once the Network Upgrades are placed in service, every network customer receives some benefit from those facilities. Therefore, it sees no reason to limit the refund to the requirement in proposed LGIA Article 11.4.1 that the Transmission Provider continue to receive payment for transmission service from the Generating Facility.

718. Western states that if it has to return monies to an Interconnection Customer in less time than the service life of an upgrade, rates may have to be increased to ensure the timely repayment of other federal investments. It believes such a rate increase would be inequitable to existing customers. BPA states that the Interconnection Customer should not be entitled to a refund over an arbitrary five year period and argues that other customers should not have to bear the risk that the Interconnection Customer will cease taking transmission service. LADWP states that the five year requirement imposes an undue burden on public power customers. It requests that, if the Commission's generation interconnection pricing policy is applied to a non-jurisdictional transmission owner, that owner should have the flexibility to provide such refunds over the same period that it would use to amortize such facilities if constructed for the benefit of its own customers. WEPCO states that the Commission should recognize that sometimes

both the Interconnection Customer and the Transmission Provider may desire a payback period of less than five years. Accordingly, it recommends that the Commission revise Article 11.4.1 of the NOPR LGIA to provide for repayment at such earlier time as the Parties may agree.

719. Mirant argues that, at a minimum, the Commission should require that interest on any Network Upgrades be calculated using the Transmission Provider's most recent Commission-approved rate of return in the Transmission Provider's OATT. For a non-public utility that does not have a rate of return, Mirant proposes that the Commission use the rate of return set forth in the most recent Commission order as a proxy for such entity. Peabody recommends that the Commission modify the proposed LGIA to provide for a more flexible, incentive-based rate of interest for transmission credits. Also, if a Transmission Provider files for incentive pricing for transmission service, Peabody recommends that it be required to file simultaneously to amend the interest rate in LGIA Article 11.4.1 to match such incentive mechanism. Progress Energy disagrees with the requirement to pay an Interconnection Customer interest, arguing that the Transmission Provider cannot use the funds advanced by the Interconnection Customer for purposes other than constructing the Network Upgrades and that it should not be put in the position of being a bank for the Interconnection Customer. If interest must be paid, Progress Energy proposes using the Federal Fund Commercial Rate or a similar rate to ensure that the payment of interest is not a source of profit for the Interconnection Customer.

Commission Conclusion

720. Regarding the specific rules for the payment of credits, the Commission clarifies that the Interconnection Customer is entitled to a full refund of the payments it makes toward the cost of Network Upgrades within five years after the Commercial Operation Date, as long as the Generating Facility remains in operation through the five year period.¹¹⁷ During the five year period, credits must be awarded on a dollar-for-dollar basis as payments are made for transmission services. However, the Commission is also permitting the payments to be made on any other basis that is mutually agreeable to the Interconnection Customer and the Transmission Provider. For example, if the Parties agree to a stream of uniform monthly payments designed to fully reimburse the Interconnection Customer over the five year period, that would be acceptable. In addition, as stated in Article 11.3 of the Final Rule LGIA, the Transmission Provider may elect to fund the Network Upgrades itself, with no advance payment by the Interconnection Customer, and thus no need for subsequent credits.

¹¹⁷Although Article 11.4.1 of the NOPR LGIA proposed to begin the five year period on the date that the Network Upgrades are placed in service, as the Commission explains below, the Commission concludes that the Interconnection Customer should not be entitled to receive a refund unless the Generating Facility achieves commercial operation. Therefore, the Commission is modifying Article 11.4.1 to specify that the five year period begins with the Generating Facility's Commercial Operation Date.

721. With regard to Cleco's concern about the Transmission Provider's liability at the end of the five year crediting period, the Commission clarifies that the Transmission Provider must make a lump-sum payment to the Interconnection Customer for any balance owed to the Interconnection Customer five years after the Interconnection Customer has begun commercial operation.

722. The Commission recognizes that the choice of the length of the repayment period is somewhat arbitrary. However, specifying five years as the maximum repayment period will promote the development of new generation by reducing the Interconnection Customer's risk, thereby facilitating project financing. Contrary to the views of LADWP and others, it would not be appropriate to extend repayment over a period that corresponds to the Transmission Provider's amortization period for similar facilities. As explained above, the Commission's policy for a non-independent Transmission Provider is to roll the costs of interconnection-related Network Upgrades into the Transmission Provider's transmission rate base. However, rather than require immediate roll-in, we have chosen a five year repayment period, in part to provide the Interconnection Customer with an incentive to make good faith requests for Network Upgrades.

723. With regard to the payment of interest on unpaid credits, the Commission adopts the policy proposed in the NOPR. The Commission continues to believe that the Interconnection Customer is entitled to a refund for all of the costs of the Network Upgrades for which it has paid, including a reasonable estimate of the carrying costs that it incurs in making the advance payments. The determination of an interest rate that accurately reflects this carrying cost cannot be reduced to a completely objective calculation. Interest calculated in accordance with 18 CFR § 35.19a(a)(2)(ii) provides a reasonable proxy for this carrying cost, and because it offers an objective calculation, the Commission retains this provision in Article 11.4.1 of the Final Rule LGIA.

Rules Governing the Payment of Credits

724. With regard to the payment of credits, Interconnection Customers generally are in favor of a flexible policy that allows credits to be paid under a wide range of circumstances, while Transmission Providers advocate a policy that places strict limits on when and how an Interconnection Customer may receive credits.

725. For example, Dynegy states that the Final Rule must ensure that the credits do not limit the Interconnection Customer to purchasing the delivery component of transmission service on the Transmission Provider's system with the Interconnection Customer's Generating Facility as the Point of Receipt. Instead, Dynegy believes that the credits should apply to transmission at any location on the Transmission Provider's system. Duke Energy believes that an Interconnection Customer's flexibility in obtaining refunds should be similar to the flexibility a Transmission Customer has to reassign transmission service under the OATT. Accordingly, it proposes to allow credits not only for the charges for transmitting power from the Generating Facility, but also for the charges for transmitting power from an Affiliated Generating Facility. Similarly, Peabody states that the Interconnection Customer should be allowed to receive credits for any transmission service that it purchases on the Transmission Provider's Transmission System. Both

Calpine and EPSA offer modified language for Article 11 of the NOPR LGIA that would implement these recommendations. Cal Cogen and the Energy Producers and Users Coalition claims that a term-based credit mechanism (i.e., one where the credits are paid out according to a fixed schedule) is preferable to the NOPR's proposed transmission-based mechanism.

726. Edison Mission states that Articles 2 and 11 of the NOPR LGIA should be modified so that if an Interconnection Customer pays for Network Upgrades but the interconnection agreement is then terminated or the Generating Facility not constructed, the Interconnection Customer nonetheless receives payments for the upgrades it paid for, with the payments coming from other users of the Transmission System.

727. Other commenters propose limiting the availability of credits. Dominion Resources argues that, if Network Upgrades funded by the Interconnection Customer are not used for output from the Generating Facility, a refund for such upgrades is inappropriate. Similarly, the Coalition for Pricing claims that proposed LGIP Section 11.4.2 can be read to suggest that the Interconnection Customer has some right to transmission credits as transmission service is taken anywhere on the Transmission Provider's system. It asks the Commission to clarify that this is not the case. The Alabama PSC argues that providing transmission credits only when transmission service is taken from an Interconnection Customer's Generating Facility would prevent the socialization of upgrade costs that do not benefit the network.

728. Westconnect RTO and others argue that the Transmission Provider should credit the Interconnection Customer only for the "demand" or "return" component of the otherwise applicable transmission charges, and not apply the credit to such costs as operations and maintenance, administrative and general, taxes, line losses, etc. Also, Westconnect RTO and BPA oppose the proposal in Section 12.3 of the NOPR LGIP that the Interconnection Customer receive transmission credits for expediting costs associated with constructing Network Upgrades out of sequence. TAPS states that the Interconnection Customer should receive a credit against its network transmission service bill based on the capacity of the Generating Facility, not the energy output of the unit. It argues that an energy output-based method of calculating the credit unfairly penalizes network customers and sends the wrong price signal, discouraging the construction of peaking units and the designation of such units as Network Resources.

729. WEPCO states that the Commission must continue to mandate, as proposed in Article 11.4 of the NOPR LGIA, that rights to receive credits are fully assignable. It believes that this is crucial because in many instances the Interconnection Customer is not the transmission customer.

Commission Conclusion

730. The Commission agrees with Dynegy and others that the Interconnection Customer should receive credits for transmission (delivery) service taken anywhere on the Transmission Provider's Transmission System and that credits should not be limited to service taken with respect to the Generating Facility at the point of receipt, as long as

certain conditions are met. That is, as long as the Generating Facility has achieved commercial operation, continues to operate and there are unpaid credits outstanding, the Interconnection Customer should receive credits for all of the transmission charges that it pays, including charges for "through" transmission service. This is appropriate because it provides an additional vehicle by which the Transmission Provider can meet the requirement that the Interconnection Customer must receive a full refund of all amounts due within five years of the Commercial Operation Date. Accordingly, the Commission is removing from Article 11.4.1 of the Final Rule LGIA the following language: "so long as Transmission Provider continues to receive payments for transmission service with respect to the Generating Facility during such period."

731. Edison Mission asks that Articles 2 and 11 of the NOPR LGIA be modified to allow the Interconnection Customer to receive credits for Network Upgrades that it has paid for if the interconnection agreement is terminated or the Generating Facility is not constructed. The Commission disagrees. In order to achieve an appropriate balance between the Interconnection Customer's risks and incentives, the Commission believes that the Interconnection Customer should receive a refund of the costs of Network Upgrades only if the Generating Facility has achieved commercial operation. Allowing the Interconnection Customer to avoid any responsibility for the cost of Network Upgrades needed for a Generating Facility that is never completed would improperly shift all risk of cost recovery to the Transmission Provider and its other customers. In addition, it would greatly reduce the Interconnection Customer's incentives to make good faith requests for Network Upgrades. Therefore, the Commission concludes that the Transmission Provider must provide a refund to the Interconnection Customer only after commercial operation of the Generating Facility has been demonstrated. However, if the Generating Facility fails to achieve commercial operation, but it or another Generator Facility is later constructed and makes use of the Network Upgrades, the Interconnection Customer would at that time be entitled to a refund of the investment that it made in the Network Upgrades.

732. Westconnect RTO and others argue that the Transmission Provider should credit the Interconnection Customer only for the non-usage sensitive "demand" or "return" component of the applicable transmission charges, presumably on the basis that this is the component that relates most directly to the cost of the investment for which the Interconnection Customer is to receive credits. The Commission clarifies that the Transmission Provider may decline to award credits for those transmission charges that are designed to recover out-of-pocket costs, such as the cost of line losses, associated with the delivery of the Generating Facility's output. The Commission notes, however, that all amounts paid by the Interconnection Customer toward Network Upgrades must be refunded within five years of the Commercial Operation Date. Thus, any reduction in the level of credit payments will only increase the cost of interest and the magnitude of the final cash payment that may be required.

733. Westconnect RTO and BPA oppose the proposal in Section 12.3 of the NOPR LGIP that would provide the Interconnection Customer with a refund of the costs of expediting construction of Network Upgrades so that they can be placed in service out of sequence. The Commission is not changing this provision in the Final Rule LGIP. The

sequence in which Network Upgrades would normally be constructed is based on the order in which requests are received. Although changing the order may increase or decrease the level of costs, the new level of costs is no less legitimate than the first. Thus, the Transmission Provider must refund to the Interconnection Customer the cost of constructing Network Upgrades regardless of the construction sequence.

734. In response to WEPCO's concern about the assignability of refund rights, the Commission confirms that Final Rule LGIA Article 11.4 provides that refund rights are fully assignable.

735. Finally, the Commission clarifies how the crediting policy will work when the Interconnection Customer elects to build and retain ownership of Stand-Alone Network Upgrades. In such case, the Interconnection Customer is not entitled to a refund of its investment in any facilities in which it elects to retain ownership. If the Interconnection Customer constructs Stand-Alone Network Upgrades, and chooses not to transfer ownership to the Transmission Provider, it will not receive a refund but may enter into a cost-based lease agreement with the Transmission Provider that places the upgrades under the Transmission Provider's operation and control. The rates, terms and conditions of any such lease agreement are subject to the approval of the Commission.

Responsibility for the Costs Incurred by Affected Systems

736. A number of commenters argue that the Final Rule should address directly the assignment of costs that may be incurred by Affected Systems when an Interconnection Customer obtains an interconnection.¹¹⁸ Entergy contends that, even if the Final Rule LGIA could bind an Affected System, the Commission's current interconnection pricing policies fail to establish the allocation of the costs of Network Upgrades among the Interconnection Customer, the interconnecting Transmission Provider, and the Affected System. Dominion Resources recommends that Section 3.5 of the NOPR LGIP require the Interconnection Customer to be responsible for all costs incurred by the Transmission Provider in coordinating the interconnection request with the affected party, including all study costs. Reliant states that there is presently no mechanism that provides the Interconnection Customer with transmission credits for a contribution to the construction of Network Upgrades on third party systems. Reliant recommends that the Commission add to Section 3.5 of the NOPR LGIP language proposed by EPSA that addresses this omission. Mirant recommends that the Commission require the Transmission Provider to coordinate the provision of transmission credits associated with funding Network Upgrades on affected third party systems.

737. LADWP is concerned that the NOPR did not address how the Commission intends the financing and crediting to be implemented if the Interconnection Customer does not purchase transmission service on the Affected System.

¹¹⁸ As discussed above, an Affected System is a system other than that of the Transmission Provider that may be affected by the proposed interconnection.

Commission Conclusion

738. The NOPR LGIP and NOPR LGIA included no pricing provisions that specifically address situations where Network Upgrades must be constructed on Affected Systems to protect the reliability of those systems. However, the Commission concurs with the commenters that state that the NOPR LGIA should be modified to expressly allow for refunds to be provided to the Interconnection Customer when such Network Upgrades must be constructed and the Interconnection Customer is required to pay for them. Therefore, the Commission modifies Article 11.4 of the Final Rule LGIA to make it applicable to all jurisdictional Affected System Operators on whose systems Network Upgrades are constructed to accommodate the Interconnection Customer's Interconnection Request. This means that, prior to the Commercial Operation Date, an Affected System Operator may require the Interconnection Customer to pay for all Interconnection Facilities and Network Upgrades constructed to accommodate the Interconnection Customer's Interconnection Request. Then, upon commencement of commercial operation, any Affected System Operator that has received payments from the Interconnection Customer must begin to refund to the Interconnection Customer the costs of Network Upgrades that the Interconnection Customer has paid. Furthermore, refunds are to be provided without regard to whether the Interconnection Customer has contracted for delivery service on the Affected System Operator's Transmission System. If the Interconnection Customer has not contracted for delivery service, and in the absence of another mutually agreeable payment schedule, refunds shall be provided by means of a uniform stream of monthly payments designed to fully reimburse the Interconnection Customer, with interest, over a five year period commencing with the Generating Facility's Commercial Operation Date.

739. When the Interconnection Customer is required to pay for Network Upgrades on an Affected System, it must enter into an agreement with the Affected System Operator unless the payments are incorporated in the interconnection agreement that the Interconnection Customer signs with the Transmission Provider. Any agreement with an Affected System Operator must specify the terms governing payments to be made by the Interconnection Customer as well as the payment of refunds by the Affected System Operator. The Commission is revising proposed Article 11.4.1 to incorporate this new requirement.

Policies Regarding Previously Approved Cost Allocations and Pricing Arrangements

740. A number of commenters express their views regarding the NOPR's proposal to require that all Transmission Providers remove from their transmission rates the costs of Interconnection Facilities constructed for the Transmission Provider's own Generating Facilities, and to treat them as directly assigned, generation-related costs. Commenters also address the possible retroactive application of the pricing policy adopted in the Final Rule. Calpine and Mirant request that the Commission require that all Transmission Owners make compliance filings to remove the costs of Interconnection Facilities from existing transmission rates. The Arkansas PSC states that it does not object in principle to the proposal to remove such costs from transmission rates, but notes that this could shift additional costs onto the retail customers of regulated generation-owning utilities. It

proposes that, if the cost-shifting burden is judged to be significant, a phase-in or modification may be appropriate. PSNM believes that the Commission's proposal to require all Transmission Providers to remove sole use facilities from their transmission rates currently in place resolves the lack of pricing comparability alleged by Interconnection Customers.

741. PJMTO generally agrees with the NOPR's proposal to assign to the generator the costs of Interconnection Facilities, but requests that the Commission clarify that, to the extent this policy alters existing practices, it will apply prospectively and only affect interconnections that post-date the Final Rule. PJMTO states that, historically, transmission providers have used a variety of approaches to assign cost responsibility for Interconnection Facilities, claiming that some have rolled these costs into transmission rates while others have directly assigned the costs to the Interconnection Customer. PJMTO urges the Commission not to undercut the business assumptions of existing project sponsors or to require the Transmission Provider to refile transmission rates to remove any non-network costs that have been rolled in, and invoice Interconnection Customers for such removed costs. Exelon and Sithe express similar views and state that, since Order No. 888, numerous vertically integrated utilities have spun off their Generation Facilities to non-affiliated third parties. Exelon and Sithe believe that those parties would likely claim that their interconnection arrangements have been effectively grandfathered and that no interconnection costs that may have been rolled into base transmission rates are now recoverable from them. Exelon and Sithe argue this could lead to costly and time-consuming litigation.

742. Calpine requests that the Commission find here that any policy that requires the Interconnection Customer to pay for Network Upgrades is unjust and unreasonable, and unless otherwise barred by explicit contract language, any Interconnection Customer should be permitted to have the facility cost allocation provisions of any existing agreement modified pursuant to Section 206 of the FPA to reflect the current interconnection pricing policies. However, Exelon and Sithe, using arguments similar to those above, recommend that any historical allocation of the costs of Network Upgrades that was agreed to by the parties and accepted by the Commission should not be disturbed now. Exelon and Sithe recommend that those costs be rolled into the transmission rate base only for new Interconnection Requests.

Commission Conclusion

743. The Commission believes that, to ensure fully comparable treatment of all Generating Facilities, transmission rates should not include the costs of Interconnection Facilities. As stated in the NOPR, this policy is consistent with the Commission's current treatment of generation step-up transformers, appropriately assigns the costs of Interconnection Facilities to the generation customers using them, and ensures that the Transmission Provider's own Generating Facilities and those of its competitors are treated comparably.

744. However, the Commission is sympathetic to the concern of PJMTO and Exelon and Sithe that the Transmission Provider may have difficulty recovering the costs

associated with Generating Facilities that it does not own, including those that it once owned but has since divested. Also, the Commission is concerned that the Transmission Provider may have difficulty identifying the interconnection-related costs of older Generating Facilities given that, historically, the Transmission Provider may have had no reason to segregate these costs from other transmission costs in its books of account. Therefore, the Commission is not adopting the NOPR's proposal to require the Transmission Provider to remove from its existing transmission rates the costs of all Interconnection Facilities constructed for its own Generating Facilities and to directly assign them as generation-related costs. Rather, the Commission here is imposing a more limited requirement. The Commission is requiring that the Transmission Provider remove from transmission rates only the costs of Interconnection Facilities constructed by the Transmission Provider after a date certain to interconnect Generating Facilities owned by the Transmission Provider on the effective date of this Final Rule. That date certain is March 15, 2000, the date on which the Commission issued its order in Tennessee clarifying that interconnection is a separate component of transmission service, and that an Interconnection Customer may request interconnection separately from the delivery component of transmission service. That order effectively placed Transmission Providers on notice that the costs of Interconnection Facilities cannot be recovered in rates for transmission service. Thus, the Commission presumes that after March 15, 2000, any Interconnection Agreement signed by the Transmission Provider provides for the direct assignment of Interconnection Facility costs to the Interconnection Customer. The Commission also presumes that the Transmission Provider can identify the costs of any Interconnection Facilities constructed for its own Generating Facilities after March 15, 2000. In this Final Rule, the Commission is requiring the Transmission Provider, in its next filed transmission rate case, to remove such costs from transmission rates.

745. With regard to the Arkansas PSC's concern about the impact of any cost shifting that may result from the reallocation of Interconnection Facility costs, we do not believe that the impact will be so great as to warrant a phase-in. Because the requirement that we are adopting here applies only to costs incurred after March 15, 2000, we expect the cost impact, if any, to be small. Furthermore, any cost impact will not occur until the Transmission Provider's next filed rate case.

746. Finally, in response to Calpine, the Commission is not requiring in this Final Rule any changes to previously accepted interconnection agreements.

Miscellaneous Pricing Issues

747. Dynegy argues that Article 4.6 of the NOPR LGIA should be clarified to include a more comprehensive listing of the possible services that the Interconnection Customer might be called upon to provide to the Transmission Provider under the express provisions of the LGIA. Dynegy submits that the Interconnection Customer would be required to have a Tariff on file with the Commission pursuant to Section 205 of the Federal Power Act for any service for which it seeks to charge the Transmission Provider. In the alternative, it recommends that the Commission clarify that this

provision does not require the Interconnection Customer to forego the right to seek compensation for any services beyond the two listed.

748. ACEEE states that it agrees with the Commission's general proposal on pricing, but identifies pricing issues faced by the Interconnection Customer that it believes can pose major barriers to interconnection. It claims that excessive standby charges, backup power rates, and insurance requirements have frequently been used to try to block an Interconnection Customer from interconnecting a new Generating Facility and competing on a comparable basis. It states that the Commission and others must address these pricing issues if electricity markets are to be fully accessible.

Commission Conclusion

749. In response to Dynegy, the Commission clarifies that, while Articles 4.6 and 11.6 of the Final Rule LGIA provide that the Transmission Provider must compensate the Interconnection Customer for certain specific services that the latter provides, no provision of the Final Rule LGIA limits the right of the Interconnection Customer to seek compensation for any other services that the Transmission Provider may from time to time request from the Interconnection Customer.

750. With regard to ACEEE's concerns about the rates for standby charges and backup power rates provided by the Transmission Provider to the Interconnection Customer, the rates for these services are a state jurisdictional retail rate issue. The Commission discusses insurance requirements in Part II.C.8.a of this Preamble.

2. Interconnection Products and Scope of Service

751. Scope of service, including in particular the definition and study requirements for the two Interconnection Service products proposed to be made available to Interconnection Customers, was perhaps the most heavily debated topic during the ANOPR phase of this proceeding. In addition, the controversial nature of this topic is reflected in the many pages that commenters devoted to it. These comments are addressed below.

Definition of Interconnection Products

752. The LGIA NOPR provided for two Interconnection Service products from which the Interconnection Customer would have to choose: Energy Resource Interconnection Service, which is a basic or minimal interconnection service, and Network Resource Interconnection Service, which is a more flexible and comprehensive interconnection service.¹¹⁹ Neither is a transmission delivery service. Article 4 (Scope of Service) of the NOPR LGIA defines these products and sets forth specific Interconnection Study requirements for each. This article also describes the relationship between delivery

¹¹⁹During the ANOPR negotiating sessions EPSA and other Interconnection Customers negotiated to secure these two forms of service.

service and the Interconnection Services, as well as the rights and responsibilities that each Interconnection Service entails. In addition, Section 3.2 of the NOPR LGIP sets forth the procedure that the Interconnection Customer must use to select an Interconnection Service.

753. As proposed, Energy Resource Interconnection Service would allow the Interconnection Customer to connect its Generating Facility to the Transmission System and be eligible to deliver its output using the existing firm or non-firm capacity of the Transmission System on an "as available" basis. In an area with a bid-based energy market (e.g., ISO New England, NYISO, or PJM), Energy Resource Interconnection Service would allow the Interconnection Customer to place a bid to sell into the market and the Generating Facility would be dispatched if the bid is accepted. In all other areas, no transmission delivery service would be assured, but the Interconnection Customer may obtain point-to-point transmission service or gain access to secondary network transmission service, pursuant to the Transmission Provider's Tariff. The Interconnection Studies to be performed for Energy Resource Interconnection Service would identify the Interconnection Facilities required as well as the Network Upgrades needed to allow the proposed Generating Facility to operate at full output. In addition, the Interconnection Studies would identify the maximum allowed output of the Generating Facility without Network Upgrades.

754. In contrast, Network Resource Interconnection Service would require the Transmission Provider to undertake the Interconnection Studies and Network Upgrades needed to integrate the Generating Facility into the Transmission System in a manner comparable to that in which the Transmission Provider integrates its own generators to serve native load customers. If the Transmission Provider is an RTO or ISO with market-based congestion management, it would have to integrate the Generating Facility in the same manner as all other Network Resources.

755. The Transmission Provider would study the Transmission System at peak load, under a variety of severely stressed conditions, to determine whether, with the Generating Facility at full output, the aggregate of generation in the local area can be delivered to the aggregate of load, consistent with the Transmission Provider's reliability criteria and procedures. Under this approach, the Transmission Provider would assume that some portion of the capacity of existing Network Resources is displaced by the output of the new Generating Facility.

756. Network Resource Interconnection Service provides for all of the Network Upgrades that would be needed to allow the Interconnection Customer to designate its Generating Facility as a Network Resource and obtain Network Integration Transmission Service. Thus, once an Interconnection Customer has obtained Network Resource Interconnection Service, any future transmission service request for delivery from the Generating Facility would not require additional studies or Network Upgrades. However, Network Resource Interconnection Service itself does not convey any delivery service and the Interconnection Customer would not be required to identify a specific buyer (or sink). If the Interconnection Customer wishes to obtain the delivery

component of transmission service, it would have to do so pursuant to the Transmission Provider's Tariff.

757. Requests for long-term transmission service for deliveries outside the Transmission Provider's system may require additional Interconnection Studies and Network Upgrades. Network Resource Interconnection Service would allow the Generating Facility to be used to provide Ancillary Services and, should the Transmission System become congested, the Generating Facility would be subject to the same congestion management procedures that apply to all other Network Resources. Article 4.1.2.3 of the NOPR LGIA states that "[d]epending on how the cost allocation issue is resolved, the [Interconnection Customer] may be allocated congestion rights based on the construction of upgrades."

758. Proposed LGIA Article 4.3 also provides for generator balancing service arrangements and refers to other articles that address payment for certain services provided by the Interconnection Customer.

Comments

759. Several commenters, primarily Transmission Providers, object to the proposed requirement that Interconnection Customers be allowed to request Network Resource Interconnection Service. NRECA-APPA and others argue that, contrary to the Commission's assertion, Network Resource Interconnection Service would convey transmission delivery rights to the Interconnection Customer in the form of a permanent right to the future use of the Transmission System's delivery capacity. APS contends that Network Resource Interconnection Service would provide delivery service rights that are greater than any available under Order No. 888, and claims that Network Resource Interconnection Service may require a Transmission Provider to expand transmission capacity beyond any foreseeable needs of network load and to hold that capacity indefinitely. LG&E Energy believes that Network Resource Interconnection Service could result in substantial overbuilding of the Transmission System as a result of the requirement that transmission be upgraded to accommodate any Interconnection Customer taking Network Resource Interconnection Service to serve any load on the system. However, TAPS is concerned that Network Resource Interconnection Service does not provide for the capacity expansions that may be needed to allow network customers to access their Network Resources without congestion. It claims that the NOPR's treatment of Network Resource designation and network service is inconsistent with the OATT Network Integration Transmission Service, which requires a demonstration of load-specific deliverability from designated Network Resources. TAPS states that Network Resource Interconnection Service lacks such a deliverability test and, as a result, would be a service under which the Network Resource designation is meaningless from a load serving entity's point of view. It claims that while Network Resource Interconnection Service would grant some rights to the Interconnection Customer, it leaves the load serving entity to bear all the risk of congestion between its Network Resources and its load.

760. PSNM notes that for an Interconnection Customer to secure delivery rights using Network Integration Transmission Service under the OATT, the Generating Facility must be designated as a Network Resource. The Interconnection Customer also must pay separately for point-to-point service when not providing service as a Network Resource. PSNM claims that the language in the NOPR LGIA would undo that requirement. Western objects to the fact that Network Resource Interconnection Service would impose no obligation on an Interconnection Customer to serve network load or to meet network operating obligations, such as providing Ancillary Services, and would not require an Interconnection Customer to participate in regional planning processes. Dairyland Power states that Article 4.1.2 of the NOPR LGIA seems to presuppose that Network Resource Interconnection Service may be used only in conjunction with Network Integration Transmission Service under the OATT, but the LGIA is not explicit. It asks the Commission to clarify the purpose of Network Resource Interconnection Service and how it may actually be used.

761. Central Maine claims that the exact products or services required to be offered are not clearly defined. Industrial Energy asserts that the acknowledgment of potential congestion in the Network Resource Interconnection Service description seems to contradict the further specifications in proposed LGIA Article 4.1.2.3, which appears to contemplate delivery from the Generating Facility within the Transmission Provider's Transmission System of any amount of capacity and/or energy up to the amount initially studied without additional studies or Network Upgrades. TANC recommends that the Commission replace the study provision requiring displacement of existing generation (NOPR LGIA Article 4.1.2.2) with appropriate technical guidelines and procedures for identifying resource displacement.

762. LG&E Energy claims that the proposal is inconsistent with the Commission's proposed approach to Standard Market Design. It notes that the market designs of certain ISOs permit customers to designate any resource as a Network Resource, but do not require the Transmission System to be upgraded to ensure physical delivery of all generation resources to all loads. Rather, according to LG&E Energy, the effect of transmission congestion is reflected in locational energy prices. Also, the Midwest ISO states that it is not clear how Network Resource Interconnection Service would evolve as Standard Market Design is implemented. It believes that Network Resource Interconnection Service is more appropriate for an Interconnection Customer that wishes to designate its Generating Facility as a capacity resource in a market design where there is a capacity market. If there is not such a market, the Midwest ISO would support Energy Resource Interconnection Service alone as sufficient to provide for reliable interconnections, and allow for market-based mechanisms to support expansion of the Transmission System beyond minimum reliability needs. Both the Wisconsin PSC and American Wind Energy advise the Commission to defer consideration of Network Resource Interconnection Service until it can be evaluated in the context of Standard Market Design. Dairyland Power states that it is not clear how Network Resource Interconnection Service would fit with the new Network Access Service contemplated in the Commission's Standard Market Design rulemaking.

763. Some commenters argue that there should be only one interconnection product and that product should define a minimum level of service. For example, ISO New England believes that its Minimum Interconnection Standard has resulted in equal treatment of new and incumbent generation owners and has resulted in a substantial number of new generators being interconnected onto the bulk power Transmission System in New England. It also states that the Minimum Interconnection Standard allows every generator owner, new and incumbent alike, the opportunity to participate in all markets.

764. PG&E notes that, while Network Resource Interconnection Service requires the Transmission Provider to interconnect new plants in a manner comparable with that of other Network Resources, in California there are no Network Resources. PG&E asks the Commission to explain how this Interconnection Service would apply in areas where no network transmission service is available. Central Maine argues that the definition of products and services should be left to regional practices.

765. Xcel states that the description of Network Resource Interconnection Service appears to assume the Transmission Provider's system is the same as its Control Area. However, with the development of large transmission networks subject to an RTO's OATT, it may not be possible to actually deliver the capacity and energy of any individual generator to a network load on a huge regional network. The Midwest ISO recommends that, if Network Resource Interconnection Service is retained as part of the Final Rule, an Interconnection Customer within a large footprint RTO like the Midwest ISO should be allowed to select specific zones (or Control Areas) in which it would be eligible to be a designated Network Resource.

Commission Conclusion

766. Article 4 of the NOPR LGIA did not adequately convey the Commission's intent, particularly with regard to the characteristics that distinguish the two proposed interconnection products and the rights and responsibilities that each entails. Many of the commenters' concerns can be addressed by improving the clarity and accuracy in the Final Rule provisions concerning scope of services and interconnection products. Therefore, as described below, the Commission modifies the text of proposed LGIA Article 4 and provides the following clarifications.

767. Both Energy Resource Interconnection Service and Network Resource Interconnection Service provide for the construction of Network Upgrades that would allow the Interconnection Customer to flow the output of its Generating Facility onto the Transmission Provider's Transmission System in a safe and reliable manner. However, contrary to the assertions of several commenters, neither Energy Resource Interconnection Service nor Network Resource Interconnection Service in and of itself conveys the right to do so. Moreover, neither type of Interconnection Service constitutes a reservation of

transmission capacity. The Interconnection Customer, load or other market participant would have to request either point-to-point or Network Integration Transmission Service under the Transmission Provider's OATT in order to receive the delivery service that is a prerequisite to flowing power onto the system. When an Interconnection Customer that has chosen either Energy Resource Interconnection Service or Network Resource Interconnection Service later requests firm point-to-point delivery service, additional Network Upgrades may be required, depending on the availability of transmission capacity to deliver power to the delivery point.

768. Network Resource Interconnection Service is intended to provide the Interconnection Customer with an interconnection of sufficient quality to allow the Generating Facility to qualify as a designated Network Resource on the Transmission Provider's system without additional Network Upgrades. This means that Network Resource Interconnection Service entitles the Generating Facility to be treated in the same manner as the Transmission Provider's own resources for purposes of assessing whether aggregate supply is sufficient to meet aggregate load within the Transmission Provider's Control Area, or other area customarily used for generation capacity planning. Thus, with Network Resource Interconnection Service, the Interconnection Customer would be eligible to obtain Network Service under the Transmission Provider's OATT, or network access service under the Tariff of an RTO or ISO, without the need for additional Network Upgrades.

769. However, contrary to the views of some commenters, Network Resource Interconnection Service does not necessarily provide the Interconnection Customer with the capability to physically deliver the output of its Generating Facility to any particular load on the system without incurring congestion costs. Depending on the location of the load for which the Generating Facility serves as a designated Network Resource, it may be required to participate in a redispatch procedure, or other non-discriminatory congestion management process, such as locational marginal pricing. Network Upgrades required under Network Resource Interconnection Service integrate the Generating Facility into the Transmission System in a manner that ensures that aggregate generation can meet aggregate load while satisfying regional reliability criteria and generation capacity planning requirements. However, these upgrades do not necessarily eliminate congestion.

770. In response to ISO New England and the Midwest ISO, the Commission is not limiting the Interconnection Customer's interconnection alternatives to a single option that meets only a minimum interconnection standard. In general, such a policy would not provide an interconnection that meets the standard that the Transmission Provider uses to interconnect its own generators. The Commission notes, however, that in regions where the Transmission System is operated by an independent entity, the Commission allows flexibility, as discussed in Part II.C.1 (Interconnection Pricing Policy). For example, an independent entity may determine, subject to Commission approval, that the designation of Network Resources is not necessary (which, PG&E points out, is the case in California).

771. The Commission recognizes that the Transmission Provider's Transmission System may not comprise a single Control Area, as several commenters point out. If the Transmission Provider operates more than one Control Area, it may limit the network service that is available to an Interconnection Customer taking Network Resource Interconnection Service to the Control Area where the Generating Facility is located. If the Interconnection Customer wishes to serve load in another Control Area, it must submit a separate request for transmission service to that other area, and it would be subject to the pricing provisions of the Transmission Provider's OATT for that service.

772. The Commission further clarifies that, if the Generating Facility of an Interconnection Customer taking Network Resource Interconnection Service is selected by a load as a designated Network Resource, it will be required to meet all network operating obligations that the OATT imposes upon Network Resources generally. If an Interconnection Customer's Generating Facility has not been designated as a Network Resource by any load, it cannot be required to provide Ancillary Services except to the extent such requirements extend to all generators that are similarly situated.

773. Finally, in response to Dairyland Power and others, the Commission notes that an RTO or ISO may propose in its tariff filing to modify the definition and scope of the available interconnection products to accommodate its market.

Pricing of Network Resource Interconnection Service

774. Some commenters express concern over the application of the proposed interconnection pricing policy to Network Resource Interconnection Service. For example, Progress Energy and the Alabama PSC believe that an Interconnection Customer taking Network Resource Interconnection Service should pay a reservation charge for reserved but unused transmission capacity on the Transmission Provider's Transmission System. Progress Energy believes that such an approach would properly allocate the cost of the transmission capacity being reserved for the Interconnection Customer until a customer actually begins paying for transmission service for output from the Interconnection Customer's Generating Facility.

775. Entergy states that the requirement that a Transmission Provider offer Network Resource Interconnection Service should not be included in the Final Rule until the Commission has thoroughly analyzed the effects of providing such service. If this service is required, however, Entergy recommends that a Transmission Provider be compensated by any Interconnection Customer electing this service, as the service prevents a Transmission Provider from achieving the maximum use of its Transmission System due to the standing transmission reservation that it claims is granted to an Interconnection Customer under this service. The Coalition for Pricing recommends that the Interconnection Customer be required to commit to pay for Network Resource Interconnection Service for a specific term long enough to protect other customers from economic harm. It further recommends that, if the Interconnection Customer is not required to commit to a specific term of Network Resource Interconnection Service, it should at a minimum be required to pay some amount up front to cover ongoing expenses associated with the upgrades constructed if service is cancelled after a short time.

776. NRECA-APPA states that coupling Network Resource Interconnection Service with the Commission's current interconnection pricing policy will cause customers to bear much of the cost of Network Upgrades while having no right to use the resulting transmission delivery capability.

777. However, American Transmission opposes any special charges for Network Resource Interconnection Service and believes that commenters' criticisms that this service confers too great an advantage on the new Interconnection Customer are overstated. It believes the provision should be designed to put the independent generation owner on a competitive footing equal to that of incumbent owners. If the Commission is persuaded that the proposed policy provides an undue advantage to the new Interconnection Customer, the solution lies in adjusting the service description, not in imposing a surcharge.

Commission Conclusion

778. The Commission is not requiring the Interconnection Customer to pay a reservation fee for the delivery component of transmission service as a condition for receiving Network Resource Interconnection Service. As explained above, Network Resource Interconnection Service does not convey to the Interconnection Customer a reservation of transmission capacity or the right to begin taking firm or non-firm transmission service on the Transmission Provider's system. Rather, its purpose, as stated in proposed LGIA Article 4.1.2.1, is to provide the Network Upgrades needed to integrate the Interconnection Customer's Generating Facility into the Transmission System in a manner that is comparable to that in which the Transmission Provider integrates its own resources or other Network Resources. When the Interconnection Customer does take transmission service, it (or its power sales customer) will be required to pay appropriate rates, subject to the crediting provisions of Article 11.4 of the Final Rule LGIA. To charge the Interconnection Customer an additional reservation fee, as several commenters propose, would violate the Commission's prohibition against "and" pricing. Nevertheless, Network Resource Interconnection Service does not guarantee that the Interconnection Customer can physically deliver its output to any load. This means that, depending on the location of its power sales customer, the Interconnection Customer may be required to pay congestion or redispatch costs.

779. Finally, in response to NRECA-APPA, the Commission emphasizes that any capacity created by the Network Upgrades constructed on the Interconnection Customer's behalf is available for use by all customers on an equal basis. The Final Rule only requires that, once the Interconnection Customer has paid for the Network Upgrades needed to integrate its Generating Facility, it cannot be charged again for any additional upgrades that may be needed to continue to qualify as a Network Resource.

Study Requirements for Network Resource Interconnection Service

780. Article 4.1.2.2 of the NOPR LGIA described the Interconnection Study procedures for Network Resource Interconnection Service. Among other things, they would require the Transmission Provider to study the Transmission System at peak load, under a variety

of severely stressed conditions, to determine whether, with the Generating Facility at full output, the aggregate of generation in the local area can be delivered to the aggregate of load, consistent with the Transmission Provider's reliability criteria and procedures.

Comments

781. PG&E states that it does not understand the difference between the study requirements for Energy Resource Interconnection Service and Network Resource Interconnection Service. For Network Resource Interconnection Service, the NOPR LGIA says that the study must be done with the system at peak load and under a variety of severely stressed conditions, but PG&E claims that it is not clear that any lesser study would be necessary for Energy Resource Interconnection Service.

782. Cal ISO states that it is essential that all studies consider off-peak operating periods with the Generating Facility at full output. It argues that, during light load periods, the energy generated is not consumed locally and has to be transmitted over longer distances, possibly causing overloads that would not be revealed by studying only on-peak periods. Therefore, Cal ISO recommends replacing "at peak load, under a variety" with "at peak load and under a variety." NERC recommends several changes in NOPR LGIA Article 4.1.2.2, including replacing "at peak load, under a variety of severely stressed conditions" with "under a set of reasonably expected limiting conditions." It states that studying interconnection impacts only under conditions of system peak load and the Generating Facility's peak output may overlook the study of other conditions that could be unsafe. NERC asserts that use of the term "limiting conditions" provides the flexibility to incorporate studies that are necessary to ensure reliability.

Commission Conclusion

783. The study requirements for Energy Resource Interconnection Service and Network Resource Interconnection Service are set forth in Sections 3.2.1 and 3.2.2 of the Final Rule LGIP.

784. In response to PG&E, the principal difference between the study requirements for Energy Resource Interconnection Service and Network Resource Interconnection Service is that the study for Network Resource Interconnection Service identifies the Network Upgrades that are needed to allow the Generating Facility to contribute to meeting the overall capacity needs of the Control Area or planning region whereas the study for Energy Resource Interconnection Service does not. The study for Energy Resource Interconnection Service includes short circuit/fault duty, steady state (thermal and voltage) and stability analyses to identify the Network Upgrades needed to allow the output of the Generating Facility to be injected into the Transmission System using capacity on an "as available" basis. By contrast, the study for Network Resource Interconnection Service includes similar analyses but also assumes that the output of the Generating Facility may displace the output of certain other Network Resources on the Transmission System. The study then identifies the Network Upgrades that would be required to allow the Generating Facility to be counted toward system capacity needs in the same manner as the displaced resources. However, the Interconnection Customer may

request that Optional Studies be performed, and Section 3.2 of the Final Rule LGIP allows the Interconnection Customer then to proceed with Network Resource Interconnection Service or to request a lower level of interconnection service whereby only certain upgrades will be completed.

785. With regard to the changes to Article 4.1.2.2 of the LGIA recommended by NERC and Cal ISO, we note that this provision is intended to serve two purposes. First, it establishes the standards for conducting necessary studies to provide the requested service while ensuring that the reliability of the system is maintained. Second, it deters a Transmission Provider from delaying an interconnection by imposing on competing Interconnection Customers, in the name of reliability, more stringent Interconnection Study requirements than it would require of its own interconnections or those of its Affiliates. Because NERC's and Cal ISO's proposals satisfy only the reliability purpose, the Commission does not adopt them. Our requirement that the interconnection be studied with the Transmission Provider's Transmission System at peak load, under a variety of severely stressed conditions, is comparable, we believe, to the study requirement that the Transmission Provider applies to its own generation. However, we are sympathetic to NERC's and Cal ISO's concerns. Therefore, the Commission would entertain a request, in a non-independent Transmission Provider's compliance filing required by this Final Rule, to adopt a different requirement (e.g., off-peak load in addition to peak load) if the non-independent Transmission Provider can demonstrate that the proposed requirement is consistent with or superior to the requirement of the Final Rule LGIP. At a minimum, the Transmission Provider must demonstrate that it consistently applies the proposed requirement in the studies it conducts for itself and its Affiliates. As discussed below in Part II.C.5 (Variations from the Final Rule), we will allow an RTO or ISO to seek an "independent entity variation" from the Final Rule LGIP if it wants to adopt a different study requirement.

Identification of Types of Interconnection Services to be Studied

786. According to Section 3.2 of the NOPR LGIP, when the Interconnection Customer submits its Interconnection Request, it would be required to identify the type of Interconnection Service it wants. However, an Interconnection Customer requesting Network Resource Interconnection Service would have the option of requesting that its Interconnection Request also be studied for the less comprehensive Energy Resource Interconnection Service up to the point when an Interconnection Facilities Study Agreement is executed.

Comments

787. Several commenters state that allowing the Interconnection Customer to request that its Interconnection Request be studied for both Network Resource Interconnection Service and Energy Resource Interconnection Service concurrently will unnecessarily tax the Transmission Provider's resources and increase the burden of performing the studies. Entergy and BPA believe that this option will unnecessarily delay the conduct of studies for third party interconnections unless the Interconnection Customer is required to select the particular service under which it will interconnect prior to the execution of an

Interconnection System Impact Study Agreement. Entergy states that such a limitation would not unduly disadvantage the Interconnection Customer, but would further ensure that a Transmission Provider's limited transmission planning resources are used to perform studies for interconnections that are likely to be completed. NYTO believes that the additional study work required to conduct concurrent studies is not accounted for in the Interconnection Feasibility, System Impact or Facilities Study sections of the NOPR LGIP. It states that additional time would be required to conduct the concurrent studies if the Transmission Provider is required to offer this option. Also, Cal ISO asks whether two deposits will be required if an Interconnection Customer requests that the Interconnection Request be studied as both Network Resource Interconnection Service and Energy Resource Interconnection Service.

788. BPA observes that the NOPR LGIP included very strict timelines for completion of various studies and provided for no meaningful milestones or other means by which the Transmission Provider can ensure that only bonafide Interconnection Requests remain in the queue. It states that this places a Transmission Provider with a large number of Interconnection Requests in a very difficult position, and the more concurrent studies the Interconnection Customer can require the Transmission Provider to perform on a single request, the more difficult this position becomes. BPA believes that requiring concurrent studies is purely for the convenience of the Interconnection Customer, and that it is not unreasonable to require the Interconnection Customer to choose early in the process what kind of resource it intends to develop.

789. Georgia Transmission believes that it is appropriate to allow the Interconnection Customer to request concurrent studies throughout the Interconnection Feasibility Study stage, but allowing the parallel studies to continue beyond that point simply gives the Interconnection Customer more time to decide what type of Interconnection Service product to contract for, while greatly increasing the study burden on the Transmission Provider. Georgia Transmission claims that the Interconnection System Impact Study is a much more complex and involved study than the Interconnection Feasibility Study. Further, to accommodate the Interconnection Customer's desire to study multiple Interconnection Service products, Georgia Transmission claims that the Transmission Provider must conduct multiple studies not only for the first Interconnection Customer, but for all other Interconnection Customers proceeding through the interconnection process to reflect the multiple service characteristics of the first Interconnection Customer. If these other Interconnection Customers also request the Transmission Provider to concurrently study multiple service options, the Transmission Provider study burden "quickly snowballs out of control."¹²⁰ At this stage of the Interconnection Study process, the cost of studying the multiple service options greatly outweighs the benefits to the Interconnection Customer.

790. TVA argues that allowing an Interconnection Customer to request that the Transmission Provider study both types of Interconnection Services may double the work of the Transmission Provider at each stage up to the Interconnection Facilities Study

¹²⁰Comments of Georgia Transmission at 18.

stage. It finds this troubling in light of the NOPR's proposed milestones frames and the possibility of the Transmission Provider having to pay liquidated damages for failure to meet the deadlines.

791. Interconnection Customers, however, express very different views. For example, Tenaska states that the choice between Network Resource Interconnection Service and Energy Resource Interconnection Service will be dictated by the Interconnection Customer's wholesale power customer. It argues that marketing efforts for new generation projects are not completed until late in the development process, making it impossible for the Interconnection Customer to know with certainty which service is requires. Tenaska asks that the Interconnection Customer be afforded maximum flexibility to choose between the two interconnection Services and recommends that, instead of making the Interconnection Customer choose prior to executing the Interconnection Facilities Study Agreement, the Final Rule LGIP should allow the Interconnection Customer to defer its choice until the execution of the interconnection agreement.

Commission Conclusion

792. While conducting complex Interconnection Studies can be burdensome for the Transmission Provider, the Commission is not amending NOPR LGIP Section 3.2 to eliminate the Interconnection Customer's option to have its request studied as Energy Resource Interconnection Service as long as it has also requested to be studied as Network Resource Interconnection Service. This is a valuable option for the Interconnection Customer because it provides key information to support its investment decisions, and thus helps to meet the Commission's goal of encouraging the development of new generation.

793. The Commission also recognizes that the Interconnection System Impact Study is more complex than the Interconnection Feasibility Study. However, the Commission does not believe that it would be reasonable to require the Interconnection Customer to choose between the two services prior to executing the Interconnection System Impact Study Agreement, as several commenters propose. Once the Interconnection Customer has asked to be studied for Network Resource Interconnection Service, a service that is far more comprehensive than Energy Resource Interconnection Service, the incremental burden created by also having to conduct an Interconnection System Impact Study for the simpler Energy Resource Interconnection Service should not be great. It is for this reason that the Commission disagrees with Georgia Transmission's contention that having to study multiple options will have a significant snowball effect on the overall study burden. Moreover, the Transmission Provider will be fully compensated for all of the costs that it incurs in conducting a more expansive study. As for the risk that the Transmission Provider faces by allowing the Interconnection Customer to make this choice, such risk is

mitigated by the fact that the Commission is not making the Transmission Provider subject to liquidated damages under the Final Rule LGIP.¹²¹

Revisions to the Final Rule LGIP and Final Rule LGIA

794. In the Final Rule, the Commission is modifying various provisions of the NOPR LGIP and NOPR LGIA to provide greater clarity and to make other minor changes with respect to scope of service and interconnection products, as discussed above. In addition, the Commission is incorporating in the Final Rule LGIP certain provisions concerning product definitions and study requirements that were included in the NOPR LGIA but not the NOPR LGIP. These provisions are being added to the Final Rule LGIP because they directly relate to the process of obtaining an interconnection. They appear as new Sections 3.2.1 and 3.2.2 in the Final Rule LGIP.

3. "Distribution" Interconnections

795. We proposed in the NOPR¹²² that we would assert authority to order interconnection when the Interconnection Customer wants to interconnect its Generating Facility with a jurisdictional transmission facility, or when it will make a wholesale sale of electric energy in interstate commerce using a public utility's "distribution" facilities.

Comments

796. Commenters objecting to the Commission's jurisdictional statement – chiefly Transmission Providers, public power providers, and state public utility commissions¹²³ – argue that "distribution" interconnection raises complex jurisdictional issues and that the Commission should leave this issue to the States, in part because they have experience regulating these kinds of interconnections. EEI notes that it is unclear if the Commission has authority over sales of power for resale using "distribution" facilities when the energy neither crosses state lines nor enters the interstate transmission system. The Public Power Council asks the Commission to recognize the jurisdiction of state commissions and local governing boards over the "distribution" systems of investor-owned and publicly owned utilities. SoCal Edison and PG&E ask the Commission to clarify that when a retail customer installs a generating facility that will never send energy over the Transmission System (*i.e.*, the energy will be consumed on site), this is a retail service arrangement beyond Commission jurisdiction.

797. The North Carolina Commission argues that, because it has not restructured its electric industry, any generating facility in North Carolina not owned by a vertically

¹²¹Liquidated damages in the LGIP are further discussed in Part II.C.8.b(4).

¹²²See Large Generator Interconnection NOPR, FERC Stats. & Regs. ¶ 32,560 at 34,178 & n.22 (2002).

¹²³*E.g.*, Consumers, EEI, LADWP, National Grid, the North Carolina Commission, NRECA-APPA, the Public Power Council, and the Wisconsin PSC.

integrated utility would be required to sell its output at wholesale (because it cannot sell directly to retail consumers). As a result, the NOPR effectively eliminates state jurisdiction over the interconnection of generators involved in programs such as net metering or green power, which rely on simpler and less expensive interconnection procedures and agreements than those proposed by the Commission. These interconnection decisions are best left to the States.

798. APS notes that the NOPR does not address how Transmission Providers will handle their responsibilities over transmission facilities jointly owned by jurisdictional and non-jurisdictional entities. This is a particular concern in the Western United States. APS warns that the failure to examine this issue in a separate NOPR will result in a patchwork of transmission terms and conditions that the Commission sought to avoid in Order No. 888.¹²⁴

799. EEI raises other objections, noting that Commission regulation of "distribution" interconnections may create new layers of regulatory costs that will not be recoverable in retail rates. It also warns that competing and possibly conflicting state and federal interconnection requirements may encourage forum-shopping by Interconnection Customers and create problems for "distribution" providers. To discourage this, National Grid proposes that an Interconnection Customer should state whether it will make sales for resale before the Scoping Meeting provided for in Section 3.3.4 of the proposed LGIP; this will determine how the Interconnection Studies will be performed. Once established, the designation could not be changed unilaterally by the Interconnection Customer.

800. NRECA-APPA argues that, because "distribution" systems do not operate like Transmission Systems, "distribution" interconnections will require provisions not in the NOPR LGIP and NOPR LGIA, including different Interconnection Study requirements. It argues that the physical differences and economic differences between interconnection at "distribution" and transmission levels – distribution is typically "low voltage" and transmission typically is "high voltage," and "distribution" providers may lack engineering personnel necessary to evaluate Interconnection Requests – would make a single rule completely inappropriate. WEPCO argues that the NOPR LGIP and NOPR LGIA are unworkable for interconnections to the "distribution" system because "distribution" companies serve load and "distribution" systems are not designed to accommodate large generation facilities seeking to move energy off the "distribution" system. Accordingly, the Commission should clarify that the principles underlying the Final Rule LGIP and Final Rule LGIA, *i.e.*, nondiscriminatory access and comparable treatment, will be applicable to both "distribution" and transmission, but that the documents will apply only to transmission level interconnections. State-approved tariffs should govern "distribution"-level interconnections. Nevertheless, an Interconnection Customer interconnecting to a "distribution" system still would be entitled to petition the Commission if it encountered undue discrimination.

¹²⁴Citing Order No. 888, FERC Stats. & Regs. ¶ 31,036 at 31,673.

801. Consumers sees a useful analogy in the Commission's natural gas regulations. It argues that the Commission should consider adopting an approach like the blanket certificate program applied to natural gas pipelines for incidental jurisdictional uses of non-jurisdictional transportation facilities. The goal of the Commission's blanket certificate program¹²⁵ is to remove restraints on the flow of gas between the interstate and the intrastate market. It allows entities that are otherwise state-jurisdictional to perform incidental Commission-jurisdictional activities without subjecting them, or their incidental interstate activities, to full Commission regulation.

802. NARUC states that it "supports the Commission's statement that the NOPR [LG]IA and [LG]IP 'will apply only when a generator interconnects to the Transmission Provider's transmission system or makes wholesale sales in interstate commerce at either the transmission or distribution voltage level,'" but argues that the States "are best situated to ensure the efficient, reliable and safe interconnection of small generators to local distribution systems and should continue to have that authority, as the NOPR recognizes."¹²⁶ TAPS supports Commission jurisdiction over the interconnection of generators used for wholesale sales, whether the interconnection is made to transmission or "distribution," because such application is essential to prevent evasion of the intent of the NOPR to provide non-discriminatory interconnection service, and should encompass wholesale interconnections to the Distribution Systems of large jurisdictional utilities that have divested their transmission facilities to an independent transmission company or the like.

Commission Conclusion

803. At the outset, it is important to clarify several terms when discussing the question of jurisdiction. "Local distribution" is a legal term; under FPA Section 201(b)(1), the Commission lacks jurisdiction over local distribution facilities.¹²⁷ "Distribution" is an unfortunately vague term, but it is usually used to refer to lower-voltage lines that are not networked and that carry power in one direction. Some lower-voltage facilities are "local distribution" facilities not under our jurisdiction, but some are used for jurisdictional service such as carrying power to a wholesale power customer for resale and are included in a public utility's OATT (although in some instances, there is a separate OATT rate for using them, sometimes called a Wholesale Distribution Rate).

804. This Final Rule applies to interconnections to the facilities of a public utility's Transmission System that, at the time the interconnection is requested, may be used either to transmit electric energy in interstate commerce or to sell electric energy at wholesale in

¹²⁵ 18 CFR 284.224 (2003).

¹²⁶ NARUC comments at 5 (citation omitted) (emphasis added by NARUC).

¹²⁷ 16 U.S.C. 824(b)(1) (2000).

interstate commerce pursuant to a Commission-filed OATT.¹²⁸ In other words, the standard interconnection procedures and contract terms adopted in this Final Rule apply when an Interconnection Customer that plans to engage in a sale for resale in interstate commerce or to transmit electric energy in interstate commerce requests interconnection to facilities owned, controlled, or operated by the Transmission Provider or the Transmission Owner, or both, that are used to provide transmission service under an OATT that is on file at the Commission at the time the Interconnection Request is made. Therefore, the Final Rule applies to a request to interconnect to a public utility's facilities used for transmission in interstate commerce. It also applies to a request to interconnect to a public utility's "distribution" facilities used to transmit electric energy in interstate commerce on behalf of a wholesale purchaser pursuant to a Commission-filed OATT. But where the "distribution" facilities have a dual use, *i.e.*, the facilities are used for both wholesale sales and retail sales, the Final Rule applies to interconnections to these facilities only for the purpose of making sales of electric energy for resale in interstate commerce.¹²⁹

805. In response to SoCal Edison and PG&E, we clarify that we are not asserting jurisdiction over a hook-up between a retail customer and a Transmission Provider when a retail customer installs a generator that will produce electric energy to be consumed only on site.

806. Regarding the arguments that the NOPR LGIP and NOPR LGIA are designed for interconnection to a transmission system and not a "distribution" system, we expect that the majority of interconnections to jurisdictional "distribution" or other jurisdictional low-voltage facilities will be made by generators no larger than 20 MW. These Small Generators will be interconnected using the standard procedures and agreement adopted in the Small Generator rulemaking. We are proposing rules in that proceeding to accommodate the interconnection of Small Generators, mostly to jurisdictional "distribution" (not "local distribution") and low-voltage facilities. However, in response to WEPCO's argument, we conclude that under some circumstances (*e.g.*, interconnection to facilities below 69 kV) the Interconnection Studies in the Final Rule LGIP may be inappropriate to analyze some Large Generator Interconnection Requests. In such a case,

¹²⁸For purposes of this paragraph, the term "Commission-filed OATT" means a tariff that is on file at, and has been approved by, the Commission.

¹²⁹The Commission will exercise exclusive jurisdiction only over the Commission-jurisdictional service. *See* Laguna Irrigation District, 95 FERC ¶ 61,305 at 62,039 (2001) *aff'd sub nom.* Pacific Gas & Electric Co. v. FERC, 44 Fed. Appx. 170 (9th Cir. 2002); Tex-La Electric Cooperative of Texas, Inc., 67 FERC ¶ 61,019 at 61,055-56, *final order*, 69 FERC ¶ 61,269 (1994) (both noting that the Commission asserts jurisdiction over the service when the facilities are not purely "transmission" facilities). Accordingly, the Commission will continue to exercise exclusive jurisdiction over the rates, terms, and conditions of the Commission-jurisdictional service provided over the dual use "distribution" facility, but the Commission will not assert jurisdiction over all uses of that facility, because the regulation of "local distribution" of electricity to end users is reserved to the States.

we will allow the Transmission Provider to use modified Interconnection Studies, subject to Commission approval. The Commission expects that interconnection requests of this kind will be rare and, as a result, we do not at this time incorporate a standard study specifically designed for interconnections to low-voltage or "distribution" facilities into the Final Rule LGIP. Accordingly, a Transmission Provider may use the studies it deems appropriate to properly study the Interconnection Request, subject to Commission approval. The Commission therefore requires that a Transmission Provider, upon receipt of a request for jurisdictional interconnection to a jurisdictional "distribution" or low-voltage facility, file with the Commission an amendment to the LGIP in its OATT that describes the Interconnection Studies applicable to such requests.

807. APS raises concerns regarding joint ownership of transmission by jurisdictional and non-jurisdictional entities. In Order No. 888, the Commission required each public utility that owns an interstate transmission facility jointly with a non-jurisdictional entity to offer service over its share of the joint facility, even if the joint ownership contract prohibits service to third parties.¹³⁰ Applying the same principle here, joint ownership does not affect the Commission's authority to regulate the public utility. Accordingly, the Final Rule LGIP and Final Rule LGIA would apply to Interconnection Service provided by the public utility on its portion of a jointly owned facility.

808. Regarding EEI's comment about the Commission's authority over an interconnection for the purpose of making sales of electric energy for resale using "distribution" facilities when the energy neither crosses state lines nor enters the interstate transmission system, this question is moot because the Commission is not here extending its jurisdiction to any facility that is not already under its jurisdiction, pursuant to a Commission-filed OATT at the time the interconnection request is made.

809. Finally, regarding EEI's objection that Commission regulation of "distribution" interconnections may create new layers of regulatory costs not recoverable in retail rates, our jurisdiction discussion above clarifies that because this Final Rule applies only where the Commission already has jurisdiction at the time interconnection is requested, this should not result in any new unrecoverable regulatory costs to a Transmission Provider.

4. Issues Relating to Qualifying Facilities

810. The NOPR did not address interconnection issues related to qualifying facilities (QFs) under the Public Utility Regulatory Policies Act of 1978 (PURPA).¹³¹ Nevertheless, several commenters bring QF-related issues to our attention.

¹³⁰ See Order No. 888, FERC Stats. & Regs ¶ 31,036 at 31,692; Order No. 888-A, FERC Stats. & Regs ¶ 31,048 at 30,219 (urging such public utilities to seek mutually agreeable revisions to their agreements with non-jurisdictional entities to permit third-party access to all, or at least the public utility share, of the facilities, and to file proposed revisions to such contracts with the Commission).

¹³¹ See 16 U.S.C. 2601 *et seq.* (2000).

Comments

811. Cal Cogen and ELCON recommend that the Commission allow a QF to request interconnection under state authority when it either sells the majority of its output under a PURPA-based power sales agreement, or does not sell power to the wholesale market. If the QF primarily generates electricity for sale in wholesale markets under non-PURPA agreements, they argue, the Final Rule should apply. Cal Cogen argues that this approach is in keeping with the Commission's Regulations, which give the States the responsibility for QF interconnections,¹³² and Commission precedent, which holds that an interconnection agreement in which an interconnected utility purchases a QF's total output falls under state authority.¹³³

812. Similarly, SoCal Edison and PG&E request that the Commission clarify that the Final Rule LGIP and Final Rule LGIA will not apply to a QF selling to the interconnected utility or to on-site customers. Calpine requests that generating facilities currently interconnected to the Transmission System under non-FERC-jurisdictional arrangements, such as QFs, that subsequently become FERC-jurisdictional by terminating their QF status or deciding to sell power in the wholesale market, not be treated as "new" generating facilities or "new" Interconnection Customers under the interconnection procedures. While only the contractual arrangements have changed, the physical interconnection requirements remain unchanged, and as long as the Generating Facility's output will be substantially the same after conversion, no Interconnection Studies are necessary and the Interconnection Customer should not be placed in the Transmission Provider's interconnection queue with new Generation Facilities. Rather, the Interconnection Customer should only have to execute the Commission-jurisdictional interconnection agreement to become effective upon termination of the state-jurisdictional agreement. Independent Producers, which makes a similar argument, notes that treating a newly jurisdictional former QF as a new interconnection would be discriminatory since this would essentially require that facilities be interconnected twice. If an existing QF is already in the "base case" used to determine impacts of new generators, and this same base case is used to analyze the interconnection of the existing QF, there will be no effect.

Commission Conclusion

813. The Commission's Regulations govern a QF's interconnection with most electric utilities in the United States,¹³⁴ including normally nonjurisdictional utilities.¹³⁵ When an

¹³²Citing 18 CFR 292.306, 292.308 (2003).

¹³³Citing Western Massachusetts Electric Co., 61 FERC ¶ 61,182 (1992), aff'd sub nom. Western Massachusetts Electric Co. v. FERC, 165 F.3d 922 (D.C. Cir. 1999).

¹³⁴18 CFR 292.303, 292.306 (2003).

¹³⁵The absence of interstate commerce in Alaska, Hawaii, portions of Texas and Maine, and Puerto Rico is not germane to the Commission's jurisdiction over QF matters
(continued...)

electric utility is obligated to interconnect under Section 292.303 of the Commission's Regulations, that is, when it purchases the QF's total output, the relevant state authority exercises authority over the interconnection and the allocation of interconnection costs.¹³⁶ But when an electric utility interconnecting with a QF does not purchase all of the QF's output and instead transmits the QF power in interstate commerce, the Commission exercises jurisdiction over the rates, terms, and conditions affecting or related to such service, such as interconnections.¹³⁷

814. Thus, the Commission has jurisdiction over a QF's interconnection to a Transmission System if the QF's owner sells any of the QF's output to an entity other than the electric utility directly interconnected to the QF. Because the presence of any output sold to a third party determines Commission jurisdiction, we reject Cal Cogen and ELCON's requests that we establish jurisdiction over QF interconnections based on the amount of energy sold to a third party. Accordingly, this Final Rule applies when the owner of the QF seeks interconnection to a Transmission System to sell any of the output of the QF to a third party. This jurisdiction applies to a new QF that plans to sell its output to a third party, and to an existing QF interconnected to a Transmission System that historically sold its total output to an interconnected utility or on-site customer and now plans to sell output to a third party. Nevertheless, consistent with the Commission's Regulations, states will continue to exercise authority over QF interconnections when the owner of the QF sells the output of the QF only to an interconnected utility or to on-site customers.

815. Finally, regarding a former QF interconnected to a Transmission System that sells electric energy at wholesale in interstate commerce, we conclude that the owner of the QF need not submit an Interconnection Request if it represents that the output of the generating facility will be substantially the same as before. A QF, under the Commission's Regulations,¹³⁸ must provide electric energy to its interconnecting utility much like the interconnecting utility's other Network Resources, since the utility must purchase the QF's power to displace its own generation. When the owner of a QF that was formerly interconnected to a Transmission System seeks to sell energy at wholesale

¹³⁵(...continued)
under PURPA. See 16 U.S.C. 2602 (2000).

¹³⁶See Western Massachusetts Electric Co., 61 FERC ¶ 61,182 at 61,661-62 (1992) (Western Massachusetts), aff'd sub nom. Western Massachusetts Electric Co. v. FERC, 165 F.3d. 922, 926 (D.C. Cir. 1999).

¹³⁷See id. at 61,661-62. The Commission further clarified that the use of facilities for non-jurisdictional services is not dispositive when determining jurisdiction: "The fact that the facilities used to support the jurisdictional service might also be used to provide various nonjurisdictional services, such as back-up and maintenance power for a QF, does not vest state regulatory authorities with authority to regulate matters subject to the Commission's exclusive jurisdiction." Id. at 61,662.

¹³⁸18 CFR 292.303 (2003).

and represents that the output of its generator will be substantially the same after conversion, it would be unreasonable for a Transmission Provider to require the former QF to join the interconnection queue.

5. Variations from the Final Rule

816. In the NOPR, we proposed to allow a Transmission Provider to justify variations from the non-price terms and conditions of the interconnection provisions of the Final Rule using the approach taken in Order No. 888. Order No. 888 allows two types of variations. First, public utilities may seek to use regional differences to justify proposed changes to certain specifically identified OATT provisions when the proposed alternative provision is "reasonable, generally accepted in the region, and consistently adhered to by the [T]ransmission [P]rovider."¹³⁹ Second, public utilities may argue that proposed changes to any OATT provision are "consistent with or superior to" the terms of the OATT. In the NOPR, we also stated that if a legitimate need for regional variations in specific provisions in the Final Rule LGIP and Final Rule LGIA were identified, we would consider adopting specific provisions that permit regional variations.

Comments

817. While a few commenters, including Cinergy, Dynegy, and SoCal Edison, support the proposed provision, others seek greater flexibility to propose changes based on regional differences for provisions other than those the Commission identified as specific eligible provisions. For example, several commenters argue that the Commission should allow variations for regional differences based on the reliability needs of a particular region, which may be unique because of system configuration or generation prevalent in the region.¹⁴⁰

818. Several commenters, including APS, the Connecticut PUC, and WestConnect RTO, request that the Commission allow specific regional interconnection standards or reliability requirements to be treated as regional differences. The Florida RCC proposes that the Commission require that the Parties comply with any standards and guidelines of the Applicable Reliability Council. It offers several specific provisions that should be revised to account for the requirements established by the Florida RCC and other regional reliability councils.

819. MidAmerican argues that the Final Rule should recognize regional differences particular to the Midwest. As an example, it offers the high potential for wind farms in the Midwest, and the resulting need to study voltage flicker, harmonics, dynamic voltage stability, stray voltage, and small signal stability. According to MidAmerican, these additional study options, which were not expressly proposed in the NOPR, should be included in the Final Rule to recognize regional differences. Entergy requests that the

¹³⁹See Order No. 888, FERC Stats. & Regs ¶ 31,036 at 31,770.

¹⁴⁰E.g., Florida RCC, NARUC, the North Carolina Commission, the Public Power Council, and WEPCO.

Commission consider extending the dates for completing Interconnection Studies in a region when there is a large number of Interconnection Requests.

820. Dairyland Power requests that during the compliance phase of this rulemaking the Commission allow a Transmission Provider greater flexibility to make changes using a regional differences rationale. Monongahela Power argues that regional differences should be accommodated, but only on a case-by-case basis through application for exemption rather than through changes to the Final Rule. In this way, the Final Rule serves as a baseline national standard. In contrast, Mirant requests that the Commission restrict the availability of variations based on regional differences to large, established ISOs that can show that the variations are consistent with or superior to what appears in the Final Rule.

821. NYISO recommends that the Commission revise the definition of Good Utility Practice, which was proposed to include "practices, methods or acts generally accepted in a region," and which is used repeatedly in the NOPR LGIP and NOPR LGIA to describe the standards that will be applied to certain obligations. It urges that the definition should include among eligible regions those administered by an RTO or ISO.

Commission Conclusion

822. We will apply a regional differences rationale to accommodate variations from the Final Rule during compliance, but with certain restrictions. We conclude that a non-independent transmission provider (such as a Transmission Provider that owns generators or has Affiliates that own generators) and an RTO or ISO should be treated differently because an independent RTO or ISO does not raise the same level of concern regarding undue discrimination. Accordingly, we will allow an RTO or ISO greater flexibility than that allowed under the regional differences rationale to propose variations from the Final Rule provisions, as further discussed below.

823. Although commenters generally did not identify provisions in the NOPR LGIP or NOPR LGIA that should be subject to variations based on "regional differences," when a commenter did provide specific provisions, the revisions were based on the reliability requirements of a given region. Because we intend to supplement rather than supplant the work that regional reliability groups already have undertaken regarding interconnection, we are permitting a Transmission Provider, on compliance, to offer variations based on existing regional reliability requirements. Accordingly, regional flexibility is included in the Final Rule definition of Good Utility Practice, which includes practices established by relevant reliability councils and local laws and regulations. We accommodate NYISO's proposal that the definition of Good Utility Practice be revised as requested by instead defining it to include "acceptable practices, methods, or acts generally accepted in the region." Thus, this definition includes by implication the Commission-approved practices of those regions administered by an RTO or ISO.

824. Nevertheless, there may be Final Rule provisions that do not include reference to Good Utility Practice that may be subject to or affected by regional reliability restrictions. Rather than identify all such provisions in the Final Rule, as the Florida RCC proposes,

we leave it to the Transmission Provider to justify variations based on regional requirements. With this approach, we are permitting public utilities the flexibility necessary to ensure that reliability needs are met. Because we seek greater standardization of interconnection terms and conditions, we are not permitting a non-independent Transmission Provider to use the regional differences justification in the absence of established regional reliability standards.

825. For other proposed deviations from the Final Rule LGIP and Final Rule LGIA not made in response to established regional reliability requirements, we are requiring non-independent transmission providers to justify variations in non-price terms and conditions of the Final Rule LGIP and Final Rule LGIA using the approach taken in Order No. 888, which allows them to propose variations on compliance that are "consistent with or superior to" the OATT.

826. To clarify, if on compliance a non-RTO or ISO Transmission Provider offers a variation from the Final Rule LGIP and Final Rule LGIA and the variation is in response to established (*i.e.*, approved by the Applicable Reliability Council) reliability requirements, then it may seek to justify its variation using the regional difference rationale. If the variation is for any other reason, the non-RTO or ISO Transmission Provider must present its justification for the variation using the "consistent with or superior to" rationale that the Commission applies to variations from the OATT in Order No. 888.

827. With respect to an RTO or ISO, at the time its compliance filing is made, as discussed above, we will allow it to seek "independent entity variations" from the Final Rule pricing and non-pricing provisions. This is a balanced approach that recognizes that an RTO or ISO has different operating characteristics depending on its size and location and is less likely to act in an unduly discriminatory manner than a Transmission Provider that is a market participant. The RTO or ISO shall therefore have greater flexibility to customize its interconnection procedures and agreements to fit regional needs.

6. Waiver Availability for Small Entities

828. In the NOPR, we did not address whether special provisions are needed for small Transmission Providers for whom providing Interconnection Services might be overly burdensome.

Comments

829. Maine PSC asks the Commission to provide flexibility and waiver of the full requirements of the Final Rule LGIP and Final Rule LGIA for small transmission owners. Southwest Transmission requests that the current "small utility" exception for Order Nos. 888 and 889 should not only be retained, but it should be expanded to apply to cooperatives with total electric energy dispositions that exceed four million MWh annually and with outside sales that do not exceed one million MWh annually. SoCal Water District also asks for a waiver for utilities with annual sales of less than four million MWh.

Commission Conclusion

830. We are sympathetic to the array of concerns raised by small Transmission Providers. Order Nos. 888 and 889 established guidelines for the granting of waivers to small entities, and this Final Rule adopts that approach and makes conforming changes to the regulatory text in Part 35 of the Commission's regulations.¹⁴¹ We recognize, for example, that it might be a financial burden on a small Transmission Provider to perform Interconnection Studies or manage the construction of Interconnection Facilities in the same manner as a larger Transmission Provider. The small Transmission Provider may simply not have the staff or expertise to efficiently accommodate all Interconnection Requests.

831. Because the possible scenarios under which small entities may seek waivers from the Final Rule are diverse, they are not susceptible to resolution on a generic basis and we will require applications and fact-specific determinations in each instance. If the circumstances that give rise to the exemption change, the waiver may no longer be appropriate. In addition, we will apply the same standards to any entity seeking a waiver, including public utilities seeking waiver of some or all of the requirements of the Final Rule, as well as non-public utilities seeking waiver of the reciprocity provision. Each entity, however, will have to apply for this waiver and demonstrate that it qualifies for the waiver as required in Order No. 888.

7. OATT Reciprocity Requirements Applied to the Final Rule LGIP and Final Rule LGIA

832. In the NOPR, we proposed that the Final Rule LGIP and Final Rule LGIA be subject to the reciprocity provision of Order No. 888, as incorporated into the OATTs adopted by public utilities.¹⁴² The reciprocity provision allows any public utility that provides open access transmission to a non-public utility to receive as a condition of service non-discriminatory access in return.¹⁴³ With the addition of the Final Rule LGIP and Final Rule LGIA to the OATT, in order to meet its reciprocity obligation, a non-public utility would have to provide Interconnection Service to the Transmission Provider and the Transmission Provider's Affiliates under the same terms and conditions under which it receives service.

Comments

¹⁴¹See 18 CFR 35.28(d) (2003); Reg. Text 35.28(f)(3), *infra*.

¹⁴²Large Generator Interconnection NOPR, FERC Stats. & Regs. ¶ 32,560 at 34,184-185. See also Order No. 888, FERC Stats. & Regs. ¶ 31,036 at 31,755.

¹⁴³See Order No. 888, FERC Stats. & Regs. ¶ 31,036 at 31,760.

833. Several public power commenters, including Lakeland, LPPC, Nebraska PPD, NRECA-APPA, and the Public Power Council, request that the Commission clarify that it indeed intends to apply, without modification, the reciprocity policy as expressed in Order No. 888 to the Final Rule LGIP and Final Rule LGIA. Other commenters such as LADWP and LIPA warn that any attempt to expand the reciprocity policy to allow a generator unaffiliated with a Commission-jurisdictional Transmission Provider to require a non-public utility to comply with the reciprocity condition would be an impermissible extension of Commission jurisdiction.

834. Mirant argues that the Commission should add additional reciprocity language to every Transmission Provider's OATT that conditions the continued provision of transmission service on a non-public utility Interconnection Customer offering comparable Interconnection Service on its own transmission facilities.

835. Nebraska PPD objects to any reciprocity with respect to the Final Rule LGIP and Final Rule LGIA. In the alternative, it seeks clarification that the jurisdictional Transmission Provider may waive reciprocity. It also joins LPPC in requesting that only terms and conditions, and not the rate provisions, be subject to the reciprocity condition.

836. Pinnacle West argues that the Commission should state that the reciprocity requirement cannot be satisfied if a non-public utility fails to provide credits against transmission service bills for Network Upgrades. Otherwise, Pinnacle West continues, the non-public utilities would be engaging in prohibited "and" pricing that charges customers twice for transmission service. It states that Commission precedent has made clear that to satisfy reciprocity, a non-public utility must charge rates comparable to the rates it charges itself.¹⁴⁴

837. TAPS explains that the reciprocity condition should impose an obligation to interconnect on a basis that is reasonable under the circumstances and comparable to the way the non-public utility treats its own interconnections. It supports the availability of a Commission waiver of the reciprocity requirement for small transmission owners.

838. Certain public power entities, including the Bureau of Reclamation, LIPA, NYTO, Southwest Transmission, and TAPS, ask the Commission to consider the statutory or regulatory restrictions applicable to public power and other non-public utilities when the Commission evaluates their reciprocity compliance filings. They request that non-public utilities be afforded sufficient flexibility to include or modify certain provisions as required by law.

839. SoCal Edison expresses concern that an interconnection with a non-public utility may require Network Upgrades to a neighboring public utility's transmission facilities, and that the neighboring public utility would have no recourse should the owner of the generator and the non-public utility proceed with the interconnection without paying the

¹⁴⁴Citing Missouri Basin Municipal Power Authority, 99 FERC ¶ 61,062 at 61,296 (2002).

neighboring public utility's upgrade costs. It proposes that the Commission, as part of the reciprocity provision, allow a jurisdictional utility to disconnect from its non-jurisdictional neighbor unless the neighbor ensures that the interconnecting generator mitigates the effects on the jurisdictional utility's system.

Commission Conclusion

840. Some commenters may have misunderstood our reciprocity statement in the NOPR as extending reciprocity rights to public utilities that do not own, control, or operate transmission either directly or through an Affiliate. The owners of many generators are public utilities that do not own, and are not affiliated with a public utility that owns, transmission. They are thus incapable of offering reciprocity service. We wish to make it clear that this Final Rule in no way alters the applicability of the reciprocity provision in the OATT and the reciprocity policy articulated in Order No. 888 and its progeny. The point of the reciprocity requirement is to permit a public utility that provides open access transmission service to require a non-public utility that owns, controls, or operates transmission facilities to have available reciprocal transmission service from that non-public utility. The concept of reciprocity is simply irrelevant if the non-public utility does not own, control, or operate transmission facilities, as is the case with many Interconnection Customers. Because the Final Rule LGIP and Final Rule LGIA are to become a part of the OATT, the reciprocity provision in the OATT applies to interconnection as well. EEI – Alliance of Energy Suppliers, MidAmerican, and Nevada Power, among others, filed comments supporting this approach.

841. Under the reciprocity provision in Section 6 of the OATT, if the public utility seeks transmission service from a non-public utility to which it provides open access transmission service, the non-public utility that owns, controls, or operates transmission facilities must provide comparable transmission service that it is capable of providing on its own system. Under the OATT, a public utility may refuse to provide open access transmission service to a non-public utility if the non-public utility refuses to reciprocate. A non-public utility may satisfy the reciprocity condition in one of three ways: first, it may provide service under a Tariff that has been approved by the Commission under the voluntary "safe harbor" provision. A non-public utility using this alternative submits a reciprocity Tariff to the Commission seeking a declaratory order that the proposed reciprocity Tariff substantially conforms to or is superior to the OATT. The non-public utility then must offer service under its reciprocity Tariff to any public utility whose transmission service the non-public utility seeks to use. Second, the non-public utility may provide service to a public utility under a bilateral agreement that satisfies its reciprocity obligation. Finally, the non-public utility may seek a waiver of the reciprocity condition from the public utility.¹⁴⁵

842. A non-public utility that has a "safe harbor" Tariff may add to its Tariff an interconnection agreement and interconnection procedures that substantially conform or are superior to the Final Rule LGIP and Final Rule LGIA if it wishes to continue to

¹⁴⁵ See Order No. 888-A, FERC Stats. & Regs. ¶ 31,048 at 30,285-86.

qualify for safe harbor treatment. A non-public utility that owns, controls, or operates transmission and that has not filed with the Commission a safe harbor Tariff and seeks transmission service from a public utility must either satisfy its reciprocity obligation under a bilateral agreement or seek a waiver of the OATT reciprocity condition from the public utility.

843. We do not require, as Pinnacle West proposes, that a non-public utility also provide transmission credits for Network Upgrade costs, to satisfy the Commission's reciprocity condition. With respect to a tariff filed under the "safe harbor" provision, our reciprocity policy requires that it contain rates comparable to the rates the non-public utility charges itself.¹⁴⁶ As for rates contained in a bilateral agreement, they are a fact-specific matter that will be subject to a case-by-case analysis.¹⁴⁷

844. Regarding the applicability of the reciprocity requirement to public power and other nonjurisdictional entities, we shall limit reciprocity compliance to those services a nonjurisdictional entity is capable of providing on its system.¹⁴⁸ We likewise will consider the legal and regulatory restrictions on nonjurisdictional entities' contractual rights and tax-exempt status when we evaluate any "safe harbor" reciprocity filings.

845. Finally, since we did not propose to change the reciprocity condition articulated in the OATT in this Final Rule, SoCal Edison's concerns are more appropriately addressed in the discussion of effects on third party systems.

8. General Comments/Clarifications

a. Insurance

846. In the NOPR, we omitted the insurance requirements originally filed in the ANOPR Consensus LGIA. Those insurance requirements would have set out the minimum coverage types and amounts that each Party to the LGIA must maintain. The NOPR did not propose insurance requirements because insurance requirements are not contained in the OATT.

Comments

847. Many commenters, primarily Transmission Providers, ask the Commission to reconsider its proposal to omit the insurance requirements.¹⁴⁹ They argue that insurance

¹⁴⁶See generally Order No. 888, FERC Stats. & Regs ¶ 31,036 at 31,761; see also Long Island Power Authority, 84 FERC ¶ 61,280 at 62,333 (1998).

¹⁴⁷Order No. 888-A, FERC Stats. & Regs ¶ 31,048 at 30,289.

¹⁴⁸Id. at 30,286.

¹⁴⁹E.g., American Transmission, APS, Dominion Resources, Dynegy, Entergy,
(continued...)

provisions are common in individually negotiated interconnection agreements and are important for managing risks and containing liability costs. The magnitude of the costs and potential liability at issue necessitate the inclusion of insurance provisions, they claim. Entergy explains that since the indemnification provision in NOPR LGIA Article 18 likely will be inadequate to make the Transmission Provider whole, insurance is necessary to ensure that damaged Parties are made whole for a disturbance caused by a Generating Facility.

848. Several commenters, including PSNM, Southern, and Tenaska, argue that the Commission should not follow the OATT on this issue because Interconnection Service is different from transmission service in that the operation of generators poses safety and operational risks. PJMTO and PSEG note that a generation project is unlikely to obtain financing without appropriate insurance provisions within the Final Rule LGIA.

849. Some commenters, including Avista, Dynegy, FP&L, and National Grid, argue that the Commission should restore the insurance provision that appeared in the ANOPR LGIA, which included mandatory insurance types and coverage amounts. Others, including Dominion Resources, NYTO, and Progress Energy, argue that while state laws and local business practices should dictate the actual amount of coverage, the Final Rule LGIA should describe the types of insurance coverage each Party must carry. Some commenters including EEI – Alliance of Energy Suppliers state that while it is infeasible on a generic basis to stipulate the appropriate levels of insurance for all facilities, the Interconnection Customer and Transmission Provider should be required to maintain certain minimum levels of insurance as agreed by the Parties.

Commission Conclusion

850. We conclude that requiring certain minimum insurance in the Final Rule will benefit both the Transmission Provider and the Interconnection Customer and will help the Transmission Provider to avoid undue financial risk. Accordingly, we are restoring the insurance requirement in the Final Rule LGIA. The addition of this provision should help the Transmission Provider and the Interconnection Customer to manage the risks arising from Interconnection Service. The Final Rule requires that each Party, at its own expense, maintain certain minimum insurance coverages throughout the period of their interconnection agreement. These coverages include Employers' Liability and Workers' Compensation Insurance, Commercial General Liability Insurance, Comprehensive Automobile Liability Insurance, and Excess Public Liability Insurance.

b. Liquidated Damages

851. Two liquidated damages provisions appeared in the NOPR, one in Article 5.1 of the LGIA and the other in Section 13.5 of the LGIP.

¹⁴⁹(...continued)

FP&L, National Grid, NiSource, NYTO, Oklahoma G&E, PSNM, and Tucson Electric.

852. The liquidated damages provision in the NOPR LGIA would be applicable if an Interconnection Customer chooses the option described in Article 5.1.B. Under this option, if a Transmission Provider fails to complete construction of the Interconnection Facilities by the In-Service Date or the Network Upgrades by the Commercial Operation Date, the Transmission Provider would pay the Interconnection Customer liquidated damages. Liquidated damages would be limited to 0.5 percent per Calendar Day of the actual aggregate costs of the Interconnection Facilities or Network Upgrades for which the Transmission Provider remains responsible, not to exceed 20 percent of such costs.

853. The liquidated damages provision in Section 13.5 in the NOPR LGIP would have the Transmission Provider pay liquidated damages if it fails to meet its obligations in the LGIP and does not remedy the failure within 15 Business Days. Liquidated damages would be one percent of the actual costs of the applicable study cost per Calendar Day, with a cap at 50 percent. Also, upon expiration of the remedy period, the Transmission Provider would refund any deposit amount for the applicable study that the Interconnection Customer had paid beyond the actual reasonably incurred study costs.

Comments

854. Many commenters make similar arguments about these provisions, and since the provisions serve different functions, there may be different responses to the same argument. Nevertheless, there are a few issues that the Commission will address collectively; namely, legal authority to allow liquidated damages, and the applicability of liquidated damages to public power organizations and RTOs.

(1) Legal Authority to Require Liquidated Damages

855. Some commenters argue that liquidated damages are beyond the Commission's statutory authority inasmuch as they are penalties that are not fact-specific because they are not designed to remedy the actual damages experienced,¹⁵⁰ or are damages beyond the statutory authority of the Commission.¹⁵¹ Others, including El Paso and WestConnect RTO, argue that liquidated damages are inconsistent with just and reasonable rates under the Federal Power Act. Southern questions whether the Commission has authority to require liquidated damage in private contracts. Idaho Power argues that the liquidated damages provisions violate the Federal Power Act by preventing a Transmission Provider from recovering costs prudently incurred in providing service to an Interconnection Customer. Maine PSC notes that the imposition of liquidated damages is at odds with the Commission's precedent on liability, which states that there should be no liability without fault and that liability should be unavoidable if caused by one's own gross negligence or intentional actions.¹⁵² Other commenters, including Idaho Power and WestConnect RTO,

¹⁵⁰ E.g., El Paso, Idaho Power, PacifiCorp, and WestConnect RTO.

¹⁵¹ E.g., Entergy and SoCal PPA.

¹⁵² See, e.g., ANR Pipeline Co., 98 FERC ¶ 61,128 at 61,862 (2002).

argue that an Interconnection Customer should file a complaint if it believes that the rates, terms, and conditions of Interconnection Service are unjust or unreasonable.

Commission Conclusion

856. We are deleting the liquidated damages provisions from the Final Rule LGIP and retaining them, with modifications, in the Final Rule LGIA.

857. Liquidated damages provisions are within our statutory authority because, although we do not assess or award damages, we have jurisdiction under Section 205 over agreements from which damages may arise. Liquidated damages can help manage risk within a jurisdictional agreement.

858. In response to the comments questioning the imposition of liquidated damages by regulatory fiat, we clarify that the Final Rule, like the NOPR, does not require liquidated damages. A Transmission Provider has the option to agree to a liquidated damages provision after agreeing to the dates for designing, procuring and constructing the Interconnection Facilities and Network Upgrades designated by the Interconnection Customer.¹⁵³ If the Parties are unable to agree on an acceptable schedule, they may negotiate terms and conditions – including revisions to the liquidated damages provision – under the Negotiated Option in Article 5.1.4 of the Final Rule LGIA. So, rather than impose liquidated damages, the Final Rule LGIA provides liquidated damages as an option that may become a provision in the interconnection agreement signed by the Parties.

859. Because we are not including a liquidated damages provision in the Final Rule LGIP, we are not discussing that proposed provision here.

(2) Applicability of Liquidated Damages to Public Power, Cooperatives, and RTOs

860. Georgia Transmission argues that liquidated damages are particularly burdensome for cooperatives because of their inability to recover these costs except directly from the cooperative customers. For similar reasons, liquidated damages may make it financially prohibitive for some public power providers to handle Interconnection Requests from third party Interconnection Customers.¹⁵⁴ Western warns that it cannot agree to a contractual provision that would result in open-ended financial exposure when funds have not been appropriated for this purpose.

861. Midwest ISO TO argues that the liquidated damages provisions will not work in the RTO context, especially when the RTO is non-profit, for several reasons: (1) a Transmission Owner in an RTO should not be subject to liquidated damages because it

¹⁵³LGIA Articles 5.1.2 and 5.1.3.

¹⁵⁴E.g., Imperial Irrigation, Lakeland, and LPPC.

will not be in charge of the interconnection process – the RTO will be, (2) an RTO should not pay liquidated damages since the costs will end up being spread over all customers who will pay the Interconnection Customer for the RTO's failure to meet the schedule, and (3) in an RTO context, with a neutral, non-profit RTO, there should be much less of a need for liquidated damages.

862. Cal ISO argues that since a Transmission Owner, rather than an RTO or ISO, will undertake many of these functions, the RTO or ISO should not be a guarantor for the Transmission Owner. For the RTO's responsibilities, Cal ISO continues, an Interconnection Customer is afforded recourse via Section 210 of the Federal Power Act.

863. PSEG and PJMTO similarly argue that the Final Rule should treat liquidated damages as a last resort remedy that would not apply where either the Interconnection Customer has an effective alternative backstop to protect itself against discriminatory conduct by the Transmission Provider or Transmission Owner, or the interconnection process is under the control of an independent third party unaffiliated with any market participant.

864. The Midwest ISO also argues that if an RTO or the Transmission Owner must pay liquidated damages, the Commission should limit their exposure by imposing liability only in cases of gross negligence and should require a Party to pay liquidated damages only if its action or inaction alone caused the damages.

Commission Conclusion

865. In response to commenters that question their ability to pay or recover liquidated damages, the Final Rule LGIA does not require that all executed interconnection agreements contain liquidated damages provision. As noted above in the discussion of proposed LGIA Article 5.1 (Options), a Transmission Provider may reject liquidated damages when the schedule proffered by the Interconnection Customer exposes it to too much risk.

866. Therefore, public power entities that have met a reciprocity obligation by filing a safe harbor Tariff will have the same opportunity to negotiate the liquidated damages provision as any other non-public power Transmission Provider. Entities with safe harbor tariffs that face unusual limitations, such as cooperatives financed by the Rural Utilities Service or federal power entities subject to contracting restrictions set by statute or regulation, may request waiver of the liquidated damages provision of the Final Rule LGIA when they comply with their reciprocity condition.

867. We agree with the Midwest ISO that liquidated damages may be unnecessary when an RTO or ISO administers the interconnection agreement and oversees the interconnection process. As noted above in Part II.C.5 (Variations from the Final Rule), we will permit RTOs and ISOs to use an independent entity variation standard to justify variations from the Final Rule provisions. Accordingly, we will consider proposals to eliminate liquidated damages from the compliance filings of RTOs and ISOs.

(3) General Comments on the LGIA Liquidated Damages Provision

868. Many commenters, most of them Transmission Providers, ask the Commission to either eliminate¹⁵⁵ or modify¹⁵⁶ the liquidated damage provision in the NOPR LGIA. They argue that liquidated damages are inappropriate because the Transmission Owner recognizes no profit from the interconnection and has no means of recouping such costs.¹⁵⁷

869. PG&E argues that the Commission should eliminate the liquidated damage clause and instead provide a rapid method for addressing Interconnection Customer complaints. PacifiCorp contends that this is not an appropriate context for liquidated damages because the Parties are not negotiating the terms. The Louisiana PSC argues that liquidated damages should be unavailable without a demonstration that harm was caused and that the Transmission Provider caused the harm. While FP&L argues that liquidated damages should not apply unless a Transmission Provider can recover these costs in rates, including retail rates, the Louisiana PSC argues that liquidated damages should not be recoverable in transmission charges.

870. Some commenters contend that, if the Parties agree to liquidated damages and liquidated damages are recoverable, it should be the exclusive remedy for failure to complete construction on time.¹⁵⁸ SoCal Edison argues that operating dates must be agreed upon between the Transmission Provider and the Interconnection Customer in order for liquidated damages to apply. Southern contends that liquidated damages should be available only for facilities that are not completed on time. If a Transmission Provider is subject to liquidated damages for failure to complete Interconnection Facilities being built by another Interconnection Customer, Dominion Resources argues, the Interconnection Customer constructing the Interconnection Facilities should indemnify the Transmission Owner for any liquidated damages resulting from the Interconnection Customer's failure to meet the designated date.

871. Others commenters, including Georgia Transmission and NRECA-APPA, argue that, in lieu of liquidated damages, the Commission should include a Good Utility Practice and best efforts standard that holds the Transmission Provider liable for actual damages. Several commenters ask the Commission to adopt a provision that would

¹⁵⁵E.g., APS, Bridger Valley, Cinergy, El Paso, FP&L, Entergy, Idaho Power, LADWP, Monongahela Power, PacifiCorp, PG&E, Tucson Electric, and Western.

¹⁵⁶E.g., Ameren, American Transmission, Cal ISO, the Construction Issues Coalition, MidAmerican, Mirant, National Grid, NSTAR, NYTO, PSNM, Sempra, and SoCal Edison.

¹⁵⁷E.g., APS, Cinergy, Exelon, and Oklahoma G&E.

¹⁵⁸E.g., American Transmission, Construction Issues Coalition, NYTO, NSTAR, SoCal Edison, and WestConnect RTO.

protect a Transmission Provider from liquidated damages if it meets a certain standard, such as a best efforts or Reasonable Efforts standard.¹⁵⁹ Some commenters, including Cleco and FP&L, argue that liquidated damages should be available only in cases of intentional wrongdoing or negligence.

872. Several Transmission Providers also argue alternatively that, if the liquidated damages provision remains in the Final Rule LGIA, it should be modified. Recommended modifications include not holding the Transmission Provider liable for Force Majeure events and circumstances beyond its control, such as permitting and regulatory delays, delays due to third parties, and delays due to the requesting Interconnection Customer or other Interconnection Customers.¹⁶⁰ Ameren argues that proposed LGIA Article 5.1.B(ii) might result in confusion, appeals, and litigation.

873. FP&L comments that the liquidated damages provision penalizes the Transmission Provider without a symmetrical opportunity for it to make a profit or recoup its costs and requests that the Transmission Provider have the opportunity to receive a financial benefit above its costs if a study is completed on time. Other commenters, including American Transmission, Cleco, MidAmerican, PG&E, and SoCal Edison, ask that the Commission make liquidated damages bilateral, thereby subjecting an Interconnection Customer to liquidated damages for missing its milestones. American Transmission further argues that an Interconnection Customer should be responsible for liquidated damages payable to the Transmission Provider at two levels of liability – a higher level when Generating Facilities lower in the queue are dependent on the Interconnection Customer's timely performance and a lower level when no third parties are harmed by the delay but the Transmission Provider deserves compensation.

874. Ameren argues that the NOPR LGIA does not address a situation in which multiple Interconnection Customers rely on the same Transmission Provider Interconnection Facilities and Network Upgrades. American Transmission proposes that total liability for a particular project should be the same regardless of the number of Interconnection Customers requesting the component. The Construction Issues Coalition recommends that the Commission modify proposed LGIA Article 5.1.B(ii) to specify a maximum of 20 percent of the project costs for all Interconnection Customers relying on the upgrade.

875. National Grid argues that the ERCOT LGIA provision, which has a compensatory approach, was better than the NOPR LGIA provision, which takes a punitive approach. The asymmetry between risk and reward may cause a Transmission Provider to avoid any obligation to perform Interconnection Services, says National Grid. Since a Transmission Provider can opt out of the liquidated damages provision in the interconnection agreement, an Interconnection Customer will likely be forced to find another builder.

¹⁵⁹E.g., Ameren, Cal ISO, Central Maine, El Paso, Exelon, and WestConnect RTO.

¹⁶⁰E.g., Ameren, the Construction Issues Coalition, Dominion Resources, FP&L, NE Utilities, NSTAR, PG&E, Sempra, SoCal PPA, and Southern.

876. PG&E requests that the Commission adopt a 15 month period for completing the work, which was in the ERCOT liquidated damages provision.

877. Cal ISO argues that damages must track the entity performing the work. In cases where there is an RTO or ISO, the Transmission Owner should be liable, and the RTO or ISO should not be a guarantor for the Transmission Owner.

878. Western argues that it is inequitable to allow the Interconnection Customer to extend the In-Service Date without penalty (Article 5.5) without also giving the Transmission Provider this option. Also, the Transmission Provider should be allowed to provide justification for not meeting unreasonable deadlines.

879. The Construction Issues Coalition argues that proposed LGIA Article 5.1.B.1.a should be modified to allow a Transmission Provider or a Transmission Owner not to enter into an interconnection agreement that includes liquidated damages for any reason, not just because of unacceptable dates. Because the limits on liquidated damages recovery may not be appropriate for every Interconnection Customer, Mirant argues, the proposed LGIA liquidated damages provision should be optional and left to the election of the Interconnection Customer.

880. American Forest expresses concern that the liquidated damages cap could be used by the Transmission Provider to delay or deny completion of Interconnection Studies or construction of facilities or upgrades simply by paying liquidated damages. The Commission should clarify that the cap should not be used by the Transmission Provider to impede the development of new generation. It proposes either deleting the cap or adding language to specify that the cap does not apply if the Transmission Provider intentionally delays or denies service. Also, Cal ISO notes that the penalty of 0.5 percent of the upgrade cost in proposed LGIA Article 5.1.A(ii) for each day the Transmission Provider fails to meet an agreed upon deadline for completing any portion of the Transmission Provider Interconnection Facilities or Network Upgrades does not really work as an incentive because there may be no incentive to meet a deadline if the cost of the upgrade is small because the penalty would be so low.

881. Several commenters, including Duke Energy, EPSA, and NE Utilities, support the liquidated damages provision in the NOPR LGIA but none provide detailed arguments explaining their support.

Commission Conclusion

882. As noted above, the proposed LGIA liquidated damages provision allows a Transmission Provider to refuse the Interconnection Customer's proffered construction schedule and perhaps even negotiate to revise the liquidated damages provision if the Parties end up negotiating over construction terms.¹⁶¹ We are concerned that

¹⁶¹In Final Rule LGIA Article 5.1.4, the Parties may negotiate terms under the
(continued...)

Transmission Providers will always negotiate to eliminate liquidated damages liability unless the provision is revised to further protect the Transmission Provider. For this reason, we are adopting the recommendations of several commenters to revise this provision.

883. In the Final Rule LGIA, liquidated damages would be recoverable if an Interconnection Customer chooses the Alternate Option in Final Rule LGIA Article 5.1.2. Under this option, if a Transmission Provider fails to complete the Interconnection Facility or the Network Upgrades by the dates designated by the Interconnection Customer and accepted by the Transmission Provider, the Transmission Provider would pay the Interconnection Customer liquidated damages. Liquidated damages would be limited to 0.5 percent per Calendar Day of the actual aggregate costs of the Interconnection Facilities or Network Upgrades for which the Transmission Provider remains responsible, and not to exceed 20 percent of the Transmission Provider's actual costs. They would not be recoverable under certain circumstances, such as when the Interconnection Customer is not ready to commence use of the Transmission Provider's Interconnection Facilities or Network Upgrades by the date specified (unless the Interconnection Customer was not ready due to delay on the part of the Transmission Provider) or if the delay is due to a cause beyond the reasonable control of the Transmission Provider.

884. Liquidated damages should not be payable if the delay is due to circumstances beyond the control of the Transmission Provider. As a result, liquidated damages will be available only due to the action or inaction of a Transmission Provider, and not when the delays are due to third parties or other circumstances beyond the Transmission Provider's control. For the purposes of this provision, the Transmission Provider's subcontractors will not be considered third parties, but delays due to the action or inaction of Interconnection Customers earlier in the queue will be considered delays due to third parties. This provision also will sufficiently protect a Transmission Provider that seeks to interconnect multiple Generating Facilities to the same interconnection, since liability to each of the Interconnection Customers for liquidated damages may be avoidable as long as the delay is not attributable to the Transmission Provider or its subcontractors. This will also counterbalance the Interconnection Customer's ability to adjust the schedule under Final Rule Article 5.7, since the Transmission Provider can avoid liability for the acts of third parties. Finally, because liquidated damages liability will not have to be paid unless the Transmission Provider is at fault, we conclude that these damages will not be considered just and reasonable costs of service and will not be recoverable in transmission rates.

885. Finally, if the Parties agree to liquidated damages and liquidated damages are payable, this will be the exclusive remedy for failure to complete construction on time. We are not making the liquidated damages provision bilateral, however, because the Final Rule LGIA provides a Transmission Provider the necessary protection from liquidated

damages liability, as well as the ability to negotiate provisions of the interconnection agreement to better match its chosen level of risk.

(4) General Comments on the LGIP Liquidated Damages Provision

886. Many commenters, most of them Transmission Providers, ask the Commission to either eliminate¹⁶² or modify¹⁶³ the liquidated damages provision in the LGIP.

887. Those opposed to the liquidated damages provision in the LGIP argue, among other things, that liquidated damages are inappropriate because the Transmission Owner recognizes no profit and has no means for recouping costs.¹⁶⁴ Entergy notes that liquidated damages are improper because the Commission traditionally rejected these payments in favor of the payments of identifiable and direct costs incurred. PacifiCorp contends that this is not an appropriate context for liquidated damages because the Parties are not bargaining on the terms. Southern complains that the liquidated damages are improper because the LGIP provides for an uncontrolled and lengthy process due to the many opportunities for the Interconnection Customer to change data and Generating Facility configuration.

888. The NYISO and PSNM argue that instead of liquidated damages, the Commission should use the OATT Section 19.4 study requirement, which requires due diligence to perform within a specified time period. Under this approach, if a Transmission Provider is unable to meet the deadline, it must notify the customer and provide an estimate of the additional time needed and explain why more time is necessary.

889. Among those commenters requesting modification, several Transmission Providers propose that liquidated damages be made bilateral, thereby subjecting Interconnection Customers to liquidated damages for failure to meet deadlines.¹⁶⁵ American Transmission argues that there should be separate levels of liability facing the Interconnection Customer depending on third party harm caused by the Interconnection Customer's delay. Some commenters, including National Grid and NE Utilities, recommend a reciprocal financial incentive to earn for superior performance to offset the risk of liquidated damages.

¹⁶²E.g., APS, Bridger Valley, El Paso, Entergy, FP&L, LADWP, LPPC, NYISO, PacifiCorp, PG&E, PGE, PJMTO, PSNM, Southern, WestConnect RTO, and Western.

¹⁶³E.g., AEP, American Forest, American Transmission, Cal ISO, Central Maine, Cleco, Duke Energy, National Grid, NE Utilities, NYTO, and Salt River Project.

¹⁶⁴E.g., APS, PG&E, and PGE.

¹⁶⁵E.g., American Transmission, Joint Consumer Advocates, and the Midwest ISO.

890. Several Transmission Providers, including AEP, Ameren, Idaho Power, LG&E Energy, and NE Utilities, recommend modifying the proposed LGIP to exempt the Transmission Provider from circumstances beyond its control, such as the action or inaction of third parties, the failure of the Interconnection Customer to provide all relevant data, failure of a third party contracted by the Interconnection Customer to provide timely studies, or permitting or other state regulatory prerequisites.

891. The Salt River Project contends that a Transmission Provider should be able to avoid liquidated damages in the LGIP as it can in the LGIA. NSTAR recommends that the LGIP adopt NEPOOL language that allows the Parties to agree upon a schedule with deadlines if money damages are at stake for non-completion.

892. Several commenters, including Dominion Resources, FP&L, and Progress Energy, argue that the liquidated damages provision should be revised so that it does not apply unless the failure to meet a deadline results from negligence or intentional wrongdoing by the Transmission Provider.

893. Duke Energy asks the Commission to clarify that the Reasonable Efforts standard also applies to restudies, and that liquidated damages apply only to the study obligations under the LGIP, and not all of the LGIP obligations. NE Utilities recommends that, to avoid overlap and ambiguity, the first sentence of proposed LGIP Section 13.5 should be revised to apply to "study-related" obligations.

894. American Transmission argues that the 50 percent cap on liquidated damages in the LGIP is excessive and it should be reduced to 25 percent.

895. American Forest proposes either deleting the cap or adding language to specify that the cap does not apply if the Transmission Provider intentionally delays or denies service.

896. Mirant argues that the liquidated damages provision in the LGIP should provide for liquidated damages of one percent per day starting on the date the Transmission Provider misses a deadline for completing the study, but after 30 days, the Transmission Provider should pay the Interconnection Customer liquidated damages equal to the remaining difference between the study cost and the amount already paid in liquidated damages. Also, the Transmission Provider should refund with interest any deposit amount in excess of the actual reasonably incurred study costs immediately upon expiration of the 15 day remedy period. These modifications provide a better incentive for Transmission Provider compliance.

897. Some commenters, including Calpine, EPSA, and KeySpan, argue in favor of the incentive that this proposed liquidated damages provision provides.

Commission Conclusion

898. We are eliminating liquidated damages from the Final Rule LGIP. While we understand the value of providing an incentive to complete Interconnection Studies, we

are concerned that the availability of such a provision may undermine the Transmission Provider's ability to economically administer its study process.

899. Moreover, we question whether liquidated damages are appropriate during the study phase, since at that time it will be unclear whether a prospective Interconnection Customer intends to pursue its Interconnection Request. Because at this stage the prospective Interconnection Customer does not face a substantial risk of damages, we are not standardizing liquidated damages for Transmission Providers during the study phase (*i.e.*, in the Final Rule LGIP). Rather, we are requiring that a Transmission Provider use due diligence to perform within a specified time period. This approach, which has been applied to facilities studies in OATT Section 19.4, gives the Transmission Provider a deadline, and requires that the Interconnection Customer be kept apprised in writing of any difficulties encountered in meeting the deadline. In order to ensure that a Transmission Provider complies with its obligations, we urge the Interconnection Customer to bring any disputes to the Commission's Dispute Resolution Service, or if necessary, pursue claims of unduly discriminatory treatment under Section 206 of the Federal Power Act.

c. Consequential Damages

900. Consequential damages are losses that flow indirectly – rather than directly and immediately – from an injurious act.¹⁶⁶ In the NOPR, the Commission chose to maintain consistency with the OATT, and the NOPR LGIA did not limit liability for losses or costs for consequential damages. Instead, it relied on the statement in Order No. 888-A that Transmission Providers and customers can rely on any statutes or other laws to protect Parties from consequential or indirect damages.¹⁶⁷ The NOPR also stated that the OATT protects a Transmission Provider from consequential damages and indirect damages claims by third parties through indemnification except in cases of negligence or intentional wrongdoing by the Transmission Provider. The Commission sought comments on this approach and the relative merits of the alternative provisions in the consensus and ERCOT interconnection agreements.

Comments

901. Many commenters, mostly Transmission Providers, recommend that the Final Rule LGIA limit exposure to consequential damages, such as incidental, exemplary or indirect damages, lost profits, and other business interruption damages.¹⁶⁸ Without a provision limiting exposure, the Mississippi PSC explains, a Transmission Provider will be unable

¹⁶⁶Black's Law Dictionary 394 (7th ed. 1999).

¹⁶⁷Order No. 888-A, FERC Stats. & Regs ¶ 31,048 at 30,302.

¹⁶⁸*E.g.*, Ameren, American Transmission, APS, Avista, Central Maine, the Coalition for Contract Terms, Dominion Resources, Duke Energy, FP&L, Mississippi PSC, NYTO, PacifiCorp, Progress Energy, PSNM, RTO West Utilities, Tucson Electric, and WestConnect RTO.

to contractually protect itself from these claims. The risk of exposure will impose significant additional costs, which will then be charged to all transmission customers. In this way, clauses that exclude liability for consequential damages reduce rates.

902. APS explains that, because statutes for liability vary from state to state, the LGIA must recognize these differences, and dictating specific terms should be avoided. FP&L notes that, contrary to the Commission's reliance on state statutes, not all states provide consequential damages protection. As an example, FP&L points to Florida, which allows exclusion of consequential damages, but the provision must be included in a contract. Progress Energy warns that a reliance on statutes or other laws dealing with consequential damages, as the Commission proposed in the NOPR, will only invite future disagreements and litigation.

903. Some commenters, including Duke Energy and Dynegy, request that, if language limiting liability for consequential damages is not inserted, the Commission should, at a minimum, provide Parties the option of mutually agreeing to include a limitation on liability, consistent with existing Commission policy.

904. Westconnect RTO notes that if liquidated damages are not available under the option in proposed LGIA Article 5.1B(i)(b), an Interconnection Customer may still sue the Transmission Provider for failing to meet the In-Service Date if there is no limitation of liability clause. It notes that without a clause limiting liability for consequential damages, an Interconnection Customer may still be able to secure damages akin to liquidated damages, even if the Parties do not expressly agree to liquidated damages in their executed interconnection agreement.

905. Central Maine takes issue with the NOPR position that a Transmission Provider is protected from consequential and indirect damage liability to third parties through indemnification. A Transmission Provider's obligation to indemnify the Interconnection Customer for third party claims against the Interconnection Customer may be viewed as a payment of consequential damages by the Transmission Provider.

Commission Conclusion

906. There are several factors that convince us that a provision limiting consequential damages should be added to the Final Rule LGIA. First, by standardizing the liability protection, rather than leaving the issue to state law, it should offer greater certainty to Transmission Providers and Interconnection Customers alike. Contrary to APS's argument, it is precisely because state liability statutes vary that we are prescribing a specific liability provision. Second, liability limitation provisions protect against excessive utility rates by capping damage awards.¹⁶⁹ Finally, a goal of this rulemaking is to reduce litigation arising from interconnection, and an express provision in the LGIA limiting liability will have this effect. For these reasons, we are including a provision

¹⁶⁹ See Richard J. Pierce, Regional Transmission Organizations: Federal Limitations Needed for Tort Liability, 23 Energy L.J. 63, 67-72 (2002).

limiting consequential damages. Final Rule LGIA Article 18.2 protects either Party from liability for any special, indirect, incidental, consequential, or punitive damages, including profit or revenue. The Parties remain liable for any liquidated damages payable, and any damages for which a Party may be liable to the other Party under another agreement.

d. Two vs. Three Party Agreements

907. In the NOPR, the Commission proposed that, along with the Interconnection Customer, the Transmission Provider, and, to the extent necessary, the Transmission Owner, must become signatories to the interconnection agreement. The intent was to require the Transmission Provider to sign the agreement, and if the Transmission Owner is a separate entity, to require it to sign as well. We reasoned that the Transmission Provider should sign the agreement because the Interconnection Service would be provided under the Transmission Provider's OATT. However, we noted that no one disputes that the Transmission Owner must also enter into an agreement with the Interconnection Customer, and it would be inefficient to require the Interconnection Customer to enter into separate agreements with the Transmission Owner and the Transmission Provider.

Comments

908. Interconnection Customers, such as Calpine, Dairyland Power, and PSEG, generally prefer a three party agreement because it facilitates "one-stop shopping." RTOs, ISOs, and some Transmission Owners, including Cal ISO, PJM, and PG&E believe that, when the Transmission Provider is not the Transmission Owner, the former's responsibilities can be fully addressed in the Tariff and it need not be a Party to the interconnection agreement. They argue that the main purpose of the agreement is to establish a property-based relationship between the Interconnection Customer and the Transmission Owner. Also, PJM states that the NOPR LGIA is not structured to accommodate its use as a three party agreement, and should be changed to clearly define the roles of Transmission Owners and Transmission Providers.

Commission Conclusion

909. We are replacing the proposed words "to the extent necessary" with the words "if the Transmission Owner is not the Transmission Provider" in the Final Rule provision. Thus, both must sign the interconnection agreement when the Transmission Owner is not also the Transmission Provider. We believe that this better defines the relationship among the Parties in one document, protects the Interconnection Customer and, therefore, facilitates the development of new generation resources. In an RTO or ISO where the Transmission Provider is not the Transmission Owner, the RTO or ISO's compliance filing may propose a modified interconnection agreement that provides different respective rights and obligations in the region. In other cases, we do not believe that the three party agreement should create an undue burden for either entity.

D. Compliance Issues

1. Amendments to Transmission Providers' OATTs

910. The Commission is requiring all public utilities that own, control, or operate interstate transmission facilities to adopt the Final Rule LGIP and Final Rule LGIA as an amendment to their OATTs within 60 days after the publication of the Final Rule in the Federal Register. RTOs and ISOs are required to make a compliance filing by this same deadline, but their compliance filings will be assessed using the independent entity variation standard as described in Part II.C.5 of this preamble.

2. Grandfathering of Existing Interconnection Agreements (ISOs and non-ISOs)

911. The Commission is not requiring retroactive changes to individual interconnection agreements filed with the Commission prior to the effective date of this Final Rule.¹⁷⁰ Non-generic agreements submitted for approval by the Commission before the effective date of the Final Rule are grandfathered and will not be rejected outright for failing to conform to the Final Rule LGIA. Generic interconnection procedures submitted for approval or approved by the Commission before the effective date of the Final Rule must be resubmitted after being revised to conform to this Final Rule. For previously accepted individual interconnection agreements, the Commission's interconnection case law and policies govern.

912. As for requests for interconnection pending when the Final Rule takes effect, Final Rule LGIP Section 5.1 ensures that an Interconnection Customer that has been assigned a Queue Position before the issuance of the Final Rule retains that Queue Position. If an Interconnection Customer has signed any Interconnection Study agreement as of the effective date of the Final Rule, it has the option to either continue with the remaining Interconnection Studies under the Transmission Provider's existing study process or complete the remaining studies for which it does not have a signed Interconnection Study agreement under the provisions of the Final Rule LGIP.

3. Order No. 2001 and the Filing of Interconnection Agreements

¹⁷⁰Section 5 of the Final Rule LGIP governs the treatment of Queue Positions established prior to the effective date of the Final Rule. It also provides a transition process for Transmission Providers with Interconnection Requests outstanding when the Final Rule takes effect.

913. Order No. 2001¹⁷¹ revised the format through which traditional public utilities and power marketers must satisfy their obligation, pursuant to Section 205 of the Federal Power Act and Part 35 of the Commission's Regulations, to file agreements with the Commission.¹⁷² Public utilities that have standard forms of agreement in their transmission tariffs, cost-based power sales tariffs, or tariffs for other generally applicable services no longer need to file conforming service agreements with the Commission. The filing requirement for conforming agreements is now satisfied by filing the standard form of agreement and an Electronic Quarterly Report.¹⁷³ Order No. 2001 also lifts the requirement that parties to an expiring conforming agreement file a notice of cancellation or a cancellation tariff sheet with the Commission. The public utility may simply remove the agreement from its Electric Quarterly Report in the quarter after it terminates.¹⁷⁴

914. Non-conforming agreements, which are agreements for transmission, cost-based power sales and other generally applicable services that do not conform to an applicable standard form of agreement in a public utility's tariff, must continue to be filed with the Commission for approval before going into effect.¹⁷⁵ This category includes unexecuted agreements and agreements that do not precisely match the applicable standard form of service agreement.¹⁷⁶

915. With respect to interconnection agreements, Order No. 2001 found that Part 35 of the Commission's Regulations does not make a distinction between an interconnection agreement and other agreements for service that must be filed in conformance with this part of the Commission's Regulations.¹⁷⁷ Order No. 2001 therefore found that if an interconnection agreement conforms with a Commission-approved standard form of interconnection agreement, the utility does not have to file it but must report it in the Electric Quarterly Reports. Order No. 2001 also states that the requirement to file contract data and transaction data begins with the first Electric Quarterly Report filed after service commences under an agreement, and continues until the Electric Quarterly Report filed after it expires or by order of the Commission. However, an Interconnection Agreement that does not precisely match the Transmission Provider's approved standard

¹⁷¹Revised Public Utility Filing Requirements, Order No. 2001, 67 FR 31043 (May 8, 2002), FERC Stats. & Regs. ¶ 31,127 (2002); reh'g denied, Order 2001-A, 100 FERC ¶ 61,074 (2002); reconsideration and clarification denied, Order No. 2001-B, 100 FERC ¶ 61,342 (2002); further order, Order No. 2001-C, 101 FERC ¶ 61,314 (2002).

¹⁷²See Order No. 2001 at P 12.

¹⁷³See id. at P 18.

¹⁷⁴See id. at P 249.

¹⁷⁵See id. at P 19.

¹⁷⁶See id. at P 196.

¹⁷⁷See id. at P 200.

LGIA or that is unexecuted must be filed in its entirety. The Transmission Provider should clearly indicate where the agreement does not conform to its standard Interconnection Agreement, preferably through red-lining and strike-out.

III. INFORMATION COLLECTION STATEMENT

916. The Office of Management and Budget (OMB) regulations require that OMB approve certain reporting and record keeping (collections of information) imposed by an agency.¹⁷⁸ The information collection requirements in this Final Rule are identified under the Commission data collection, FERC-516 "Electric Rate Schedule Filings." In accordance with Section 3507(d) of the Paperwork Reduction Act of 1995,¹⁷⁹ the proposed reporting requirements in the subject rulemaking will be submitted to OMB for review. Interested persons may obtain information on the reporting requirements by contacting the Federal Energy Regulatory Commission, 888 First Street, NE, Washington, D.C. 20426 (Attention: Michael Miller, Office of the Executive Director, 202-502-8415) or from the Office of Management and Budget (Attention: Desk Officer for the Federal Energy Regulatory Commission, fax: 202-395-7285, e-mail pamelabeverly.oirasubmission@omb.eop.gov).

917. The regulated entities shall not be penalized for failure to respond to this collection of information unless the collection of information displays a valid OMB control number.

918. **Public Reporting Burden:** The Commission did not receive specific comments concerning its burden estimates and uses the same estimates here in the Final Rule. Comments on the substantive issues raised in the NOPR are addressed elsewhere in the Final Rule.

Data Collection	No. of Respondents	No. of Responses	Hours Per Response	Total Annual Hours
FERC-516				
LGIPs & LGIAs	95	1	4	380
LGIPs & LGIAs to be developed	81	1	6	486
	81	1	25	2,205
Recordkeeping	176	1	6	1,056

¹⁷⁸5 CFR 1320.11 (2003).

¹⁷⁹44 U.S.C. 3507(d) (2000).

Docket No. RM02-1-000

- 197 -

Totals	3,947
--------	-------

Total Annual Hours for Collection: (reporting (2,891) + recordkeeping (1,056) = 3,947 hours.

Information Collection Costs: The Commission sought comments about the time to comply with these requirements. No comments were received. Staffing requirements to review and modify existing LGIPs & LGIAs = \$19,000 (95 respondents x \$200 (4 hours @ \$50 hourly rate)). To be added to this cost are the costs for review and preparation of new LGIPs and LGIAs or \$125,550 (81 respondents x \$1,550 (31 hours @ \$50 hourly rate)) = \$144,550. There are also the annualized costs for processing (operations) and maintenance (recordkeeping) of these documents = \$70,752 (176 respondents x \$402 ((6 hours @ \$50 hourly rate) (for processing these documents)(operations) + (6 hours @ \$17 hourly rate) (recordkeeping/maintenance)). The Commission believes there will be a one-time start up costs to comply with these requirements for the procedures and agreements and then an additional \$70,752 to maintain them. Total annualized costs = \$215,302.

Titles: FERC-516 "Electric Rate Schedule Filings."

Action: Revision of Currently Approved Collection of Information

OMB Control Nos.: 1902-0096.

Respondents: Business or other for profit.

Frequency of Responses: One-time implementation.

Necessity of Information: The final rule revises the reporting requirements contained in 18 CFR Part 35. The Commission promulgates a standard LGIP and standard LGIA that public utilities must adopt. As noted in the Final Rule, the adoption of these procedures and agreement will (1) reduce interconnection costs and time for generators and Transmission Providers alike; (2) limit opportunities for Transmission Providers to favor their own generation; (3) facilitate market entry for generation competitors; and (4) encourage needed investment in generator and transmission infrastructure.

919. Interconnection plays a growing crucial role in bringing much needed generation into the market to meet the needs of electricity customers. However, requests for interconnection frequently result in complex technical disputes about interconnection feasibility, cost and cost responsibility. The Commission expects that a standard LGIP and standard LGIA will reduce interconnection costs and time for Interconnection Customers and Transmission Providers, resolve most interconnection disputes, minimize opportunities for undue discrimination, foster increased development of economic generation, and improve system reliability.

920. For information on the requirements, submitting comments on the collection of information and the associated burden estimates including suggestions for reducing this burden, please send your comments to the Federal Energy Regulatory Commission, 888 First Street, NE, Washington, D.C. 20426 (Attention: Michael Miller, Office of the Executive Director, 202-502-8415) or send comments to the Office of Management and Budget (Attention: Desk Officer for the Federal Energy Regulatory Commission, fax: 202-395-7285, e-mail pamelabeverly.oirasubmission@omb.eop.gov)..

IV. ENVIRONMENTAL IMPACT STATEMENT

921. Commission Regulations require that an environmental assessment or an environmental impact statement be prepared for any Commission action that may have a significant adverse effect on the human environment.¹⁸⁰ No environmental consideration is necessary for the promulgation of a rule that is clarifying, corrective, or procedural or does not substantially change the effect of legislation or regulations being amended,¹⁸¹ and also for information gathering, analysis, and dissemination.¹⁸² The Final Rule updates Part 35 of the Commission's Regulations and does not substantially change the effect of the underlying legislation or the regulations being revised or eliminated. In addition, the Final Rule involves information gathering, analysis and dissemination. Therefore, this Final Rule falls within categorical exemptions provided in the Commission's Regulations. Consequently, neither an environmental impact statement nor an environmental assessment is required.

V. REGULATORY FLEXIBILITY ACT

922. The Regulatory Flexibility Act (RFA)¹⁸³ requires that a rulemaking contain either a description and analysis of the effect that the proposed rule will have on small entities or a certification that the rule will not have a significant economic impact on a substantial number of small entities. In the NOPR, the Commission stated that the proposed regulations would impose requirements only on interstate transmission providers, which are not small businesses. The Commission certified that the proposed regulations would not have a significant adverse impact on a substantial number of small entities.

Comments

923. NRECA-APPA argues that the Commission failed to adequately account for the limited resources of small service providers when drafting the NOPR's RFA compliance statement. According to NRECA-APPA, the NOPR inconsistently suggests that it would

¹⁸⁰Regulations Implementing National Environmental Policy Act, Order No. 486, 52 FR 47897 (Dec. 17, 1987), FERC Stats. & Regs. ¶ 30,783 (1987).

¹⁸¹ 18 CFR 380.4(a)(2)(ii) (2003).

¹⁸² 18 CFR 380.4(a)(5) (2003).

¹⁸³ 5 U.S.C. 601-612 (2000).

apply to wholesale sales through Distribution Systems, but the RFA compliance language states that the regulations impose requirements only on interstate Transmission Providers.

Commission Conclusion

924. As explained above, only facilities owned by public utilities that own, control, or operate interstate transmission facilities (Transmission Providers) are subject to the Final Rule. Thus the Final Rule applies to the same class of entities subject to Order No. 888. In Order No. 888, the Commission concluded that the number of affected small entities did not constitute a "substantial number" under the RFA and noted that small entities would be eligible for a waiver.¹⁸⁴ The Commission adopts the same reasoning here. The waiver available for compliance with the Commission's Order No. 888¹⁸⁵ is also available for this Final Rule.

The Regulatory Flexibility Act of 1980 (RFA)¹⁸⁶ generally requires a description and analysis of the effect of proposed or Final Rules that will have significant economic impact on a substantial number of small entities or a certification that the rule will not have such an economic effect. In this Final Rule, the Commission is requiring public utilities that own, control, or operate facilities used for transmitting electric energy in interstate commerce to modify their OATTs, first established under Order No. 888, to include a standard LGIP and standard LGIA. In Order Numbers 888 and 889, the Commission certified that its rules would not impose a significant economic impact on a substantial number of small entities.¹⁸⁷ In Order No. 888, the Commission found that just over one-tenth of the total number of public utilities constitute small entities.¹⁸⁸ And of that number, several had already filed OATTs, reducing this number even further. As the Commission noted in Order No. 888 and reemphasizes here, waiver provisions are applicable here.¹⁸⁹ This waiver policy follows the provisions of the Small Business Act (SBA) by acknowledging the definition of a small electric utility. The Small Business Size Standards component of the North American Industry Classification System defines a small electric utility as one that, including its affiliates, is primarily engaged in the generation, transmission, and/or distribution of electric energy for sale and whose total

¹⁸⁴Order No. 888, FERC Stats. & Regs ¶ 31,036 at 31,897.

¹⁸⁵See 18 CFR 35.28(d) (2003).

¹⁸⁶5 U.S.C. 601-612 (2000).

¹⁸⁷Order No. 888, FERC Stats. & Regs. ¶31,036, at 31,898.

¹⁸⁸ 5 U.S.C. 601(3) (2000), citing to Section 3 of the Small Business Act, 15 U.S.C. 632 (2000). Section 3 of the Small Business Act defines a "small-business concern" as a business which is independently owned and operated and which is not dominate in its field of operation.

¹⁸⁹See 18 CFR 35.28(d) (2003).

electric output for the preceding fiscal year did not exceed 4 million MWh.¹⁹⁰ Continuing to make the waiver process available should address the concerns of those entities that ask the Commission to extend the "small utility" exception.¹⁹¹ This Final Rule will promote consistent reporting practices for all reporting companies. It will not be a significant burden to industry, since several Transmission Providers have already filed interconnection procedures as part of their OATTs and much of the information is already being supplied under interconnection agreements throughout the industry. Accordingly, the Commission certifies that this Final Rule will not have a significant economic impact on a substantial number of small entities.

VI. DOCUMENT AVAILABILITY

925. In addition to publishing the full text of this document in the Federal Register, the Commission also provides all interested persons an opportunity to view and/or print the contents of this document via the Internet through the Commission's Home Page (<http://www.ferc.gov>) and in the Commission's Public Reference Room during normal business hours (8:30 a.m. to 5:00 p.m. Eastern time) at 888 First Street, N.E., Room 2A, Washington, D.C. 20426.

926. From the Commission's Home Page on the Internet, this information is available in the Federal Energy Regulatory Records Information System (FERRIS). The full text of this document is available on FERRIS in PDF and WordPerfect format for viewing, printing, and/or downloading. To access this document in FERRIS, type the docket number excluding the last three digits of this document in the docket number field.

927. User assistance is available for FERRIS and the Commission's Website during normal business hours from FERC Online Support (by phone at (866)208-3676 (toll free) or for TTY, contact (202)502-6652, or by e-mail at FERCOnlineSupport@ferc.gov), for TTY (202) 502-8659.

VII. EFFECTIVE DATE AND CONGRESSIONAL NOTIFICATION

928. This Final Rule will take effect on [insert date that is 60 days after date of publication in the FEDERAL REGISTER]. The Commission has determined, with the concurrence of the Administrator of the Office of Information and Regulatory Affairs of the Office of Management and Budget, that this rule is not a "major rule" within the meaning of Section 251 of the Small Business Regulatory Enforcement Fairness Act of

¹⁹⁰13 CFR 121.61 (Sector 22, Utilities, North American Industry Classification System, NAICS) (2003).

¹⁹¹Maine PSC, Southwest Transmission, and SoCal Water District.

Docket No. RM02-1-000

- 201 -

1996.¹⁹² The Commission will submit the Final Rule to both houses of Congress and the General Accounting Office.¹⁹³

List of subjects in 18 CFR Part 35

Electric power rates, Electric utilities, Reporting and recordkeeping requirements.

By the Commission.

(S E A L)

Magalie R. Salas,
Secretary.

In consideration of the foregoing, the Commission revises part 35, Chapter I, Title 18 of the Code of Federal Regulations, as follows.

PART 35 – FILING OF RATE SCHEDULES

1. The authority citation for part 35 continues to read as follows:

Authority: 16 U.S.C. 791a-825r, 2601-2645; 31 U.S.C. 9701; 42 U.S.C. 7101-7352.

2. In § 35.28, the last sentence in the paragraph (d) introductory text is revised, and paragraph (f) is added to read as follows:

¹⁹² 5 U.S.C. 804(2) (2000).

¹⁹³ 5 U.S.C. 801(a)(1)(A) (2000).

§ 35.28 Non-discriminatory open access transmission tariff.

* * * * *

(d) Waivers. * * * Except as provided in paragraph (f) of this section, an application for waiver must be filed either:

* * * * *

(f) Standard generator interconnection procedures and agreement.

(1) Every public utility that is required to have on file a non-discriminatory open access transmission tariff under this section must amend such tariff by adding the standard interconnection procedures and agreement contained in Order No. 2003, FERC Stats. & Regs. ¶ _____ (Final Rule on Generator Interconnection) or such other interconnection procedures and agreement as may be approved by the Commission consistent with Order No. 2003, FERC Stats. & Regs. ¶ _____ (Final Rule on Generator Interconnection).

(i) The amendment required by the preceding subsection must be filed no later than [insert date 60 days after publication in the FEDERAL REGISTER].

(ii) Any public utility that seeks a deviation from the standard interconnection procedures and agreement contained in Order No. 2003, FERC Stats. & Regs. ¶ _____ (Final Rule on Generator Interconnection), must demonstrate that the deviation is consistent with the principles of Order No. 2003, FERC Stats. & Regs. ¶ _____ (Final Rule on Generator Interconnection).

(2) The non-public utility procedures for tariff reciprocity compliance described in paragraph (e) of this section are applicable to the standard interconnection procedures and agreement.

(3) A public utility subject to the requirements of this paragraph may file a request for waiver of all or part of the requirements of this paragraph, for good cause shown. An application for waiver must be filed either:

(i) No later than [insert date 60 days after publication in the FEDERAL REGISTER], or

(ii) No later than 60 days prior to the time the public utility would otherwise have to comply with the requirements of this paragraph.

Docket No. RM02-1-000

- 203 -

The following Appendices will not be published in the Code of Federal Regulations.

Appendix A

**Flow Chart of the
Large Generating Facility Interconnection Process**