

FEDERAL ENERGY REGULATORY COMMISSION

Washington, D. C. 20426

July 24, 2015

OFFICE OF ENERGY PROJECTS

Project No. 14648-000–Idaho
Anderson Ranch Pumped Storage
Hydroelectric Project
Owyhee Hydro, LLC

Matthew Shapiro
Owyhee Hydro, LLC
1210 W. Franklin St., Ste. 2
Boise, ID 83702

Subject: Deficient Preliminary Permit Application

Dear Mr. Shapiro:

Your preliminary permit application filed on November 24, 2014, for the Anderson Ranch Pumped Storage Hydroelectric Project No. 14648-000 is deficient. The deficiencies are identified in the enclosed Schedule A.

The Commission strongly encourages electronic filing. Within 30 days, please file the requested information using the Commission's eFiling system at <http://www.ferc.gov/docs-filing/efiling.asp>. For assistance, please contact FERC Online Support at FERCOnlineSupport@ferc.gov, (866) 208-3676 (toll free), or (202) 502-8659 (TTY). In lieu of electronic filing, please send a paper copy to: Secretary, Federal Energy Regulatory Commission, 888 First Street NE, Washington, D.C. 20426. The first page of any filing should include docket number P-14648-000.

Failure to provide this information may result in your application being rejected. If you have any questions concerning this letter, please call Karen Sughrue at (202) 502-8556.

Sincerely,

David Turner, Chief
Northwest Branch
Division of Hydropower Licensing

Enclosure: Schedule A
cc: Public Files

DEFICIENCIES

1. Section 4.81(b)(1) of the Commission's regulations requires the application include the physical composition and dimensions of any dams, spillways, penstocks, powerhouses, tailraces, or other structures that would be part of the project. Please revise the application to provide the physical composition of the proposed penstocks, powerhouse, and tailrace, and the dimensions of the proposed powerhouse and tailrace.
2. Section 4.81(b)(4) of the Commission's regulations requires the application include the total estimated average annual energy production for any proposed project. Please revise your application to include this information.