

FEDERAL ENERGY REGULATORY COMMISSION
WASHINGTON, D.C. 20426

February 2, 2006

In Reply Refer To:
Midwest Independent Transmission
System Operator, Inc.
Docket Nos. ER06-255-000
ER06-255-001

Midwest Independent Transmission System Operator, Inc.
Attn: Sally L. Clore, Contracts Administrator
701 City Center Drive
Carmel, Indiana 46032

Dear Ms. Clore:

1. On November 29, 2005, as supplemented on December 9, 2005, you submitted for filing a Large Generator Interconnection Agreement (LGIA) among FirstEnergy Generation Corp. (FirstEnergy), Midwest Independent Transmission System Operator, Inc. (Midwest ISO), and American Transmission System, Inc. (ATSI). You state that the LGIA is based on Midwest ISO's *pro forma* LGIA provided in Attachment X of the Midwest ISO's Open Access Transmission and Energy Markets Tariff (Attachment X), including Midwest ISO's proposed revisions to Attachment X that are currently pending before the Commission in Docket No. ER05-1475-000, *et al.* In addition, Appendix C of the LGIA, Interconnection Details, includes, among other things, ATSI's generally applicable requirement that generators interconnecting to its system be designed with a power factor range of 0.95 leading to 0.90 lagging. You request waiver of the Commission's 60-day prior notice requirement to allow the LGIA to become effective November 30, 2005.

2. Notices of the November 29 and December 9, 2005 filings were published in the *Federal Register*, 70 Fed. Reg. 73,998 and 70 Fed. Reg. 76,803 (2005), with interventions or protests due on or before December 20, 2005, and December 30, 2005, respectively. No interventions or protests were filed.

3. On September 12, 2005, in Docket No. ER05-1475-000, Midwest ISO proposed revisions to its Attachment X, Midwest ISO's *pro forma* LGIA. That filing is pending. The proposed LGIA at issue in this proceeding includes the same proposed revisions that are pending in Docket No. ER05-1475-000, *et al.*

4. Insofar as the proposed LGIA reflects the same proposed revisions that are pending in Docket No. ER05-1475-000, *et al.*, the Commission accepts and suspends for a nominal period the proposed LGIA, and makes it effective, subject to refund and subject to the outcome of Docket No. ER05-1475-000, *et al.*, on November 30, 2005.¹ Midwest ISO is directed to file, within 30 days of an order either approving or directing revisions to Attachment X in Docket No. ER05-1475-000, *et al.*, any necessary revisions to the proposed LGIA to conform to any revisions to Attachment X adopted in Docket No. ER05-1475-000, *et al.*

By direction of the Commission.

Magalie R. Salas,
Secretary.

¹*Prior Notice and Filing Requirements under Part II of the Federal Power Act*, 64 FERC ¶ 61,139 at 61,984, *order on reh'g*, 65 FERC ¶ 61,081 (1993) (waiver of prior notice requirement will be granted for service agreements filed within 30 days after the commencement of service).